

R113 2170

N.W. corner **BUILDING DIVISION — BUILDING INSPECTOR'S REPORT CARD** \$10.00

of Lot #3, Ptn of
Rancho Del Paso

TYPE BUILDINGS

PERMIT NO. E-2940	LOCATION	3210 - Northgate Blvd.		A-6
DATE Dec. 28-62	PURPOSE	Const. foundation for garage move-		
ZONE R-1	OWNER	J. Brower & L. Wilson 3212-Northgate		
	ARCH'T	GI 3-4708		
	CONT'R	Dan Neves 2016 - 9th Street		
VAL. \$800.	STORIES	ROOMS	APTS.	SIZE 570 sq.ft.
INSP.	DATE	BLDG. TYPE	OCCUPANCY GROUP	
FORM				
JOIST				
FRAME				
SHEET ROCK				
FINAL	2-9-65	<i>J. Barbato</i>		

DATE	SPECIAL CONDITIONS OF WORK -- REMARKS
11-28-65	Pt Grite - Electrical plumbing. 2 x 6 joist to stand, cut to make back. Pipe for berth not large enough
11-4-65	Pt Grite - Electrical plumbing. 2 x 6 joist to stand, cut to make back. Pipe for berth not large enough
1-14-66	Pt Grite - Numerous (stems) Loose
1-20-66	Pt Grite - Corrections not made Coast
B-3-66	Pt Grite - Corrections not made Coast
	COMPLETE AND OK

INSPECTOR