

R 336 F 91-95

BUILDING DIVISION — BUILDING INSPECTOR'S REPORT CARD \$155.50

TYPE BUILDINGS

PERMIT NO. H-8668	LOCATION 3009 - P Street A-2
DATE Sept. 8-72	PURPOSE Remodel office building
ZONE C-4	OWNER Tom. Kiernan Co. Same
	ARCH'T Donald T. Daves 5237-Overbrook Way
	CONTR Stathos Const. Co. 94-Parklite Cir.

VAL. \$50,000.	STORIES 1	ROOMS	APTS.	SIZE 8,000 sq. ft.
-----------------------	---------------------	-------	-------	------------------------------

INSP.	DATE	BLDG. TYPE V no Hr	OCCUPANCY GROUP F-2	PHONE (O) (C) 421 1997
-------	------	------------------------------	-------------------------------	----------------------------------

FORM

JOIST

FRAME *10-27-72* *Welding*

SHEET ROCK *11-9-72* *Welding*

M.C. *8-7-73* *M. Collins*

FINAL

DATE	SPECIAL CONDITIONS OF WORK — REMARKS
10-24-72	P.C. frame not ready Callaway
10-25-72	P.C. frame - not ready working
11-8-72	P.C. sp. section of frame reduced
1-8-73	Corridor width <input checked="" type="checkbox"/> Wadding
1-22-73	P.C. final - tape marking in Callaway
3-5-73	P.C. final - exit lights not installed Handmons
	P.C. final - Mechanical not final Callaway

COMPLETE
AND OK

INSPECTOR