

CITY OF SACRAMENTO
1231 I Street, Sacramento, CA 95814

Permit No: 9906975
Insp Area: 4

Site Address: 2360 HARVARD ST SAC
Parcel No: 277-0041-013

Sub-Type: ACOM
Housing (Y/N): N

CONTRACTOR
JAMES D FREEMAN ELECTRIC
6735 32ND ST
SAC CA 95660

OWNER
AUBLE JAMES W
601 MILLS RD
SACRAMENTO CA 95864

ARCHITECT

Nature of Work: NEW 200AMP MAIN SERVICE-3 PHASE, FOR NEW 3 PHASE RECEPTACLE

CONSTRUCTION LENDING AGENCY : I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name _____ Lender's Address _____

LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

✓ License Class License Number 636376 Date 6/2/99 Contractor Signature James D Freeman

OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code: any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00):

____ I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

____ I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

____ I am exempt under Sec. _____ B & PC for this reason: _____

Date _____ Owner Signature _____

IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and hereby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

X Date 6/2/99 Applicant/Agent Signature James D Freeman

WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations:

____ I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

~~____~~ I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier LEGION INS CO Policy Number WC1-0576102 Exp Date 10/01/1999

____ (This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

✓ Date 6/2/99 Applicant Signature James D Freeman

WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.

THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.

ISSUED

10/18/1999

JUN 29 1999

SEND LETTERS TO:

Name: JAMES FREEMAN
Attention: _____
Address: _____
City/State/Zip: _____

100% BILLING SACRAMENTO FRONT PAGE ONLY
DEVELOPMENT SERVICES DIV
50% BILLING
NO BILLING

W.A. # 57715

SMUD COMMITMENT LETTER

Thank you for submitting your plans for 2360 HARVARD for an electric service commitment. Your cooperation enables us to give you the best service possible, as well as provide for your future requirements.

We are returning one copy of your plans indicating the service location and other requirements checked below. Our commitment is subject to changing conditions and, as a result, may not be valid after twelve months.

Please contact the Estimator if additional information is desired.

Estimator: M. DURKIN (M.A.) Telephone (916) 732- 5764

Service will be: Overhead Underground

Volts: / Phase: 3 Wire: 4 Type: DELTA

(Street light service voltage will be the same as above.)

- Transformer pad required: Yes No SMUD Dwg. _____
- Conduit required: Yes No (see sketch)
- Right-of-way required: Yes No
- Transformer protection required: Yes No see sketch and SMUD Dwg. _____
- Primary pull box required: Yes No Number: SMUD Dwg. _____
- Service box required: Yes No Number: SMUD Dwg. _____
- Switchgear pad required: Yes No Number: SMUD Dwg. _____
- Street light service box required: Yes No (see sketch)

Other requirements: See enclosed Booklet Prints

*A maximum fault current of 20,800 amps symmetrical is based on the largest transformer that could be needed to serve the Single Combined main sizes of 200 amps.


Metering will be outside, if possible. If in a meter room, door must be keyed for SMUD key. Contact the Estimator for details.

*If future load growth necessitates increasing the main switch size, the available fault current should be recalculated

NOTE: This commitment letter may be required by local inspection authority as part of its plan check requirement

④ 3/0 Copper
 2 1/2" rigid 10
 200 amp Disconnect (Nuts & Washers Main)
 Safety System (Delta)

1 1/2" Galvanized Eye Bolt as per spec.



JUN 30 1999

ISSUED


CITY OF SACRAMENTO DEVELOPMENT SERVICES DIV

RECEIVED 1993
 6-30-99
 2 1/2" CONN.

200

(Outdoor)


EX 1 1/2" Galvanized Gas Bond w/#6 COPPER



This set of plans and specifications must be kept on the job at all times and it is unlawful to make any changes or alterations to the same without written permission from the Building Inspection Division.
 The approval of this plan and specification SHALL NOT be held to permit or approve the violation of any City Ordinance or State Law.

④ 3/0 Copper

~~3/0 Copper~~



(Indoor)

④ #6 Equipment w/ #6 approved for purpose

ITE.
 200 amp 3Ø Sub Panel (42 Space) Surface Mount.

1" Galvanized water Main w/#6 Copper

17260 Harvard St