

R149 7-184-193

| | | | | | |
|-------------------------------------|-----------------------|--|-----------------|---------------|--------------|
| Lot 313 | | BUILDING DIVISION — BUILDING INSPECTOR'S REPORT CARD | | | \$40.00 |
| Carella Gardens #11 & 12 | | TYPE BUILDINGS | | | R180 9161 |
| PERMIT NO. | LOCATION | | A-5 | | |
| F-2169 | 1642 - Neihart Avenue | | | | |
| DATE | PURPOSE | Plan #122 | | | |
| Nov 3-65 | OWNER | George W. Reed 920-9th St. | | | |
| ZONE | ARCH'T | | | | |
| R-1 | CONTR | Owner same 441-4941 | | | |
| VAL. | \$10,600. | STORIES | ROOMS | APTS. | SIZE |
| | | | | 289-gar. | 1116 sq. ft. |
| INSP. | DATE | BLDG. TYPE | OCCUPANCY GROUP | PHONE (O) (C) | |
| FORM | 12-9-65 | Calloway | | | |
| JOIST | 12-16-65 | Lapier | | | |
| FRAME | 1-30-66 | Parbato | | | |
| SHEET ROCK | 1-31-66 | Parbato | | | |
| FINAL | 3-21-66 | Dana Fuller | | | |

| DATE | SPECIAL CONDITIONS OF WORK—REMARKS |
|-----------------|---|
| 12-15-65 | Plumbing - Not ready Pied |
| 1-27-66 | L.S.R. - Not ready Pied |
| 3-24-66 | D. J. Lind - " Fireplace damper won't stay open 2 Blue pipes not supported properly. Chapin |
| | |
| | |
| | |
| | |
| | |
| COMPLETE AND OK | INSPECTOR |