

BUILDING DIVISION—BUILDING INSPECTOR'S REPORT CARD

TYPE VII BUILDINGS

PERMIT NO. <i>Richy</i>	LOCATION <i>3624 Sac Blvd</i>		
DATE <i>SSU</i>	PURPOSE <i>Remodeling &amp; Interior Rep.</i>	ROOMS	APTS.
ZONE <i>APR 27</i>	OWNER <i>P. Hart, 3624 Sac Blvd</i>		PHONE
SACRAMENTO BUILDING DIVISION	ARCH'T	CONT'R <i>[Signature]</i>	
	VAL. <i>58</i>	STORIES	SIZE

FOUNDATION	STORY	BSMT	1	2	3	ROOF		
Ex Wall	Joints						Chimneys	Cement Tests
	Beams and Girders						Fire Place	
Int Wall	Studs and Columns						Gas Water Heater	
	Bridging Fire Stops						Heater Closet	
Piers	Fire Escape Stand Pipes						Furnace	Window Courts
	Metal Lath						Boiler Room	
	Stairs						Elevator Shaft	

DATE	CONDITION OF WORK—REMARKS
6/10/27	Made inspection of barn being built on rear of lot with new & old lumber instructed
	owner to put in additional bracing & girts.

COMPLETED  
AND O. K.

Inspector