

CITY OF SACRAMENTO
1231 I Street, Sacramento, CA 95814

Permit No: 0513551

Insp Area: 1
Thos Bros: 297C3

Site Address: 900 2ND ST SAC
Parcel No: 006-0012-037

Sub-Type: COM
Housing (Y/N): N

CONTRACTOR
ROBERT HUDSON ELECTRIC
5753 AUBURN BLVD # 4
SACRAMENTO CA 95861

OWNER
COOK ROBERT C
1108 2ND ST
SACRAMENTO, CA 95814

ARCHITECT

Nature of Work: PAPERLESS - C/O LIKE FOR LIKE 200AMP BREAKER FROM 600AMP SWITCHBOARD

CONSTRUCTION LENDING AGENCY : I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name _____ Lender's Address _____

LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class C10 License Number 575774 Date 9-8-05 Contractor Signature Robert Hudson

OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00);

_____, I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

_____, I, as owner of the property, am exclusively contracting with licensed contractors to construct _____ (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

I am exempt under Sec. _____ B & PC for this reason: _____

Date _____ Owner Signature _____

ISSUED
CITY OF SACRAMENTO
SEP 08 2005
DOWNTOWN PERMIT CENTER

IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and hereby authorize representative(s) of this city to enter upon the above mentioned property for inspection purposes.

Date 9-8-05 Applicant/Agent Signature Robert Hudson

WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations:

_____, I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

_____, I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier STATE FUND Policy Number 1536715-00 Exp Date 10/01/2005

_____, (This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Date 9-8-05 Applicant Signature Robert Hudson

WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.

THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.



2190 South Kalamath St. Denver, Colorado 80223
 Phone: (800) 394 4232 | Cell: (303) 881 2271
 Warehouse: (303) 937 9665 | Fax: (303) 937 9674
 Email: Sales@RockyMountainElectrical.com

Molded Case Breaker Test Report

05/3551
 900 200 st

Manufacturer: PENNSYLVANIA

Test Report Number: _____

Breaker Catalog Number: SFBC200

Long Time Delay Curve: _____ to _____ @ 300%±10%

Instantaneous Range: Tested at High= _____ ±10%

Tested at Low= _____ ±10%

Long Time Delay

A Phase: 35.153

B Phase: 35.126

C Phase: 34.917

Adjustment: _____

Adjustment: _____

Adjustment: _____

Instantaneous

A Phase: 969

B Phase: 853

C Phase: 1038

Adjustment: _____

Adjustment: _____

Adjustment: _____

DI.RO Reading

A Phase: _____

B Phase: _____

C Phase: _____

Adjustment: _____

Adjustment: _____

Adjustment: _____

Mega Ohms

Breaker Closed: A-B: _____

B-C: _____

C-A: _____

Breaker Open: A-A: _____

B-B: _____

C-C: _____

Arc Chutes:

Contacts:

Mechanical Operation:

Test Machine: Multi-Amp CB-8160

Multi-Amp CB-9116

Multi-Amp CB-9110

Test Technician: DALLAS

Test Date: 8-31-05

CIRCUIT BREAKERS
201 HARRIS AVENUE
SACRAMENTO, CA 95838
(916) 567-0771

Circuit Breakers Plus
201 Harris Avenue #12
Sacramento, CA 95838
916) 567-0771 Fax (916) 567-0773
1-800-244-2828
ur website: www.circuitbreakersplus.com

NO. 1012
Call - 870-1076
Office - 978-0121
0513551

CHART #542729231000735
MINAL #LK152062
E #89/31/05 TIME #12:01
CON #00101 REF # #000
RE #MASTERCARD EXP #08/08
COUNT #*****0046
TH #037009
S CODE #0

electric

SHIP TO: Will Call

Robert
MIKE

VIA
DATE SHIPPED
8-31-05

SALE \$ 533.56

APPROVED

PHONE ORDER

SIGNATURE
PLEASE IMPRINT CARD
I AGREE TO PAY ABOVE TOTAL AMOUNT
ACCORDING TO CARD ISSUER AGREEMENT

TOP COPY MERCHANT
BOTTOM CUSTOMER

THANK YOU (12)

DESCRIPTION	UNIT PRICE	UNIT TOTAL
ANIA SF3-C-200	575	575.00
21-0000-8506-		
66-emp 2107		

<input type="checkbox"/> CASH	<input type="checkbox"/> NEW (FACTORY WARRANTY)		SUB TOTAL	575.00
<input type="checkbox"/> CHECK #	<input type="checkbox"/> NEW SURPLUS (CBP WARRANTY)	<input type="checkbox"/> FED EX	TAX	44.56
<input checked="" type="checkbox"/> VISA/MC	<input checked="" type="checkbox"/> RECONDITIONED (CBP WARRANTY)	<input type="checkbox"/> AIR FREIGHT	FREIGHT	14.00
<input checked="" type="checkbox"/> ACCOUNT	<input checked="" type="checkbox"/> USED (CBP WARRANTY)		TOTAL	633.56
<input type="checkbox"/> COD	<input type="checkbox"/> AS IS			

Signature: _____

All returns subject to 25% restocking fee, after 50 days. 50%.
Please refer to terms and conditions of sale on reverse side hereof

PLEASE PAY FROM THIS INVOICE

White - File Pink - File Canary - Customer Gold - Packing Slip

CITY OF SACRAMENTO
 PLANNING & BUILDING DEPARTMENT
 BUILDING DIVISION
 WWW.CITYOFSACRAMENTO.ORG
 Help Line: 1-916-264-5656 OR 1-866-EZ-PERMIT
 Inspection: 1-916-808-4677



Downtown Permit Center 1-916-264-8807
 1231 I Street, Suite 200, Sacramento, CA 95814

North Permit Center 1-916-808-2364
 2101 Arena Blvd., Suite 200, Sacramento, CA 95834

Fax # 916-264-1901

FAXED PERMIT APPLICATION

(certain restrictions apply)

ISSUED
CITY OF SACRAMENTO

Faxed request must be received in this office by 3:00 P.M. to be processed the following work
 Note: Contractors must have a current certificate of Worker's Compensation Insurance.

SEP 08 2005

Note: Work started before a Building Permit is issued will be subject to grand fee.

DOWNTOWN PERMIT CENTER

IN ORDER TO PROCESS THIS REQUEST, ALL THE FOLLOWING INFORMATION MUST BE PROVIDED:

RESIDENTIAL APARTMENTS (4+ units per building) COMMERCIAL (limited)

Job Address: 900 2nd Street Unit # _____ Contract Price \$ 1200.00

Contact Person: Robert Hudson Contact Phone: 916 870 1076

Property Owner: Cook and Co. Contractor: Robert Hudson Electric #9

Address: 1108 2nd Street Address: 5753 Auburn Blvd. #9

City/State/Zip: Sacramento, CA City/State/Zip: Sacramento, CA 95841

Phone: 448 2300 Phone: 338 5323 FAX: 978-9883

NATURE OF REQUEST: Indicate from the selections below & provide details under description of work.

Reroof (excluding tile)
 Tear-Off
 Resheet
 House Garage
 # Stories: _____
 # Squares: _____
 Material:
 Siding
 Wood
 T-111
 Horiz
 Vinyl
 Stucco
 *Design Review approval may be required.

HVAC Installations
 Change-out New
 Heat Pump
 Package
 Split system
 Roof mount
 Cut-in
 Heat pump or elect unit to gas
 Wall furnace
 Other (describe below)
 Value of duct work: _____
 Equipment: \$ _____
 Cut-in: \$ _____
 * Design Review approval may be required.

Water Heater (Residential Only)
 Gas Electric
 Change-out
 Electric to Gas
 Relocate
 New
 Dry Rot or Termite Damage Repair (Describe Locations Below)
 *Design Review approval may be required.

Minor Electric and/or Minor Plumbing (Residential Only)
 Electric Service Change # _____
 New electric circuits
 Re-wire
 Water Service Replacement
 Sewer Service Replacement
 Gas Line Replacement
 Re-plumb
 Water Waste

Public Utilities Safety Inspection (Residential and single apartment units Only)
 SMUD PG&E
 * NOTE: Correction Notice items will require an additional building permit.

DESCRIPTION OF WORK:

Remove weak 200A, 3 Pole Circuit breaker from existing 600A Switchboards. Install new circuit breaker same type manuf. Circuit breaker feeds existing subpanel at. *Bill N. 2/1/05*