

CITY OF SACRAMENTO

Permit No: 0217089

1231 I Street, Sacramento, CA 95814

Insp Area: 3

Thos Bros: 317 E1

Site Address: 2332 MARSHALL WY SAC

Sub-Type: RES

Parcel No: 013-0073-011

Housing (Y/N): N

CONTRACTOR

OWNER

ARCHITECT

MALCOLM GILMOUR
2332 MARSHALL WY
SACRAMENTO CA 95818

Nature of Work: RROOF HOUSE 1.5 STORY W/15 SQS COMP

CONSTRUCTION LENDING AGENCY: I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name Lender's Address

LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class License Number Date Contractor Signature

OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00);

I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

I am exempt under Sec. B & PC for this reason:

Date 11/27/02 Owner Signature

IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and herby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

Date 11/27/02 Applicant/Agent Signature

WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations:

I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier Policy Number Exp Date

(This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Date 11/27/02 Applicant Signature

WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.

THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.

OWNER-BUILDER VERIFICATION

ATTENTION PROPERTY OWNERS

An owner-builder building permit has been applied for in your name and bearing your signature.

Please complete and return this information in the envelope provided at your earliest opportunity to avoid unnecessary delay in processing and issuing your building permit. No building permit will be issued until this verification is received.

1. I personally plan to provide the major labor and materials for construction of the proposed Improvement (yes or no) \_\_\_\_\_
2. I (have/have not) \_\_\_\_\_ signed an application for A building permit for the proposed work.
3. I have contracted with the following person (firm) to provide the proposed construction:

Name \_\_\_\_\_ Address \_\_\_\_\_  
City \_\_\_\_\_ Telephone \_\_\_\_\_  
Contractors License No. \_\_\_\_\_

4. I plan to provide portions of the work, but I have hired the following person to coordinate, Supervise, and provide the major work.

Name \_\_\_\_\_ Address \_\_\_\_\_  
City \_\_\_\_\_ Telephone \_\_\_\_\_  
Contractors License No. \_\_\_\_\_

5. I will provide some of the work but I have contracted (hired) the following to provide the Work indicated:

Name	Address	Phone	Type of work
KLM ROOFING			

Signed W. H. M. Y. Linn

Job Address 2332 MARSHALL WY, SACRAMENTO CA 95818

Permit No: 0217089

PERMIT NO.  
0217089

CITY OF SACRAMENTO  
2101 ARENA BLVD, #200  
BUILDING INSPECTIONS DIVISION

AREA NO.  
33R

WHEN CORRECTIONS HAVE BEEN MADE, CALL 264-5191 FOR REINSPECTION OF WORK.

JOB LOCATION 2332 MARSHALL WY 1082

INSPECTION REQUESTED ROOF FINAL No IN PROGRESS

THE UNDERSIGNED  BUILDING  PLUMBING  MECHANICAL  ELECTRICAL  
INSPECTOR THIS DAY INSPECTED THIS STRUCTURE FOR THE REQUESTED INSPECTION AND FOUND THE FOLLOWING VIOLATIONS OF CITY AND/OR STATE LAWS GOVERNING SAME:

① PLYWOOD SHEATHING IS REQUIRED TO BE INSTALLED PER A.P.A. SPECIFICATION. ALL HORIZONTAL EDGES SHALL HAVE NOMINAL 1X WOOD SUPPORTS.

② PLYWOOD SHEATHING IS REQUIRED TO BE FASTENED PER A.P.A. & U.B.C REQUIREMENT FASTEN ALL SHEATHING 12" O.C INTO FIELD STUDS, 6" O.C AT EDGES.

③ SHINGLES ARE REQUIRED TO BE INSTALLED PER MANUFACTURE SPECIFICATION. FASTENERS ARE REQUIRED TO PENETRATE THROUGH LAMINATED AREA OF MATERIAL; STAPLES SHALL BE PLACED HORIZONTAL. RE-FASTEN ALL SHINGLES PER SPECIFICATION.

808-5258

INSPECTOR Kyle Calvey

DATE 5/6/83

BUILDING INSPECTIONS 808-5716

INSPECTOR'S COPY

PERMIT NO.

0217089

CITY OF SACRAMENTO  
2101 ARENA BLVD, #200  
BUILDING INSPECTIONS DIVISION

AREA NO.

3R

WHEN CORRECTIONS HAVE BEEN MADE, CALL 264-5191 FOR REINSPECTION OF WORK.

JOB LOCATION 2332 MARSHALL WY 2 OF 2

INSPECTION REQUESTED ROOF FINAL No IN PROGRESS

THE UNDERSIGNED  BUILDING  PLUMBING  MECHANICAL  ELECTRICAL  
INSPECTOR THIS DAY INSPECTED THIS STRUCTURE FOR THE REQUESTED INSPECTION AND FOUND THE FOLLOWING VIOLATIONS OF CITY AND/OR STATE LAWS GOVERNING SAME:① ALL PLUMBING SOIL STACK VENT PIPES SHALL  
EXTEND MIN. 6" ABOVE ROOF. EXTEND ALL IN  
APPROVED MANNER② SOIL STACK VENT FLASHINGS ARE DAMAGED  
REPLACE WITH NEW 26 GA GALVANIZED - COUNTER  
FLASH ALL IN APPROVED MANNER (RUBBER COLLAR  
OR METAL CONE)③ FRONT CHIMNEY BACK SADDLE & SIDE  
FLASHING ARE BADLY DAMAGED & RUSTED.  
REPLACE ALL DAMAGED/WORN CHIMNEY  
FLASHINGS WITH MIN. 26 GA GALVANIZED  
METAL. INSTALL 26 GA STEP FLASHINGS &  
COUNTERFLASH ALL IN APPROVED MANNER.④ COVER EXPOSED PLYWOOD BETWEEN CHIMNEY  
& FRONT ENTRY

INSPECTOR

KYLE CALANCA

DATE

5/6/03

BUILDING INSPECTIONS 808-5716

INSPECTOR'S COPY