

23210 7/19/68

| | | | | | |
|----------------------|--|--|-----------------|---------------|--------------------------------|
| Lot 52 | | BUILDING DIVISION — BUILDING INSPECTOR'S REPORT CARD | | | \$61.00 |
| Parkway Greens #2 | | TYPE BUILDINGS | | | |
| PERMIT NO. F-7875 | LOCATION 5075 Scarborough Way | | | A-5 | |
| DATE Jul. 10/67 | PURPOSE Const. dwlg. with garage & covered patio | | | | |
| | OWNER Jack Cole 7497 Loma Verde Way | | | | |
| ZONE R-1 | ARCH'T | | | | |
| | CONTR Owner Same | | 421-0512 | | |
| VAL. \$17,100. | | STORIES 1 | ROOMS | APTS. | 380 gar. SIZE 1,763 sq. ft. |
| INSP. | DATE | BLDG. TYPE | OCCUPANCY GROUP | PHONE (O) (C) | |
| FORM | | Larsen | | | |
| JOIST | 9-8-67 | Larsen | | | |
| FRAME | 11-15-67 | Larsen | | | |
| SHEET ROCK | 11-30-67 | Nimmerson | | | |
| FINAL | 12-5-68 | | | Patio letter | |

| DATE | SPECIAL CONDITIONS OF WORK — REMARKS |
|---------|--|
| 8-4-67 | Pt Form - not used <i>Lesson</i> |
| 8-7-67 | Pt Form - <i>Abandoning 3' side use</i> <i>5'</i> <i>Count</i> |
| 8-8-67 | Pt Form - clear out footings. Drop <i>into footings</i> <i>Lesson</i> |
| 8-25-67 | Pt Slab footings not wide or <i>deep enough</i> <i>Lesson</i> |
| 8-28-67 | All footings & slab <i>Count</i> |
| 9-6-67 | Pt Crit - <i>irregularities</i> <i>Lesson</i> |
| 11-2-67 | COMPLETE AND OK Pt Form - <i>not used</i> <i>Lesson</i> |
| 11-8-67 | Pt Form - <i>not used</i> <i>Lesson</i> |

INSPECTOR