

BUILDING DIVISION-BUILDING INSPECTOR'S REPORT CARD

TYPE BUILDINGS

PERMIT No. 1976-A	LOCATION 2608 - S Street	
DATE 9/4/34	PURPOSE Erect private garages	
ZONE Mult. Fam	OWNER Ben Karlovich	
	ARCH'T Owen	
VAL. 12500	STORIES	ROOMS
		APTS.
		SIZE
Light Shafts		Elevator Shafts
Vent Shafts		Boiler Rooms
Owner's Inspector		Sprinkler System
Lath		Gas Vents
Fire Escapes		Chimneys
Stand Pipes		Skylights

DATE	CONDITION OF WORK-REMARKS
9/11/34	1st/ASP. Cement Floor for Poi Garage ^{OK} A.W. Campbell ✓
	Owner did not call up for inspection. Owner was
	building; Brute Wall on line 4" thick with 2 Rebar's
	Told Owner this wall would have to be increased
	to <u>8"</u> in thickness. The rest of frame O.K. A.W. Campbell
	COMPLETE AND O. K. INSPECTOR