

DATE	CONDITION OF WORK-REMARKS
12/5/33	1 ST /NSP. 4" x 4" R.W. Posts Erected and set 18" in ground and located 3 ft from property line. O.K. A.W. Campbell
12/20/33	2 ND /NSP. Frame. Carpenter installed girders in center of garage as rafters were over span permitted.
	4 TH /NSP. 6 Stall Veh. Garage (3 enclosed) (3 open) completed
12/20/33	COMPLETE AND O.K. Allen A. Campbell INSPECTOR