

R207, F247-252

BUILDING DIVISION — BUILDING INSPECTOR'S REPORT CARD \$97.

Port. of Rancho		TYPE BUILDINGS			
Del Paso					
PERMIT NO.	F-6032		LOCATION 2211 - Royale Rd.	A-6	
DATE	Dec. 9-66		PURPOSE Constr. Dwelling with att. gar. cov. terr		
ZONE			OWNER William G. Gannon	2160 - Royale Rd.	
			ARCH'T Spore & White	2950 - 23rd Street	
			CONT'R Smoothwall, Inc.	2160 - Royale Rd.	
VAL.	\$31,000.	STORIES	ROOMS	APTS.	768 gar. SIZE 3200 sq. ft.
INSP.	DATE	BLDG. TYPE	V no-hr	OCCUPANCY GROUP	(O) (C) 927-2961
FORM	12-30-66	New			
JOIST					
FRAME	1-25-66	Risks			
SHEET ROCK	1-27-67	Risks 2-1-67 Risks			
FINAL	3-28-67	Risks			

DATE	SPECIAL CONDITIONS OF WORK — REMARKS
12/19/66	Pt down Not ready Callaway
1-23/67	P.T. Frame - Same Room needs ventilation. Solid
	Glass no opening for ventilation. 2x6 ceiling joint
	need end blocking. Rials
3/27/67	ILLUMINOUS CEILING IN KITCHEN HAS BEEN REMOVED TO MEET MIN CEILING HGTs OF 7'-6"
	COMPLETE AND OK INSPECTOR