

CITY OF SACRAMENTO

1231 I Street, Sacramento, CA 95814

Permit No: 0107651

Insp Area: 1

Thos Bros: 297C3

Site Address: 545 DOWNTOWN PL SAC

Parcel No: 006-0087-053

SUITE 1111

Sub-Type: REM

Housing (Y/N): N

CONTRACTOR

LENNEN
4708 ST. ANDREWS DR
STOCKTON, CA. 95219

OWNER

WESTFIELD DEVELOPMENT
11601 WILSHIRE BLVD, 12TH FLOOR
LOS ANGELES, CA 90025

ARCHITECT

Nature of Work: RETAIL REMODEL

CONSTRUCTION LENDING AGENCY : I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name _____

Lender's Address _____

LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class B 799168 License Number _____ Date 9-17-01 Contractor Signature Jessame Lennen

OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00);

____ I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

____ I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

____ I am exempt under Sec. _____ B & PC for this reason: _____

Date _____ Owner Signature _____

IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and hereby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

Date 9/17/01 Applicant/Agent Signature Jessame Lennen

WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations:

____ I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

____ I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier State fund Policy Number 001471-00 ^{Group 7B} Exp Date 7-31-02

____ (This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Date 9-17-01 Applicant Signature Jessame Lennen

WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.

THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.

CITY OF SACRAMENTO

**60 DAY TEMPORARY
Certificate of Occupancy**
For Information Contact (916) 264-5716

Building Address: 545 Downtown Plaza Suite 1111 Permit No. 01-07651

Building Use: Retail: DBA 21 Forever Occupancy: M

Building Owner: Westfield Development Construction Type: I-FR

Owner Address: 11601 Wilshire Blvd. 12th fl. Los Angeles Sprinkled? Yes No

Portion of Building Occupied: Suite 1111 Area: 7,605 Sq. Ft.

Specific purpose for temporary occupancy and/or conditions/limitations of temporary occupancy: **FOR STOCKING ONLY**

AS OF 11/9/01 OK FOR TEMPORARY OCCUPANCY PER R. YASUI & R. HEINS.

11/07/01 *Keith A. Will* DENNIS RICHARDSON
Date By:Print Sign CITY BUILDING OFFICIAL

[TCO approvals: RCY, DLV, KAW, SB]

BC 109.4 TEMPORARY CERTIFICATE

If the Chief Building Official finds that no substantial hazard will result from occupancy of any building or portion thereof before the same is completed, a temporary Certificate of Occupancy may be issued for the use of a portion or portions of a building or structure prior to the completion for the entire building or structure.

POST IN A CONSPICUOUS PLACE

101

APPLICATION FOR COMMERCIAL BUILDING PERMIT

CITY OF SACRAMENTO
DEVELOPMENT SERVICES DIVISION
PERMIT SERVICES SECTION

1231 I Street, Rm. 200
Sacramento, CA 95814 (916) 264-7619 FAX 264-7046

ACTIVITY #

0107651

Insp. Area

1C

Applicant MUST complete ALL Unshaded areas

ADDRESS ~~547 L STREET~~ 545 DOWNTOWN PL. Suite 1111

PARCEL # _____

CONTACT

Name TISHA PEEBLES / EXPRESS PERMITS

Street Address 1327 POST AVE STE. H

City/State/Zip IRVINE, CA 92614

Phone 310.328.6300 FAX 310.328.7142

E-mail: _____

LICENSED CONTRACTOR Lic No. # _____

Name _____

Address _____

City/State/Zip _____

Phone _____ FAX _____

E-mail: _____

ARCHITECT/ENGINEER

Name SUNG YOUNG LEE / EXPRESS PERMITS

Address 1327 POST AVE STE. H

City/State/Zip IRVINE, CA 92614

Phone 310.328.6300 FAX 310.328.7142

E-mail: _____

OWNER

Name WESTFIELD CORP

Address 11601 WILSHIRE BLVD, 12th FL.

City/State/Zip LOS ANGELES, CA 90025

Phone 310.478.4456 FAX _____

E-mail: _____

→ Will permittee have any employees on the jobsite? No Yes → INSURANCE CO: _____

→ WORKER'S COMPENSATION POLICY # _____ EXPIRATION DATE: _____

NATURE OF WORK IN DETAIL: COMMERCIAL TENANT IMPROVEMENT
COMPLETE DEMO OF PARTITIONALS, FINISHES, FIXTURES,
NEW PARTITIONALS, TRACES, TEXTURES, ADDITION TO EXTERIOR LIGHT,
AND MECHANICAL ALTERATIONS

OCCUPANT/TENANT: FOREVER 21 VALUATION: \$ 94,750.00

FLOOD STATUS:				S.C.A.T.						
JOB DESCRIPTION		BLDG	SHELL	APT	TI ()	REM (X)	SW	FIRE	ADD	OTH
INSPECTION DISCIPLINES		BLDG	MECH	PLUMB	ELEC	SITE	FIRE			
# Stories	1st flr Area	Total Area	Use Zone	Occp Group	Const type	Fire Req. <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N	Fed Code	Vio. File		
				B-2	I	<input checked="" type="checkbox"/> SPR / <input checked="" type="checkbox"/> ALARM	18	[H]	[Quad]	
<input checked="" type="checkbox"/> B	<input checked="" type="checkbox"/> L	<input checked="" type="checkbox"/> P	<input checked="" type="checkbox"/> M	<input checked="" type="checkbox"/> E	<input checked="" type="checkbox"/> F	S	D	PW	UTIL	

COMMENTS: _____

REGIONAL SANITATION FEES? Yes No HEALTH DEPARTMENT? Yes No

WATER FLOW TEST FOR NEW BUILDINGS OR ADDITIONS? Provided Faxed

Forever 21

Downtown Plaza

547 L Street Space #1111

Sacramento, California

Balance Report



Symbol Sheet

ADJ P.D.	ADJUSTED PITCH DIAMETER
BHP	BRAKE HORSEPOWER
C.D.	CEILING DIFFUSER
C.E.	CEILING EXHAUST OR RETURN
D.D.	DIRECT DRIVE
DIA	DIAMETER
DNA	DATA NOT AVAILABLE
DNL	DATA NOT LISTED
F.E.	FLOOR EXHAUST OR RETURN
F.S.	FLOOR SUPPLY
FLA	FULL LOAD AMPS
FSR	FLOOR SUPPLY REGISTER
H.P.	HORSEPOWER
L.S.D.	LINEAR SUPPLY DIFFUSER
N.A.	NOT ACCESSIBLE
N.I.	NOT INSTALLED
N.T.	NOT TAKEN DUE TO NO VALID LOCATION
NZ	NOZZLE
O	DIAMETER
O.A. MIN	OUTSIDE AIR MINIMUM
OPEN	NO TERMINAL DEVICE INSTALLED
P.P.	PERFORATED PLATE
S.F.	SERVICE FACTORS
S.P.	STATIC PRESURE
SWE	SIDEWALL EXHAUST OR RETURN
SWS	SIDEWALL SUPPLY
V	VOLTS
SD	SUPPLY DIFFUSER
RG	RETURN GRILLE

Alco

MECHANICAL

DATE
PAGE
UNIT

Lic. #746138

FAN TEST SHEET

AREA SERVED SALES 10 TON FAN CARRIER.

MOTOR NAMEPLATE DATA

MFG	FRANKLIN BLECK / CARRIER		
HP	2.5	V	460
PH	3PH	SF	2.15
FLA	4.5	RPM	1725
MOTOR FRAME #	DNL56		

SHEAVE DATA: MOTOR

DIA	5.75	SHAFT	5/8
ADJ P.D.	MID	FIXED	-
BELT CENTER LINE	18.25		

FAN NAMEPLATE DATA

MFG	CARRIER
MODEL	38QH0120AAA
TYPE	FAN SECTION
SIZE	10 TON
SERIAL #	9E0006432

SHEAVE DATA: FAN

DIA	ALT 74	SHAFT	-
BELTS	1	-	-
DIRECT DRIVE	-	-	-

SCHEDULED/SUBMITTED DATA

FAN CFM	6,000
TSP	DNL
RPM	"
BHP	"
R.A.	"
O.S.A.	650 CFM

DESIGN OUTLET/INLET

TOTAL CFM	5895
-----------	------

TESTED OUTLET/INLET

TOTAL CFM	5960
-----------	------

TRAVERSE TOTAL

TOTAL CFM	NT
-----------	----

MOTOR TEST DATA

VOLTS	460 - 3PH
AMPS	4.2
RPM	1742
BHP	1.75
SPEED SET.	-

FAN TEST DATA

RPM	1234
SP-	0.74
SP+	0.07
TSP	0.81
FILTER SP	0.04
CFM TOTAL	5039
CFM RA	5785
CFM OA MIN.	650
SCP	-

TEMPS	EAT	LAT
HEATING		
COOLING	76	80

Room No.	Outlet No.	Code	Size	Effective Area	Required		Tested	
					FPM Vel	CFM	FPM Vel	CFM
SALES	1	CD	24"φ			750		695
	2	"	"			"		745
	3	"	"			"		725
	4	"	"			"		736
	5	"	"			"		740
	6	"	"			"		735
	7	"	"			"		735
	8	"	"			"		735
TOTAL SUPPLY								
SALES	9	CR 2	24x30			DNL		5785
TOTAL RETURN								

Remarks:

Alco MECHANICAL

Lic. #746138

DATE
PAGE
UNIT

FAN TEST SHEET

AREA SERVED SALES VAV 1

MOTOR NAMEPLATE DATA

MFG	FRANKLIN BLECK		
HP	3/4	V	277
PH	2	SF	.75
FLA	3.2	RPM	1700
MOTOR FRAME #	DNL56		
SHEAVE DATA: MOTOR			
DIA	4.75	SHAFT	1/2
ADJ P.D.	-	FIXED	-
BELT CENTER LINE	-		

FAN NAMEPLATE DATA

MFG	ENVIRO-TEC		
MODEL	DNL		
TYPE	-		
SIZE	-		
SERIAL #	1DNL		
SHEAVE DATA: FAN			
DIA	4	SHAFT	1/2
BELTS	-		
DIRECT DRIVE	- 1/2		

SCHEDULED/SUBMITTED DATA

FAN CFM	2400
TSP	DNL
RPM	"
BHP	"
R.A.	"
O.S.A.	"

MOTOR TEST DATA

VOLTS	277
AMPS	3.2
RPM	1700
BHP	.75
SPEED SET.	-

DESIGN OUTLET/INLET

TOTAL CFM	2350
-----------	------

TESTED OUTLET/INLET

TOTAL CFM	2250
-----------	------

TRAVERSE TOTAL

TOTAL CFM	NT
-----------	----

FAN TEST DATA

RPM	1675
SP-	.74
SP+	.81
TSP	.08
FILTER SP	.05
CFM TOTAL	2250
CFM RA	2242
CFM OA MIN.	MAIL AIR
SCP	-

TEMPS

	EAT	LAT
HEATING		
COOLING	76	80

Room No.	Outlet No.	Code	Size	Effective Area	Required		Tested	
					FPM Vel	CFM	FPM Vel	CFM
SALES	1	CD	24"φ			800	785	
	2	"	"			"	775	
	3	"	"			"	775	
TOTAL SUPPLY								
	4	RA	14x24			DNL	2242	
TOTAL RETURN								

Remarks:

MAIL SUPPLY AIR OSA SET @ 100% - 75°
15% - 75° & up

Lic. #746138

FAN TEST SHEET

AREA SERVED SALLES VAN 2

MOTOR NAMEPLATE DATA

MFG	FRANKLIN BLECK		
HP	3/4	V	277
PH	2	SF	.75
FLA	3.2	RPM	1700
MOTOR FRAME #	DNL56		
SHEAVE DATA: MOTOR			
DIA		SHAFT	
ADJ P.D.		FIXED	-
BELT CENTER LINE			

SCHEDULED/SUBMITTED DATA

FAN CFM	1600
TSP	DNL
RPM	"
BHP	"
R.A.	"
O.S.A.	"

MOTOR TEST DATA

VOLTS	277
AMPS	3.2
RPM	1700
BHP	.75
SPEED SET.	-

FAN TEST DATA

RPM	1575
SP-	.74
SP+	.81
TSP	.08
FILTER SP	.05
CFM TOTAL	1545
CFM RA	1520
CFM OA MIN.	
SCP	

FAN NAMEPLATE DATA

MFG	ENVILLO TECH		
MODEL	DNL		
TYPE	"		
SIZE	"		
SERIAL #	"		
SHEAVE DATA: FAN			
DIA	4	SHAFT	1/2
BELTS			
DIRECT DRIVE	-	1/2	

DESIGN OUTLET/INLET

TOTAL CFM	1590
-----------	------

TESTED OUTLET/INLET

TOTAL CFM	1545
-----------	------

TRAVERSE TOTAL

TOTAL CFM	NT
-----------	----

TEMPS	EAT	LAT
HEATING		
COOLING	76	80

Room No.	Outlet No.	Code	Size	Effective Area	Required		Tested	
					FPM Vel	CFM	FPM Vel	CFM
SALLES	1	CD	24"4			750	753	
	2	"				"	755	
TOTAL SUPPLY								
	3	RA	14x24			DNL	1520	
TOTAL RETURN								

Remarks:

MASS SUPPLY AIR, USA 100% - 75°
1590 - 75° ± OP

Lic. #746138

FAN TEST SHEET

AREA SERVED : SAVES VAN 3

MOTOR NAMEPLATE DATA

MFG	FRANKLIN BLECK		
HP	3/4	V	277
PH	2	SF	.75
FLA	3.2	RPM	1700
MOTOR FRAME #	DNL56		
SHEAVE DATA: MOTOR			
DIA		SHAFT	
ADJ.P.D.		FIXED	-
BELT CENTER LINE			

SCHEDULED/SUBMITTED DATA

FAN CFM	1600
TSP	DNL
RPM	"
BHP	"
R.A.	"
O.S.A.	"

MOTOR TEST DATA

VOLTS	277
AMPS	3.2
RPM	1700
BHP	.75
SPEED SET.	-

FAN NAMEPLATE DATA

MFG	ENVIRO TECH		
MODEL	DNL		
TYPE	"		
SIZE	"		
SERIAL #	"		
SHEAVE DATA: FAN			
DIA	4	SHAFT	1/2
BELTS	-		
DIRECT DRIVE	1/2		

DESIGN OUTLET/INLET

TOTAL CFM	1578
-----------	------

TESTED OUTLET/INLET

TOTAL CFM	1560
-----------	------

TRAVERSE TOTAL

TOTAL CFM	NT
-----------	----

FAN TEST DATA

RPM	1575
SP-	.74
SP+	.81
TSP	.08
FILTER SP	.05
CFM TOTAL	1560
CFM RA	1550
CFM OA MIN.	-
SCP	-

TEMPS

	EAT	LAT
HEATING		
COOLING	76	80

Room No.	Outlet No.	Code	Size	Effective Area	Required		Tested	
					FPM Vel	CFM	FPM Vel	CFM
SAVES	1	CD	24"φ			800	790	
	2	CD	"			"	770	
TOTAL SUPPLY								
	3	RA	14x24			DNL	1550	
TOTAL RETURN								

Remarks: MAIL AIR SUPPLY OSA 100% - 75°
1570 - 75° - UP

Alco MECHANICAL

DATE
PAGE
UNIT

Lic. #746138

FAN TEST SHEET

AREA SERVED: SAWS VAY 4

MOTOR NAMEPLATE DATA

MFG	FRANKLIN BLECK		
HP	3/4	V	277
PH	2	SF	.75
FLA	3.2	RPM	1700
MOTOR FRAME #	DNL56		
SHEAVE DATA: MOTOR			
DIA	4	SHAFT	1/2
ADJ P.D.	7	FIXED	1/2
BELT CENTER LINE	↑		

FAN NAMEPLATE DATA

MFG	EVIRO TEC		
MODEL	DNL		
TYPE	}		
SIZE	}		
SERIAL #	}		
SHEAVE DATA: FAN			
DIA	4	SHAFT	1/2
BELTS			
DIRECT DRIVE	1/2		

SCHEDULED/SUBMITTED DATA

FAN CFM	2400
TSP	DNL
RPM	}
BHP	}
R.A.	}
O.S.A.	

DESIGN OUTLET/INLET

TOTAL CFM	2345
-----------	------

TESTED OUTLET/INLET

TOTAL CFM	2350
-----------	------

TRAVERSE TOTAL

TOTAL CFM	147
-----------	-----

MOTOR TEST DATA

VOLTS	277
AMPS	3.8
RPM	1700
BHP	.75
SPEED SET	1

FAN TEST DATA

RPM	1670
SP-	.74
SP+	.81
TSP	.08
FILTER SP	.05
CFM TOTAL	2350
CFM RA	2345
CFM OA MIN.	-
SCP	-

TEMPS	EAT	LAT
HEATING		
COOLING	76	80

Room No.	Outlet No.	Code	Size	Effective Area	Required		Tested	
					FPM Vel	CFM	FPM Vel	CFM
SAWS	1	CO	24"φ			800	750	
	2	}				}	792	
	3				810			
TOTAL SUPPLY								
	4	RA	14x24			DNL	2345	
TOTAL RETURN								

Remarks:

MAIL SUPPLY AIR USA 100% - 75°

1590 ABOVE 75°

Alco MECHANICAL

Lic. #746138

DATE
PAGE
UNIT

FAN TEST SHEET

AREA SERVED STORAGE VAY 5

MOTOR NAMEPLATE DATA

MFG	FRANKLIN BLECK		
HP	3/4	V	277
PH	2	SF	175
FLA	3.2	RPM	1700
MOTOR FRAME #	DNL56		
SHEAVE DATA: MOTOR			
DIA	4	SHAFT	1/2
ADJ P.D.	-	FIXED	- 1/2
BELT CENTER LINE	-		

FAN NAMEPLATE DATA

MFG	ENVIRO TECH		
MODEL	DNL		
TYPE	}		
SIZE	}		
SERIAL #	}		
SHEAVE DATA: FAN			
DIA	4	SHAFT	1/2
BELTS			
DIRECT DRIVE	- 1/2		

SCHEDULED/SUBMITTED DATA

FAN CFM	1800
TSP	DNL
RPM	
BHP	
R.A.	
O.S.A.	

DESIGN OUTLET/INLET

TOTAL CFM	1795
-----------	------

TESTED OUTLET/INLET

TOTAL CFM	1790
-----------	------

TRAVERSE TOTAL

TOTAL CFM	NT
-----------	----

MOTOR TEST DATA

VOLTS	277
AMPS	2.9
RPM	1675
BHP	1.75
SPEED SET.	

FAN TEST DATA

RPM	1675
SP-	1.76
SP+	1.06
TSP	1.07
FILTER SP	1.04
CFM TOTAL	1790
CFM RA	1785
CFM OA MIN.	-
SCP	-

TEMPS	EAT	LAT
HEATING		
COOLING	76	80

Room No.	Outlet No.	Code	Size	Effective Area	Required		Tested	
					FPM Vel	CFM	FPM Vel	CFM
STORAGE	1	CD	24x24			900	856	
	2	"	"				875	
TOTAL SUPPLY								
	3	RA	12x24			DNL	1785	
TOTAL RETURN								

Remarks:

MAN AIR SUPPLY S.S.A 100% - 75°
15% ABOXIS 75°

Alco

MECHANICAL

Lic. #746138

DATE
PAGE
UNIT

FAN TEST SHEET

AREA SERVED : Fitting Room VAV 6

MOTOR NAMEPLATE DATA

MFG	FRANKLIN BLECK		
HP	3/4	V	277
PH	2	SF	175
FLA	3.2	RPM	1700
MOTOR FRAME #	DNL56		
SHEAVE DATA: MOTOR			
DIA	4	SHAFT	1/2
ADJ P.D.		FIXED	1/2
BELT CENTER LINE	+		

SCHEDULED/SUBMITTED DATA

FAN CFM	2400
TSP	DNL
RPM	}
BHP	
R.A.	
O.S.A.	

MOTOR TEST DATA

VOLTS	277
AMPS	3.0
RPM	1025
BHP	1.5
SPEED SET.	-

FAN TEST DATA

RPM	1025
SP-	.74
SP+	.03
TSP	.07
FILTER SP	.05
CFM TOTAL	2350
CFM RA	2242
CFM OA MIN.	-
SCP	-

FAN NAMEPLATE DATA

MFG	ENVIRO TECH		
MODEL	DNL		
TYPE	}		
SIZE			
SERIAL #			
SHEAVE DATA: FAN			
DIA	4	SHAFT	1/2
BELTS	-		
DIRECT DRIVE	-	1/2	

DESIGN OUTLET/INLET

TOTAL CFM	2375
-----------	------

TESTED OUTLET/INLET

TOTAL CFM	2350
-----------	------

TRAVERSE TOTAL

TOTAL CFM	NJ
-----------	----

TEMPS	EAT	LAT
HEATING		
COOLING	76	80

Room No.	Outlet No.	Code	Size	Effective Area	Required		Tested	
					FPM Vel	CFM	FPM Vel	CFM
FIT.	1	CD	14x14			900	915	
	2	CD	14x14			700	870	
STOR	3	CD	24x24			600	610	
1243C	4	CD	24x24			DNL	510	
TOTAL SUPPLY							92	MALL RA
FIT	5	RA	24x24			DNL	2342	
STOR	6	RA	24x24			DNL	85	
ENRC	7	RA	24x24			DNL	84	
	8	RA	14x24			DNL	2342	
	9	RA	TOTAL RETURN			DNL	87	MALL RA
				18x8				

Remarks:

MALL AIR SUPPLY O.S.A 100% - 75°
1540 ABOVE 75°

CITY OF SACRAMENTO

CERTIFICATE OF OCCUPANCY

For Information Contact (916) 264-5716

Building Address: 545 DOWNTOWN PL #1111 Permit No. 0107651

Building Use: RETAIL DBA: 21 FOREVER Occupancy: M

Building Owner: WESTFIELD DEVELOPMENT Construction Type: 1FR

Owner Address: LOS ANGELES, CA Sprinkled? [] Yes [] No

Portion of Building Occupied: SUITE 1111 Area: 7605 Sq. Ft.

2/15/02 DHAN  DENNIS RICHARDSON
Date By:Print Sign CITY BUILDING OFFICIAL

[Finaled By:RCY,WJR,BCK,SB]

This Certificate, issued pursuant to the requirements of Section 109 of the Uniform Building Code, certifies that at time of issuance the described portion of the building has been inspected for compliance with the Uniform Building Code, as adopted per Title 15 of the Sacramento City Code for the group and division of occupancy and use for which the proposed occupancy is classified. Issuance of this certificate shall not be construed as an approval of a violation of any Codes, or Federal, State and City Laws or Ordinances. Certificates presuming to give authority to such violation shall not be valid. This certificate shall be posted in a conspicuous place on the premises and shall not be removed except by the City Building Official. No changes shall be made in the character of occupancy or use without approval of the City Building Official.

POST IN A CONSPICUOUS PLACE