

5/23 7 92. 13⁹

BUILDING DIVISION — BUILDING INSPECTOR'S REPORT CARD

\$10.00

TYPE BUILDINGS

PERMIT NO. E-4131	LOCATION	3260 - Nordyke Drive		A-6
DATE Jun 7-63	PURPOSE	Const. 1-room addition to dwelling		
ZONE R-1	OWNER	Robert Beltram	Same	
	ARCH'T	482-6190		
	CON'TR	Pennant Homes 4616-El Camino Ave.		
VAL. \$1,000.	STORIES	ROOMS	APTS.	117 sq.ft. ^{SIZE}
INSP.	DATE	BLDG. TYPE	OCCUPANCY GROUP	PHONE (O) (C)
FORM	6-11-63	Const		
JOIST				
FRAME	6-25-63	Const		
SHEET ROCK	7-11-63	Collins		
FINAL	7-16-63	M. Callaway		

DATE	SPECIAL CONDITIONS OF WORK — REMARKS
6-15-63	PT of survey. Correct
6-17-63	PT toenail - all studs 1x4 across ceiling joists. Noted in error garage firewall studs must be 16" O.C. Correct
6-17-63	PT another footing and post under 456 girders. Correct
	COMPLETE AND OK
	INSPECTOR