

CITY OF SACRAMENTO

1231 I Street, Sacramento, CA 95814

Permit No: 0506433

Insp Area: 1

Thos Bros: 297E4

Site Address: 724 21ST ST SAC

Parcel No: 003-0176-011

Central City Design Review

Sub-Type: REP

Housing (Y/N): N

CONTRACTOR

TUDOR CONSTRUCTION AN RESTORATION
10291 IRON ROCK WY
ELK GROVE, CA 95624

OWNER

724 21ST ST
SACRAMENTO, CA 95814

ARCHITECT

DITIRRO JULES/THOMAS WENDEL

Nature of Work: REPAIR DRY ROT @ FRONT ENTRY STAIRWAY REPLACET READS & SIDINGS SUBJECT TO FIELD INSPECTION, SEE CERTIFICATE OF APPROPRIATENESS)

CONSTRUCTION LENDING AGENCY : I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name _____ Lender's Address _____

LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class B License Number 429045 Date 5-9-05 Contractor Signature [Signature]

OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00);

I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

CITY OF SACRAMENTO
NEIGHBORHOODS, PLANNING
AND DEVELOPMENT SERVICES

I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

I am exempt under Sec. _____ B & PC for this reason: _____

Date _____ Owner Signature _____

IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and herby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

Date 5-9-05 Applicant/Agent Signature [Signature]

WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations:

I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

~~I~~ I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier STATE FUND Policy Number 1796952-04 Exp Date 04/01/2006

(This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Date 5-9-05 Applicant Signature [Signature]

WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.



DEVELOPMENT SERVICES
DEPARTMENT
CITY OFFICES @ 13TH & I STREETS
(916) 264-5543 Fax

CITY OF SACRAMENTO
CALIFORNIA

PRESERVATION OFFICE
1231 "I" STREET, RM 200
SACRAMENTO, CA 95814
(916) 808-5962 Phone

CERTIFICATE OF APPROPRIATENESS

File Number:	PB05-038	Applicant/Owner:	Jules and Tom Ditirro
Address:	724 21 ST Street	Date Filed:	April 28, 2005
Classification:	Contributing	Date Approved:	April 28, 2005
Staff Contact:	Ellen A. Schmidt, 808-5962	APN:	003-0176-011


Project Description: Dryrot repairs at front porch and stairs.


Findings of the Preservation Director/Office: The Preservation Director has determined the project to be consistent with the Secretary of Interior's Standards for the Treatment of Historic Properties and the goals and policies of Chapter 15.124 of Title 15 of the Sacramento City Code.

The Preservation Director has reviewed the proposed project, and approves it with the following conditions of approval:

1. Replace only the damaged treads and risers at front stairway. New treads and risers shall match existing in kind.
2. Replace damaged and missing trim pieces at stairs to match original in kind
3. Retain existing columns. Replace damaged and missing trim at column capitals.
4. Replace damaged soffit material at southwest corner of building. New soffit material shall match existing in kind.
5. Provide new cap at cheek wall. New cap shall match existing in kind. Replace damaged siding at cheek walls and provide new to match existing in kind.
6. In kind shall mean to match material, profile, dimension and placement.
7. Paint all new wood work to match existing.
8. Provide new downspout on west face of building. Paint to match adjacent surfaces.
9. NO OTHER EXTERIOR WORK IS ALLOWED.
10. This approval shall expire in three years from the approval date

NOTE: Photos have been attached for clarification of work.


Ellen A. Schmidt, Associate Planner


Date

THIS IS NOT A PERMIT TO COMMENCE WORK OR CHANGE OF OCCUPANCY. PERMITS FROM THE BUILDING DIVISION (AND ANY OTHER APPROPRIATE AGENCIES) MUST BE SECURED BEFORE WORK IS STARTED OR OCCUPANCY IS CHANGED.



CITY OF SACRAMENTO

www.cityofsacramento.org

Help Line: 1-916-808-5656 OR 1-866-EZ-PERMIT
 Inspection Request: 1-916-808-7622

Downtown Permit Center
 1231 I Street, Suite 200
 Sacramento, CA 95814
 North Permit Center
 2101 Arena Blvd., Suite 200
 Sacramento, CA 95834

Fax # 916-264-1901

MINOR PERMIT APPLICATION

Date: _____

Faxed/web request must be received in this office by 3:00 P.M. to be processed the following workday. Contractors must have a current certificate of Worker's Compensation Insurance. Note: Work started before a Building Permit is issued will be subject to quad fee.

Permits requiring Plan Review are not eligible for the MINOR PERMIT PROGRAM

Design Review and Historic Preservation approval may be required if job address is located in those areas (additional forms may be required)

IN ORDER TO PROCESS THIS REQUEST, ALL THE FOLLOWING INFORMATION MUST BE PROVIDED:

Job Address: 724 21st Blvd Type: RESIDENTIAL APARTMENTS (4+ units per building) COMMERCIAL (limited)
 CONTACT INFO Name: Marek Pencuski Phone #: 997-6944 Email: _____ Contract Price: 2000.00

Property Owner: Tom Dittore Contractor: Tyler Denski License #: 429845

Address: 724 21st Street Address: 10221 Bromlock way

City/State/Zip: Sacramento CA 95814 City/State/Zip: Elk Grove CA 95624

Phone: 916-4384 Phone: 997-6944 Fax: 905-2172

Nature of Work: Provide description of work & indicate type of work in selections below. Pre-Registered? YES NO Registration # _____

Description of Work: repair dry rot on steps

<input type="checkbox"/> Reroof (excluding tile) <input type="checkbox"/> Tear-Off <input type="checkbox"/> Resheet <input type="checkbox"/> House <input type="checkbox"/> Garage # Stories: _____ # Squares: _____ Material: _____ <input type="checkbox"/> Siding <input type="checkbox"/> Wood <input type="checkbox"/> T-111 <input type="checkbox"/> Horiz <input type="checkbox"/> Vinyl <input type="checkbox"/> Stucco	<input type="checkbox"/> HVAC Installations (Residential Only) <input type="checkbox"/> Change-out <input type="checkbox"/> New <input type="checkbox"/> Heat Pump <input type="checkbox"/> Package <input type="checkbox"/> Split system <input type="checkbox"/> Roof mount <input type="checkbox"/> Cut-in <input type="checkbox"/> Heat pump or elect. unit to gas. <input type="checkbox"/> Wall furnace <input type="checkbox"/> Other (describe below) Value of duct work: _____ Equipment: \$ _____ Cut-in: \$ _____	<input type="checkbox"/> Water Heater (Residential Only) <input type="checkbox"/> Electric <input type="checkbox"/> Gas <input type="checkbox"/> Change-out <input type="checkbox"/> Electric to Gas <input type="checkbox"/> Relocate <input type="checkbox"/> New <input type="checkbox"/> Dry Rot or Termitie Damage Repair <input type="checkbox"/> Flooring/Joists <input type="checkbox"/> Mudstiff/Studs <input type="checkbox"/> Roof Structure <input type="checkbox"/> Exterior	<input type="checkbox"/> Minor Electric and/or Minor Plumbing (Residential Only) <input type="checkbox"/> Electric Service Change # amps _____ <input type="checkbox"/> New electric circuits <input type="checkbox"/> Re-wire <input type="checkbox"/> Water Service Replacement <input type="checkbox"/> Sewer Service Replacement <input type="checkbox"/> Gas Line Replacement <input type="checkbox"/> Re-plumb <input type="checkbox"/> Water <input type="checkbox"/> Waste	<input type="checkbox"/> Public Utilities Safety Inspection (Residential and single apartment units Only) <input type="checkbox"/> SMUD <input type="checkbox"/> PG&E * NOTE * Correction Notice items will require an additional building permit.
Office Use Only: Parcel #:	Date Received:	Date Issued:	Processor's Initials:	Permit #:

City of Sacramento
Development Services Department
PLANNING REVIEW FOR BUILDING PERMIT SUBMITTAL

ADDRESS: 724 21 st Street	APN: 003-0176-011
DRPB AREA / PUD / SPD: Boulevard Park District	ZONING: RO-BC
EXISTING LAND USE: Residential	
PROPOSED USE: Front porch and stair repair	
PLANNING STAFF WILL CHECK ONE OR MORE OF THE ITEMS BELOW:	
<input type="checkbox"/>	Planning review is NOT required.
<input type="checkbox"/>	Use is NOT allowed; applicant CANNOT submit for plan check.
<input type="checkbox"/>	Requires APPLICATION(s): PC ZA IR ER DR PB Required Planning application must be approved <i>before</i> project can be submitted for plan check
<input type="checkbox"/>	Application(s) IN PROGRESS: File Number: Application must be approved before project can be submitted for plan check.
<input checked="" type="checkbox"/>	Application(s) COMPLETED: File Number & approval date: PB05-038 (Approved 04-28-05) Building permit must conform to approved plans and comply with all conditions of approval. Do NOT accept applications for a building permit prior to the end of the 10-day appeal period.
<input checked="" type="checkbox"/>	Plans may be submitted for plan check. Plan checker(s) shall confirm compliance with Zoning Ordinance requirements and all applicable development standards <i>prior to issuance</i> of building permit.
<input checked="" type="checkbox"/>	Meets setback & lot coverage requirements as shown on site plan provided. (No change)
<input type="checkbox"/>	Plans to be submitted have been stamped/signed by Planning counter staff.
<input type="checkbox"/>	Route to SITE for plan check and inspection.
<input type="checkbox"/>	Route to SITE for inspection only , plan check not required.
<input type="checkbox"/>	Preliminary review ONLY ; the information on this form must be reviewed again and confirmed at the time of building permit submittal.
CONDITIONS AND COMMENTS: Must meet the conditions in PB05-038. No other planning issues.	
DATE: May 9, 2005	BY: Evan Compton 