

AIR SYSTEMS of SACRAMENTO, INC

3850 Happy Lane
Sacramento, CA 95827

DOUBLE DUCT VAV DISTRIBUTION REPORT

PROJECT Ford Motor Credit

SYSTEM: _____ DATE: 4-10-01

VAV NUMBER	OUTLET			DESIGN			PRELIMINARY			FINAL			NOTE
	No.	Type	Size	H Max	C Min	C Max	H Max	C Min	C Max	H Max	C Min	C Max	
VAV	1	SI	8			120			275			125	
2-12	2	SI	8			270			195			270	
	3	SI	8			270			295			260	
	4	SI	8			270			240			275	
	5	SI	8			270			355			300	
	6	SI	8			270			300			280	
	7	SI	8			270			415			265	
	8	SI	8			272			370			260	
					-	400			2445				
												2035	

REMARKS: _____

Brad Chesshire

AIR SYSTEMS of SACRAMENTO, INC

3850 Happy Lane
Sacramento, CA 95827

DOUBLE DUCT VAV DISTRIBUTION REPORT

PROJECT Ford Motor Credit

SYSTEM: _____

DATE: 4-10-01

VAV NUMBER	OUTLET			DESIGN			PRELIMINARY			FINAL			NOTE
	No	Type	Size	H Max	C Min	C Max	H Max	C Min	C Max	H Max	C Min	C Max	
VAV 2-8	1	SI	10			420			360			410	
	2	SI	10			420			490			420	
	3	SI	8			290			280			310	
				460	150	1130						1140	
VAV 2-9	1	SI	14			668			1100			670	
				270	120	670							
VAV 2-10	1	SI	10			410			510			410	
	2	SI	8			275			280			275	
				270	50	685						685	
VAV 2-11	1	SI	10			435			560			440	
	2	SI	14			760			1200			780	
				480	85	1190						1220	

REMARKS:

Brad Chesshire

APPLICATION FOR COMMERCIAL BUILDING PERMIT

CITY OF SACRAMENTO
 DEVELOPMENT SERVICES DIVISION
 PERMIT SERVICES SECTION

1231 I Street, Rm. 200
 Sacramento, CA 95814 (916) 264-7619 FAX 264-7046

ACTIVITY # <u>0102435</u>	Insp. Area <u>IC</u>
------------------------------	-------------------------

Applicant **MUST** complete ALL Unshaded areas

ADDRESS 1870 Gateway Oaks Dr Suite 220

PARCEL #

<p style="text-align: center;">CONTACT</p> <p>Name <u>Darrell Browning</u> Street Address <u>9050 Ranchview Ct</u> City/State/Zip <u>EIK Grove CA 95824</u> Phone <u>423-1105</u> FAX <u>685-5825</u> E-mail:</p>	<p style="text-align: center;">LICENSED CONTRACTOR Lic No. <u>46121</u></p> <p>Name <u>Browning Construction Inc.</u> Address <u>9050 Ranchview Ct</u> City/State/Zip <u>EIK Grove CA 95824</u> Phone: FAX: E-mail:</p>
<p style="text-align: center;">ARCHITECT/ENGINEER</p> <p>Name <u>Niska & Assoc.</u> Address <u>5500 Naylor Ave</u> City/State/Zip <u>Sacto 95825</u> Phone <u>925-0333</u> FAX: E-mail:</p>	<p style="text-align: center;">OWNER</p> <p>Name <u>BTU Crown Securities</u> Address <u>1870 Gateway Oaks Dr #110</u> City/State/Zip <u>Sacto 95833</u> Phone <u>569-1900</u> FAX <u>569-1911</u> E-mail:</p>

→ Will permittee have any employees on the jobsite? No Yes → INSURANCE CO: Coldwell
 → WORKER'S COMPENSATION POLICY: 713-20-6444 EXPIRATION DATE: 10-21-01

NATURE OF WORK IN DETAIL: 1st time F.I. 5018
1st time office fit
 OCCUPANT/TENANT: FORD MOTOR CREDIT UNION VALUATION: \$ 7,000.00

FLOOD STATUS:		S.C.A.T.							
JOB DESCRIPTION		SHELL	APT	TIC	REM()	SW	FIRE	ADD	OTH
INSPECTION DISCIPLINES		BLDG	MECH	PLUMB	ELEC	SITE	FIRE		
# Stories	1st flr Area	Total Area	Use Zone	Occp Group	Const type	Fire Re. Y N	Fed Code	Vio. File	
<u>3</u>		<u>5018</u>		<u>B</u>	<u>2-1H</u>	<u>Y</u>	<u>15</u>	[H]	[Quad]
B	L	P	M	E	F	S	D	PW	UTIL

COMMENTS: OK to proceed J.L.M., G.S.A., J.T., K.W.

REGIONAL SANITATION FEES? Yes No HEALTH DEPARTMENT? Yes No

WATER FLOW TEST FOR NEW BUILDINGS OR ADDITIONS? Provided Faxed

CITY OF SACRAMENTO
DEVELOPMENT SERVICES DIVISION

EXPRESS PLAN REVIEW

SUBMITTAL DATES					
1st Review		2nd Review		3rd Review	
IN	OUT	IN	OUT	IN	OUT
2/26/01	/ /	/ /	/ /	/ /	/ /

PLAN CHECK NO. _____
 ADDRESS: _____
 Commercial Residential

ACCEPTED BY: _____
 DATE: _____

DISCIPLINE	1ST REVIEW			2ND REVIEW			3RD REVIEW		
	Staff	Staff	Date	Staff	Staff	Date	Staff	Staff	Date
SAFETY	13	JT	3/1/01						
STRUCTURAL	13	JT	"						
MECHANICAL/PLUMBING	13/13	KAW	2/28/01						
ELECTRICAL	3	JM	2/29/01	13	JM	2/29/01			
FIRE	13	BJF	2-28-01						
PLANNING									

STAFF COMMENTS:

CITY OF SACRAMENTO

CERTIFICATE OF OCCUPANCY

For Information Contact (916) 264-5716

Building Address: 2870 GATEWAY OAKS DR Permit No.: 0102435
Building Use: OFFICE Occupancy: B
Building Owner: BTV CROWN EQUITIES Construction Type: II-IHR
Owner Address: SACRAMENTO, CA Sprinkled? Yes No
Portion of Building Occupied: SUITE 220 Area: 5018 Sq. Ft.
10/31/02
Date By: (Print) [Signature] Sign **DENNIS RICHARDSON**
CHIEF BUILDING OFFICIAL

[Finaled By:MW,JXE, AAC,FJ]

This Certificate, issued pursuant to the requirements of Section 109 of the Uniform Building Code, certifies that at time of issuance the described portion of the building has been inspected for compliance with the Uniform Building Code, as adopted per Title 15 of the Sacramento City Code for the group and division of occupancy and use for which the proposed occupancy is classified. Issuance of this certificate shall not be construed as an approval of a violation of any Codes, or Federal, State and City Laws or Ordinances. Certificates presuming to give authority to such violation shall not be valid. This certificate shall be posted in a conspicuous place on the premises and shall not be removed except by the Chief Building Official. No changes shall be made in the character of occupancy or use without approval of the Chief Building Official.

POST IN A CONSPICUOUS PLACE