

0518132

CERTIFICATE OF FIELD VERIFICATION & DIAGNOSTIC TESTING (Page 3-4 of 8) CF-4R

60 Moonlite Cir. <small>Project Address</small>	Ray O. Cook Co. / 829856 <small>Contractor Name / License No.</small>
Contractor Contact Michael McDermott	Telephone: 916-704-2810
HERS Rater <i>Michael McDermott</i>	Permit Number 05-18132
Certifying Signature	Sample Group Number 22642
Firm: Energy Analysis and Comfort Solutions, Inc.	Date: April 26, 2006
Street Address: PO Box 2233	Certificate Number CC14-1798363226
	HERS Provider: CalCERTS
	City/State/Zip: Orangevale / CA / 95662

Copies to: Homeowner, HERS Provider and Building Department
This CF-4R has been registered with the CalCERTS® registry in accordance with the Title 24 & Title 20 of the CCR.
CalCERTS® is an approved HERS provider by the California Energy Commission.

HERS RATER COMPLIANCE STATEMENT

The house was Tested Approved as part of sample testing, but was not tested.
As the HERS rater providing diagnostic testing and field verification, I certify that the house identified on this form complies with the diagnostic tested compliance requirements as checked on this form.

The installer has provided a copy of the CF-6R (Installation Certificate).

✓ THERMOSTATIC EXPANSION VALVE (TXV):	
Access is provided for inspection. The procedure shall consist of visual verification that the TXV is installed on the system and installation of the specific equipment shall be verified.	
HVAC System TXV	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail

CalCERTS - Certificate

CERTIFICATE OF FIELD VERIFICATION & DIAGNOSTIC TESTING (Page 5 of 8) **CF-4R**

60 Moonlite Cir. <small>Project Address</small>	Ray O. Cook Co. / 829856 <small>Contractor Name / License No.</small>
Michael McDermott <small>Contractor Contact</small>	05-18132 <small>Permit Number</small>
<i>Michael McDermott</i> <small>HERS Rater</small>	22642 <small>Sample Group Number</small>
<i>Michael McDermott</i> <small>Certifying Signature</small>	April 26, 2006 <small>Date</small>
Energy Analysis and Comfort Solutions, <small>Firm:</small> Inc.	HERS Provider: CalCERTS
PO Box 2233 <small>Street Address:</small>	Orangevale / CA / 95662 <small>City/State/Zip:</small>

Copies to: Homeowner, HERS Provider and Building Department
 This CF-4R has been registered with the CalCERTS® registry in accordance with the Title 24 & Title 20 of the CCR.
 CalCERTS® is an approved HERS provider by the California Energy Commission.

HERS RATER COMPLIANCE STATEMENT

The house was Tested Approved as part of sample testing, but was not tested.
 As the HERS rater providing diagnostic testing and field verification, I certify that the house identified on this form complies with the diagnostic tested compliance requirements as checked on this form.

The installer has provided a copy of the CF-68 (Installation Certificate).

HIGH EER AIR CONDITIONER:

Procedures for verification are available in RACM, Appendix RI.

1	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	EER values of installed systems match the CF-1R
2	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	For split systems, indoor coil is matched to outdoor coil
3	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	Time Delay Relay Verified (If Required)
HVAC System: Yes to 1 and 2; and 3 (if required) is a pass		<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail