

CITY OF SACRAMENTO

1231 I Street, Sacramento, CA 95814

Permit No: 9809012

Insp Area: 2

Site Address: 832 PROW CT SAC

Parcel No: 0240101013

Sub-Type: RES

Housing (Y/N): N

CONTRACTOR

ZIMMERMAN ROOFING
3560 RAMONA AV
SACRAMENTO, CA

95826

OWNER

GODDARD ROBERT J/LALE
832 PROW CT
SACRAMENTO CA

95822

ARCHITECT

Nature of Work: REMOVE OLD ROOF & REROOF W/PIONEER EVEREST TILE 4/12 PITCH

SFR 37 SFS

CONSTRUCTION LENDING AGENCY : I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name _____

Lender's Address _____

LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class C39 License Number 557559 Date 9-14-98 Contractor Signature Billy Coy

OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00);

I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

I am exempt under Sec. _____ B & PC for this reason: _____

Date _____ Owner Signature _____

IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and hereby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

Date 9-14-98 Applicant/Agent Signature Billy Coy

WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations:

I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier State Fund Policy Number 713 97002021 EXP: 10-1-98

(This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Date 9-14-98 Applicant Signature Billy Coy

WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.

THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.



DEPARTMENT OF
PLANNING AND DEVELOPMENT

CITY OF SACRAMENTO
CALIFORNIA

1231 I STREET
ROOM 200
SACRAMENTO, CA
95814-2998

Permit Services
916-264-7619
FAX 916-264-7046

Goddard at
832 Prow Ct
95822

TILE ROOF WORKSHEET

This worksheet must be filled out whenever any type of tile roof is applied for.

If the answer to question #5 is yes, a written engineering report from a registered engineer must be provided with each application.

- 1. BRAND AND MODEL OF TILE Pioneer Everwest
- 2. TILE WEIGHT PER SQUARE 730
- 3. WEIGHT OF ROOF SYSTEM PER SQUARE 180
- 4. TOTAL WEIGHT OF ROOF SYSTEM 910
- 5. DOES TOTAL WEIGHT OF ROOF SYSTEM EXCEED 750# PER SQUARE? YES NO
- 6. ROOF SLOPE 4/12

PLEASE PROVIDE A SEPARATE WORKSHEET FOR EACH APPLICATION INVOLVING A TILE ROOF.

All attached engine report

Goddard

Paul Zacher-Structural Engineers

4701 Lakeside Way
Fair Oaks, CA 95628

TEL: 916.961.3960
FAX: 916.961.3960
e-mail: pzacher@softcom.net

August 31, 1998

Zimmerman Roofing
3560 Ramona Avenue
Sacramento, CA 95826
TEL: 916.454.3667
FAX: 916.455.3784
TEL (Jeff): 916.392.1971
FAX (Jeff): 916.392.6853
FAX (Framer) : 916.383.5308

Attn.: Mr. Jeff Tucker,

re: Job 98199: GODDARD

Subject: Structural Investigation Report of the Roof for the Residence located at 832 Prow Court, Sacramento, CA 95822.

As requested by Mr. Jeff Tucker, this is a report to determine what needs should be addressed to correct any structural deficiencies of the roof. Paul Zacher visited the site August 28, 1998. The investigation was made to determine the existing condition of the structure. All information, data and analysis contained within this report is based on the 1994 Uniform Building Code.

The following is based on visual observations with no subsurface investigation being made.

DESCRIPTION:

Type of Facility: Residence.
Year Built: Estimated 1970's vintage.
Occupancy: Residential.
No. of Stories: One.
Dimensions: Approximately 2000 square feet with a first story plate height of 8 feet.

CONSTRUCTION:

Roof:

The roof covering will consist of Pioneer Light Weight Concrete Tile over 1/2" solid sheathing. The living area is conventionally framed with 2x6 rafters spaced at 24" on center. The garage area is framed with 2x6 rafters spaced at 24" on center and 2x6 cross ties spaced at 4'-0" on center.

① Provide wet spa stamp to cover better.
② Verify adequate collar ties or ridge support in field. Dick Matt R
9/11/98

PAUL ZACHER - STRUCTURAL ENGINEERS
4701 LAKESIDE WAY
FAIR OAKS, CA 95628
TEL: 916.961.3960
FAX: 916.961.3960

Title : ZIMMERMAN/ GODDARD **Job # 98199**
Dsgnr: P.K. ZACHER, S.E. **Date: 7:28AM, 31 AUG 98**
Description : ROOF INSPECTION

Scope : STRUCTURAL ENGINEERING

Rev. 510001

Timber Beam & Joist

Description Rafters and Beams

Timber Member Information

		2x6	2-2x6	4x8	4x10
Timber Section		2x6	2-2x6	4x8	4x10
Beam Width	in	1.500	3.000	3.500	3.500
Beam Depth	in	5.500	5.500	7.250	9.250
Le: Unbraced Length	ft	2.00	2.00	2.00	2.00
Timber Grade		Douglas Fir - Larch, Douglas Fir - Larch, Douglas Fir - Larch, Douglas Fir - Larch.			
Fb - Basic Allow	psi	875.0	875.0	875.0	875.0
Fv - Basic Allow	psi	95.0	95.0	95.0	95.0
Elastic Modulus	ksi	1,600.0	1,600.0	1,600.0	1,600.0
Load Duration Factor		1.250	1.250	1.250	1.250
Member Type		Sawn	Sawn	Sawn	Sawn
Repetitive Status		Repetitive	Repetitive	Repetitive	Repetitive

Center Span Data

Span	ft	12.00	15.25	15.50	16.00
Dead Load	#/ft	23.00	23.00	58.00	58.00
Live Load	#/ft	32.00	32.00	80.00	80.00

Results

Ratio = 0.9774 0.7785 0.9957 0.7071


Mmax @ Center	in-k	11.88	19.19	49.73	52.99
@ X =	ft	6.00	7.62	7.75	8.00
f _b : Actual	psi	1,570.9	1,268.5	1,622.0	1,061.7
F _b : Allowable	psi	1,607.3	1,629.5	1,628.9	1,501.5
		Bending OK	Bending OK	Bending OK	Bending OK
f _v : Actual	psi	55.7	36.0	58.7	46.2
F _v : Allowable	psi	118.8	118.8	118.8	118.8
		Shear OK	Shear OK	Shear OK	Shear OK

Reactions

@ Left End	DL	lbs	138.00	175.37	449.50	464.00
	LL	lbs	192.00	244.00	620.00	640.00
	Max. DL+LL	lbs	330.00	419.37	1,069.50	1,104.00
@ Right End	DL	lbs	138.00	175.37	449.50	464.00
	LL	lbs	192.00	244.00	620.00	640.00
	Max. DL+LL	lbs	330.00	419.37	1,069.50	1,104.00

Deflections

Center DL Defl	in	-0.322	-0.421	-0.424	-0.232
L/Defl Ratio		446.5	435.1	439.1	829.2
Center LL Defl	in	-0.449	-0.585	-0.584	-0.319
L/Defl Ratio		320.9	312.8	318.4	601.2
Center Total Defl	in	-0.771	-1.006	-1.008	-0.551
Location	ft	6.000	7.625	7.750	8.000
L/Defl Ratio		186.7	182.0	184.6	348.5



① ROOF PLAN - GODDARD
N.T.S.

