1231 I Street, Sacramento, CA 95814 Insp Area: Sub-Type: **ASFR** Site Address: 1328 ELOAH WY SAC Housing (Y/N): N 031-0103-004 Parcel No: **ARCHITECT** OWNER CONTRACTOR CUNNINGHAM 1328 ELOAH WY SACRAMENTO CA 95831 Nature of Work: ADD 446 SQ FT BEDROOM AND BATHROOM + 57 CVRD PORCH CONSTRUCTION LENDING AGENCY: I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C). Lender's Address Lender's Name LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect. Contractor Signature License Class License Number Date OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00); I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.) l, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code. The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a OF SACRAMENTO contractor(s) licensed pursuant to the Contractors License Law). B & PC for this reason: I am exempt under Sec. Owner Signature IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city of the permitting property of the permitten property of the permitting property of the permitten pe or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements. I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and herby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes. Date 10. 01 - 2000 Applicant/Agent Signature WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of penjury one of the following declarations: I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued. I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for

CITY OF SACRAMENTO

0011441

Permit No:

Exp Date

shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions. $\mathcal{E}/-200C$ Applicant Signature

Policy Number (This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued,I

which this permit is issued. My workers' compensation insurance carrier and policy number are:

WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.

Date of Request:	
By:	

CITY OF SACRAMENTO DEVELOPMENT SERVICES DIVISION PLANNING AND ZONING INFORMATION REQUEST

Project Address: 1328 Eloah Wn
Assessor's Parcel Number: 03/-0/03-004
Previous Use: SPIC.
Description of Request/Proposed Use: Add MBedvoon & Bath-
Is This a Change of Use?
Zoning Designation:
Comments: 10 planning entitlements required
Are There Any Planning Issues?: (circle one) YES
* Staff Site Plan Check Required? (Circle one) * Field Inspection Required? (Circle one) * Design Review/Preservation Required? (Circle one) * YES NO * YES NO
* Design Review/Preservation Required? (Circle one) YES NO Planning Review by/Date: 9/27/00

A list of items that must be reviewed by Planning is provided on the reverse side of this form.

MICROFILM AFTER FINAL

OWNER-BUILDER VERIFICATION

ATTENTION PROPERTY OWNERS

An owner-builder building permit has been applied for in your name and bearing your signature.

Please complete and return this information in the envelope provided at your earliest opportunity to avoid unnecessary delay in processing and issuing your building permit. No building permit will be issued until this verification is received.

1.	I personally plan to provide the major labor and materials for construction of the proposed Improvement (yes or no)					
2.	I (have have not) _ A building permit f	(have have not) signed an application to building permit for the proposed work.				
3.	I have contracted with the following person (firm) to provide the proposed construction:					
	Name TBA		_Address			
	City		Telephone			
	Contractors Licer	ise No.				
4 I plan to provide portions of the work, but I have hired the following person to coording Supervise, and provide the major work.						
	Name	Address				
	CityTelephone					
	Contractors Licen	se No				
5.	I will provide some of the work but I have contracted (hired) the following to provide the Work indicated:					
	Name	Address	Phone	Type of work		
	0 /					
Si	gned 771	nuly/				
Jo	b Address 3	18 ÉLDA	tt			
Pε	ermit No: O	144 R				

Robert A. Massetti, Architect 3710 Cone Court Rocklin, CA 95677 December 27, 2000

To Whom It May Concern Sacramento City Building Department

Plan Check No. 0011441R Residence Addition 1328 Eloah Way Sacramento, CA 95831

This to confirm that 5-1/2" long wedge anchors (1/2" or 7/8" round) may be used at the mudsill splice repairs, in lieu of 10" long anchors.

Sincerely.

Bob Massetti, Architect

Bol Masseth

cc: Harvey Nguyen

Robert A. Massetti, Architect 3710 Cone Court Rocklin, CA 95677 November 20, 2000

To Whom It May Concern Sacramento City Building Department

Plan Check No. 0011441R Residence Addition 1328 Eloah Way Sacramento, CA 95831

The nails to be used in the construction of this addition shall be the 0.113 size, as 6" on center, everywhere.

Sincerely.

Bot Massetti, Architect

cc: Harvey Nguyen

Robert A. Massetti, Architect 3710 Cone Court Rocklin, CA 95677 November 6, 2000

To Whom It May Concern Sacramento City Building Department

Plan Check No. 0011441R Residence Addition 1328 Eloah Way Sacramento, CA 95831

The Foundation Plan, Sheet A2, calls for 7 Simpson HD5A tie-downs to be installed around the concrete slab perimeter. Although they were not installed, the structure is stable enough with 1/2" anchor bolts spaced at 4'-0" on center maximum, with anchor bolts 6" from each corner.

Sincerely,

Bob Massetti, Architect

cc: Harvey Nguyen