

184 J 503

BUILDING DIVISION — BUILDING INSPECTOR'S REPORT CARD \$26.00

TYPE BUILDINGS

DOUBLE FEE

PERMIT NO. F-2763	LOCATION 3240 - San Diego Way			A-1
DATE Jan 11-66	PURPOSE Repair fire damage to duplex			
	OWNER L.W. Ing same			
ZONE R-2	ARCH'T <i>None</i>	<i>(See Permit F-5492)</i>		
	CONTR Owner same			
VAL. \$1,500.	STORIES	ROOMS	APTS.	SIZE
INSP.	DATE	BLDG. TYPE	OCCUPANCY GROUP	PHONE (O) (C)
FORM		<i>(renewed)</i>		
JOIST				
FRAME	<i>1-316-66</i>	<i>Plumber</i>		
SHEET ROCK	<i>1-316-66</i>	<i>Plumber (garage)</i>	<i>1-27-66</i>	<i>Plumber</i>
FINAL		<i>[Signature]</i>		

DATE	SPECIAL CONDITIONS OF WORK — REMARKS
1-19-66	Rt. frame - many studs & much
	shutting too. Panel inconsistent
	not 1/16" cc. Ceiling joists over
	spanned
8.16.67	Formwork not taped + tested 8/14-17.67

COMPLETE  
AND OK

INSPECTOR