

CITY OF SACRAMENTO
1231 I Street, Sacramento, CA 95814

Permit No: 0011509
Insp Area: 2

Site Address: 15 WATERCREST CT SAC
Parcel No: 031-1340-031

Sub-Type: NSFR
Housing (Y/N): N

CONTRACTOR
R.T. BELFORTH CONSTRUCTION
P.O. BOX 22652
SACRAMENTO CA 95822

OWNER
E & P POWELL/TEICHERT
15 WATERCREST CT
SACRAMENTO CA 95831

ARCHITECT

Nature of Work: NEW SFR, 3021 SF 1ST FLR, 2847 SF 2ND FLR (5868 SF TOTAL),
907 SF ATTCHD GAR, 32 SF CVRD PRCH

CONSTRUCTION LENDING AGENCY: I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name _____ Lender's Address _____

LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 7 of the Business and Professions Code and my license is in full force and effect.

✓ License Class B License Number 414065 Date 2/6/01 Contractor Signature R. Belforth

OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code: any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption: Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00).

____ I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

____ I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

____ I am exempt under Sec _____ B & PC for this reason: _____

Date _____ Owner Signature _____

IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and hereby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

✓ Date 2/6/01 Applicant Agent Signature R. Belforth

WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations:

____ I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued

____ I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier _____ Policy Number _____ Exp Date _____

→ ✓ (This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

✓ Date 2/6/01 Applicant Signature R. Belforth

WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.

THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.

White

DIAMOND WALL INSULATING STUCCO SYSTEM

ICBO Report #4004

JOB ADDRESS:

lot 91 15 WATERCREST
SACRAMENTO CA 95831

Date of Job Completion 11/15/01

PLASTERING CONTRACTOR:

Name: McCann Plastering, Inc.
Address: 80 Colfax Court Roseville CA 95678
Telephone No: (916) 784-2274
Contractor Number of Diamond Wall System # 2264

This is to certify that the exterior coating system on the building exterior at the above address has been installed in accordance with the evaluation report specified above and the manufacturer's instructions.

4/16/02
Date

[Signature]
Signature of authorized representative of
Plastering Contractor

This installation card must be presented to the building inspector after completion of work and before final inspection.

INSULATION CERTIFICATE

THIS IS TO CERTIFY THAT INSULATION HAS BEEN INSTALLED IN CONFORMANCE WITH THE CURRENT ENERGY REGULATIONS, CALIFORNIA ADMINISTRATION CODE, TITLE 24, STATE OF CALIFORNIA, IN THE BUILDING LOCATED AT:

SITE ADDRESS: LOT 91 STILLBREEZE WAY SACRAMENTO, CA
STREET CITY STATE

CEILINGS:

BLOW: MANUFACTURER GREENSTONE THICKNESS N/A R-VALUE N/A
 SQUARE FEET N/A # BAGS/LBS PER BAGS N/A

BATTS: MANUFACTURER JOHNS MANVILLE THICKNESS 13" R-VALUE 38
JOHNS MANVILLE

EXTERIOR WALLS:

MANUFACTURER JOHNS MANVILLE THICKNESS 3.5" R-VALUE 13
JOHNS MANVILLE

FLOOR INSULATION:

MANUFACTURER JOHNS MANVILLE THICKNESS 6.5" R-VALUE 19

AIR INFILTRATION: (TITLE 24)

YES NO

OTHER: _____

GENERAL CONTRACTOR: RL BELFORTE CONSTRUCTION LICENSE # _____

BY: _____ TITLE _____ DATE _____

INSULATION CONTRACTOR: WESTERN INSULATION LP LICENSE # 794484

BY: Jamie Blair TITLE AUTH. AGENT DATE 7/20/01
 JAMIE BLAIR

Certification of Compliance
School District Development

Part I—To be completed by the APPLICANT

Owner's Name/Address GILBERT, SANDY LINDENHOLZ
Project Address 15 WATERWELL ST
Parcel Number 031 1340-031 Lot No. 91
Subdivision Name STILLWATER No. of Units _____
Applicant's Signature [Signature] Title CONTRACTOR
Phone No. 916 375-7465 Date 2/5/01

Notice to Applicant: Pursuant to Government Code Section 66020(d), this will serve to notify you that the 90-day approval period in which you may protest the fees or other payment identified above will begin to run on the date in which the building or installation permit for this project is issued or on which they are paid to the district(s) or to another public entity authorized to collect them on behalf of the district(s), whichever is earlier.

Part II—To be completed by the BUILDING DEPARTMENT

Plan Identification Number 0011501
Building Type (check one) Residential Apartment/Condominium Commercial/Industrial
Square Feet of Chargeable Building Area 5868 # 5868
Signature/Title [Signature] Date 2/5/01

Part III—To be completed by the SCHOOL DISTRICT

School District MILPITAS Certificate No. 60912

Exempt Comments _____

Residential/Apartment/etc. Unit Square ft. x \$ 172 = \$ 10176
Commercial/Industrial _____ Square ft. x \$ _____ = \$ 804
Total fees collected..... 21012 = \$ 9922 ²⁸

This certification covers only the amount of square footage indicated above. Any additions or corrections to the square footage for this project will require an amendment to the Certificate of Compliance.

As the authorized school official, I hereby certify that the requirements of Government Code Section 65995 and any other authorized requirements have been complied with by the above signed applicant.

Signature _____ Date 2/5/01

Date of Request: _____

By: _____

CITY OF SACRAMENTO DEVELOPMENT SERVICES DIVISION
PLANNING AND ZONING INFORMATION REQUEST

Project

Address: 718 STILL BREEZE WAY

Assessor's Parcel Number: 031 1340 031

Previous Use: VACANT

Description of Request/Proposed Use: NEW CONSTRUCTION

RESIDENTIAL - SINGLE FAMILY

Is This a Change of Use? YES

Zoning Designation: E-1A PUD

Prior Applications for Project Site(P#, Z#, DRPB#): P916-048, P92-074

Comments: PER LOT PATTERSON - PD7P NOT REVIEWED PER SPEC IN

ENCLAVE PUD - GETBACKS & COVERAGE W/IN STANDARDS

NO DESIGN REVIEW

Are There Any Planning Issues?: (circle one) YES (NO)

* Staff Site Plan Check Required? (Circle one) YES (NO)

* Field Inspection Required? (Circle one) YES (NO)

* Design Review/Preservation Required? (Circle one) YES (NO)

Planning Review by/Date: [Signature] 9/27/2000

A list of items that must be reviewed by Planning is provided on the reverse side of this form.

MICROFILM AFTER FINAL

Richard Dills, S.E.

6111 Doubleton Court
Elk Grove, CA 95756

February 8, 2001


Kevin Fong Design
2 Blue Dunn Court
Sacramento, CA 95831

Attention: Kevin Fong

Re: P.C. 001509R, Limhengco Residence - 23" stem walls

This letter is to satisfy the request from the building department official that asked for a letter from the engineer of record's approval for foundation stem walls 23" above undisturbed material.

Stem walls are acceptable at this location up to 24" above undisturbed material, such that the total height from the bottom of the footing below undisturbed material to the top of the concrete stem does not exceed 48".



Sincerely,

Richard Dills, S.E.

