

BUILDING DIVISION—BUILDING INSPECTOR'S REPORT CARD

TYPE BUILDINGS

| | |
|-----------------------------|--|
| PERMIT NO. <i>A-6714</i> | LOCATION <i>1008 - 17th Street</i> |
| DATE <i>4/28/37</i> | PURPOSE <i>Hang Elec. Sign</i> |
| ZONE <i>Gen. Com.</i> | OWNER <i>Mrs F. B. Seltzer</i> |
| | ARCH'T. <i>Elec. Sign Serv. Co.</i> |
| | CONTR. <i>Elec. Sign Serv. Co.</i> |

| | | | | |
|------------------|---------|-------|-------|------|
| VAL. <i>750=</i> | STORIES | ROOMS | APTS. | SIZE |
|------------------|---------|-------|-------|------|

| | | | |
|-------------------|--|------------------|--|
| LIGHT SHAFTS | | ELEVATOR SHAFTS | |
| VENT SHAFTS | | BOILER ROOMS | |
| OWNER'S INSPECTOR | | SPRINKLER SYSTEM | |
| LATH | | GAS VENTS | |
| FIRE ESCAPES | | CHIMNEYS | |
| STAND PIPES | | SKYLIGHTS | |

| DATE | CONDITION OF WORK-REMARKS |
|---------|--|
| 5/15/37 | <p>Made inspection of small electric line - metal electric sign base 10 ft above sidewalk and more than 3 ft inside face line of curb. O.K. R.W. Campbell</p> |
| 5/15/37 | <p>COMPLETE AND O. K. <i>R.W. Campbell</i> INSPECTOR</p> |