

**CITY OF SACRAMENTO**  
1231 I Street, Sacramento, CA 95814

**Permit No: 0101653**

**Insp Area: 3**

**Site Address: 8300 DEMETRE AV SAC**  
Parcel No: 062-0010-017 BUILDING 352

Sub-Type: REM  
Housing (Y/N): N

CONTRACTOR  
STRAIGHT LINE EXCAVATION  
11357 B PYRITES WAY #1  
GOLD RIVER CA 95676

OWNER  
CITY OF SACRAMENTO  
915 I ST RM 304  
SACRAMENTO CA 95814

ARCHITECT

**Nature of Work: DEMO TWO CONCRETE PILLARS (NON-STRUCTURE) LOCATE IN PREVIOUS BOILER ROOM BUILDING 352**

**CONSTRUCTION LENDING AGENCY:** I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name \_\_\_\_\_ Lender's Address \_\_\_\_\_

**LICENSED CONTRACTORS DECLARATION:** I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class \_\_\_\_\_ License Number \_\_\_\_\_ Date \_\_\_\_\_ Contractor Signature \_\_\_\_\_

**OWNER-BUILDER DECLARATION:** I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code: any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 3 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00).

I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

I am exempt under Sec. \_\_\_\_\_ B & PC for this reason: \_\_\_\_\_

Date 2/7/01 Owner Signature Beck Fub

**IN ISSUING THIS BUILDING PERMIT,** the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and hereby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

Date 2/7/01 Applicant/Agent Signature Beck Fub

**WORKER'S COMPENSATION DECLARATION:** I hereby affirm under penalty of perjury one of the following declarations:  
 I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier \_\_\_\_\_ Policy Number \_\_\_\_\_ Exp Date \_\_\_\_\_

(This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner, so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Date 2/7/01 Applicant Signature Beck Fub

**WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.**

**THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.**

Sacramento Metropolitan Air Quality Management District

ASBESTOS SURVEY AND DEMOLITION NOTIFICATION FORM

NOTE: Please read instructions on the back of this form.

1	Contractor <u>Straight-Line Excavation</u>	Owner <u>U.S. National Leasing, LLC</u>
	Address _____	Address <u>16 Business Park Way</u>
	City _____	City <u>Sacramento</u>
	State/Zip _____	State/Zip <u>CA 95823</u>
	Telephone _____	Telephone <u>(916) 381-8200</u>
2	Structure Name <u>Bldg 352</u>	Use <u>Remise 2 fire standing, re-structure (p 11)</u>
	Address <u>8300 Demetree Ave</u>	City/Zip <u>Sacramento CA 95828</u>
3	Structure Age <u>35</u> (years)	Number of floors: <u>1</u> Size: <u>4203</u> sq. ft.
4	Has RACM reported by the consultant been removed? (circle) YES NO N/A Asbestos contractor who removed or will remove RACM _____	
5	DEMOLITION Start Date <u>   /   /   </u> Completion Date <u>   /   /   </u>	
6	Preference for return of form: <input type="checkbox"/> Mail <input type="checkbox"/> Pick-Up (after 2 working days)	
7	Applicant Name (Print) <u>U.S. National Leasing</u>	<input checked="" type="checkbox"/> Owner <input type="checkbox"/> Contractor
	Applicant's Signature <u>William E. Fabian</u>	Date <u>   /   /   </u>
I have read and understand the directions. The information on this form is true and accurate.		
8	[REDACTED SECTION]	
9	REVISION #: 1 2 3 4 5 6 7 8 9 (circle)	DEMOLITION PERMIT SHALL NOT BE ISSUED PRIOR TO <i>Approval of this not needed by SMAQMD.</i> <i>Randy Star 2/7/01</i>
	Old: Start Date <u>   /   /   </u> Completion Date <u>   /   /   </u>	
	New: Start Date <u>   /   /   </u> Completion Date <u>   /   /   </u>	

**RM RichMarc Environmental Consultants, Inc.**

1722 J Street, Suite 17A Sacramento, CA 95814  
(916) 443.0770 fax (916) 443.0990

December 16, 2000

Mr. Allen Wellborn  
Allied Environmental  
P.O. Box 2240  
Shingle Springs, Ca. 95682

**Subject: Clearance Air Sampling @ Depot Business Park, Sacramento, Ca.  
Asbestos Containing Boiler Material-Bldg. 352**

Dear Mr. Wellborn,

RichMarc Environmental Consultants, Inc. provided the services of a Certified Site Surveillance Technician (CSST) under the direction of a Certified Asbestos Consultant (CAC) at the above location on Friday, December 15, 2000. The asbestos abatement was performed inside building 352 and included the removal of asbestos containing thermal system insulation. The services for this project included the collection of clearance air samples, on-site analysis for fiber content, travel and written report.

A total of two clearance air samples were collected from inside the containment area where approximately 15 square feet of asbestos containing thermal system insulation was abated. All abatement was conducted by certified personnel under negative pressure containment. The air samples were collected using high-volume electric air pumps with 25mm. cassettes containing filters with .8 micron pores. The samples were analyzed by a NIOSH 582 equivalent analyst using the principles of Phase Contrast Microscopy (PCM). The descriptions and results of the sample analysis are included in this report for your review.

The results of the sample analysis were below the EPA recommended clearance level of 0.01 fibers per cubic centimeter (f/cc) of air. The area was cleared for re-entry at approximately 20:00 on Friday, December 15, 2000. At the time of sample collection, the work area was inspected for loose debris and the area appeared very clean and well encapsulated.

If there are any questions or comments regarding this report, please contact our office immediately. Thank you very much for your consideration.

Sincerely,



Marc A. Sallin, CAC 97-2307  
RMEC, President

CITY OF SACRAMENTO  
PERMIT ASSISTANCE

FEB 07 2001

**RECEIVED**