

R164 7220-223

W. $\frac{1}{2}$ of Lot BUILDING DIVISION — BUILDING INSPECTOR'S REPORT CARD \$46.00				
24 West Del Paso Ht. TYPE BUILDINGS				
PERMIT NO. F-23		LOCATION 3705 ^a - Taylor Street A-6		
DATE Mar 24-65		PURPOSE Const. duplex dwelling		
ZONE R-1		OWNER May L. McDaniel 581-Morey Avenue		
		ARCH'T /452-4803		
		CONT'R Showcase Homes 2272-Stockton Blvd.-		
VAL. \$12,500.		STORIES 1	ROOMS 8	APTS. 1400 sq. ft.
INSP.	DATE	BLDG. TYPE	OCCUPANCY GROUP	PHONE (O) (C)
FORM	4-2-65	Harmon		
JOIST				
FRAME	4-23-65	Dana Fuller		
SHEET ROCK	4-29-65	Chapman		
FINAL	5-20-65	Chapman		

DATE	SPECIAL CONDITIONS OF WORK — REMARKS
4-1-65	P.T. NO PLOT PLAN - Plans not OK by Planning ^{Chapin}
4-22-65	P.T. Ceiling joists not nailed to rafters - Hammond
4-28-65 P.T.	P.T. KE-NAIL S-R. IN L.R. KITCHEN - STUCCO WIRE LOOSE - Chapin.
4-30-65	P.T. Bldg locked unable to enter - Hammond
5-17-65	P.T. Trade. Lot. Water must drain
	Always from dump block top required
	to parking area ^{Hammond}
5-19-65	P.T. Final. Not ready ^{Chapin}
	COMPLETE AND OK INSPECTOR