

1949-1547-50

BUILDING DIVISION — BUILDING INSPECTOR'S REPORT CARD \$31.00

TYPE BUILDINGS

PERMIT NO. E-7915	LOCATION 3737 - Rio Linda Blvd.	A-7 A-6
DATE Jul 22-64	PURPOSE Repair fire damage to store bldg.	
ZONE C-2	OWNER George Harlan	5004-14th Avenue
	ARCH'T Owner	451-7132
	CONTR Owner	1005 - 8th Street

VAL \$8,000.	STORIES	ROOMS	APTS.	SIZE 2,500 sq. ft.
--------------	---------	-------	-------	-----------------------

INSP.	DATE	BLDG. TYPE	OCCUPANCY GROUP	PHONE (O) (C)
-------	------	------------	-----------------	---------------

FORM

JOIST

FRAME 8-31-65 *Hansen*

SHEET ROCK 9-17-65 *Hansen*

FINAL 3-4-66 *E. Hansen* *Int. Co. Rep.*

DATE	SPECIAL CONDITIONS OF WORK—REMARKS
12-25-64	Put in S.F. 30 days - if <del>not</del> 300
	Victorian Council Permit Submits 1-1-65 <i>Carroll</i>
1-28-65	MOBILE STARTED CHASIN
2-3-65	BLDG LOCKED
2-4-65	P.T. ROOF NOT PROPERLY FRAMED - CHASIN
2-15-65	P.T. BUILDING LOCKED - CHASIN
2-17-65	P.T. MUST ADD PURLINS & BRIDGES TO ROOF - CHASIN
6-9-65	Carpenter: Will call for frame 6-17-65 <i>Chapin</i>
6-17-65	Pt Bldg. Locked 8-7-65 <i>Chapin</i>
6-24-65	Pt Bldg. - Joints for ducts missing. Locking in both missing. Min. in. dia. to Jefferson. U.S. map in hall
6-29-65	Pt Bldg. - Not started <i>Chapin</i>
7-16-65	Pt Bldg. - Not ready <i>Hammers</i>
9-13-65	P.T. S/R Bldg. Locked - unable to enter <i>Hammers</i>
	COMPLETE AND OK
	INSPECTOR

BUILDING DIVISION — BUILDING INSPECTOR'S REPORT CARD \$31.00

**TYPE BUILDINGS**

PERMIT NO. E-7915	LOCATION 3737 - Rio Linda Blvd.	A-7
DATE July 22-64	PURPOSE Repair fire damage to store bldg.	
	OWNER George Harlan 5004-14th Ave.	
ZONE C-2	ARCH'T OWNER	
	CONTR same	451-7132
VAL \$8,000.	STORIES	ROOMS
		APTS.
		SIZE 2,500 sq. ft.
INSP.	DATE	BLDG. TYPE
		OCCUPANCY GROUP
		PHONE (O) (C)
FORM		
JOIST		
FRAME		
SHEET ROCK		
FINAL		

DATE	SPECIAL CONDITIONS OF WORK — REMARKS
7-15-65	<p>Q. 1. s/n - <math>\frac{1}{2}</math> s/n in Hall. Not cut light  enough to walls. Correct piece of ceiling rock  in front bedroom ceiling. E. Larsen</p>
2-10-66	<p>Pt. April. Locked. Correct</p>
2-11-66	<p>Pt. April. Panels in bathroom to be on  separate switches. Name numbers for</p>
	<p>COMPLETE AND OK</p> <p style="text-align: right;">INSPECTOR</p>