

BUILDING DIVISION—BUILDING INSPECTOR'S REPORT CARD

TYPE BUILDINGS

| | | | |
|------------------------------|--|---|------------------------|
| PERMIT NO. <i>A-4363</i> | | LOCATION <i>1111 - 11th St.</i> | |
| DATE <i>5/29/36</i> | | PURPOSE <i>Have Elec. Sign</i> | |
| ZONE <i>Gen Com</i> | | OWNER <i>Madgeard</i> | |
| | | ARCH'T. <i>Golden West Bldg Co</i> | |
| VAL. <i>150⁰⁰</i> | | STORIES | ROOMS |
| | | | APTS. <i>2-6x6-611</i> |
| LIGHT SHAFTS | | ELEVATOR SHAFTS | |
| VENT SHAFTS | | BOILER ROOMS | |
| OWNER'S INSPECTOR | | SPRINKLER SYSTEM | |
| LATH | | GAS VENTS | |
| FIRE ESCAPES | | CHIMNEYS | |
| STAND PIPES | | SKYLIGHTS | |

| DATE | CONDITION OF WORK-REMARKS |
|--------|---|
| 6/1/36 | <p>Made Trip of New Horizontal Electric Sign hung 10 ft above sidewalk and above them 3 ft inside face line of curb. Sign is properly supported and braced with top and on each side with guy wires to front of sign. OK A.W. Campbell</p> |
| 6/1/36 | <p>COMPLETE AND O. K. <i>Alice W. Campbell</i> INSPECTOR</p> |