



CITY OF SACRAMENTO

CITY MANAGER'S OFFICE  
**RECEIVED**  
MAR 16 1982

DEPARTMENT OF ENGINEERING  
915 I STREET SACRAMENTO, CALIFORNIA 95814  
CITY HALL ROOM 207 TELEPHONE (916) 449-5281

R. H. PARKER  
CITY ENGINEER  
J. F. VAROZZA  
ASSISTANT CITY ENGINEER

March 17, 1982

City Council  
Sacramento, California

Honorable Members in Session:

SUBJECT: Approval of Plans and Specifications for Force Main Replacement  
Sump No. 80

SUMMARY:

Attached is a report to the Budget and Finance Committee recommending that staff be directed to forward plans and specifications for Force Main Replacement Sump No. 80 to the City Council for approval. The Budget and Finance Committee approved staff's recommendation at their February 16, 1982 meeting.

RECOMMENDATION:

It is recommended that the plans and specifications be approved and that bids be received on April 13, 1982.

Respectfully submitted,

R. H. PARKER  
City Engineer

Recommendation Approved:

Walter J. Slize, City Manager

F/Ref.  
C.C. 9530

14-B-010-30-0

**APPROVED**  
BY THE CITY COUNCIL

MAR 23 1982

OFFICE OF THE  
CITY CLERK

March 23, 1982  
District No. 1



# CITY OF SACRAMENTO

DEPARTMENT OF ENGINEERING  
915 I STREET SACRAMENTO, CALIFORNIA 95814  
CITY HALL ROOM 207 TELEPHONE (916) 449-5281

R. H. PARKER  
CITY ENGINEER  
J. F. VAROZZA  
ASSISTANT CITY ENGINEER

February 5, 1982

Budget and Finance Committee  
Sacramento, California

Honorable Members in Session:

SUBJECT: Replacement of Sump #80 Force Main

SUMMARY:

The existing steel force main at Sump #80 is leaking and should be replaced this spring. There are sufficient funds in the Miscellaneous Sewer Fund account to cover this construction. Transfer of funds to cover this project is recommended.

BACKGROUND:

Early this fall the Maintenance Department discovered that the existing steel force main between Sump #80 and the gravity sewer outfall had deteriorated to the point that it was leaking. Repair proved impractical since the leak had saturated the surrounding ground to the point that excavation was impossible. The Maintenance Department has therefore requested the existing steel pipe be replaced with a new cast iron pipe.


FINANCIAL:

The estimated project cost is \$17,720. There are sufficient funds available in the Miscellaneous Sewer Fund to cover the work. The present balance in this account is \$183,500.


RECOMMENDATION:

It is recommended that this project be approved for transfer of funds from the Miscellaneous Sewer Fund to the City Engineer's budget after receipt of bids and that this recommendation be forwarded to the full City Council for adoption.

Respectfully submitted

  
R. H. PARKER  
City Engineer

FOR TRANSMITTAL:



FINANCE ADMINISTRATION & BUDGET