

Q175 7258-261

Lot 57		BUILDING DIVISION — BUILDING INSPECTOR'S REPORT CARD \$52.00			
Rio Park Sub.		TYPE BUILDINGS			
PERMIT NO.	LOCATION				
F-1438	7490 - Myrtle Vista				A-5
DATE	PURPOSE	OWNER			
Aug 11-65	Const. dwlg. & attached garage	Jack Baker 4109-43rd Avenue			
ZONE	ARCH'T	CONTR			
R-1		/452-4803 Hertel Const. 2272-Stockton Blvd -			
VAL. \$14,400.	STORIES	ROOMS	APTS.	567-gar.	SIZE
				1441 sq. ft.	
INSP.	DATE	BLDG. TYPE	OCCUPANCY GROUP	PHONE (O) (C)	
FORM	8-17-65	Fuller			
JOIST	8-24-65	Fuller			
FRAME	9-16-65	Callaway			
SHEET ROCK	9-23-65	Fuller			
FINAL	10/10/66	Dana E. Fuller			

DATE	SPECIAL CONDITIONS OF WORK—REMARKS
9-22-65	P.R. - Bedroom R not nailed at ceiling
	corner. Small nailing missing. Check
	R not correct at bottom. Renda
10-15-65	P. J. Final - Block drive-way, dampers stuck in fireplace, install shower door, sheet rock water heater room. - Barbato
10-20-65	P. J. Final - Corrections not made. Rich
	<p>COMPLETE AND OK</p> <p style="text-align: right;">INSPECTOR</p>