

BUILDING DIVISION-BUILDING INSPECTOR'S REPORT CARD

TYPE BUILDINGS

PERMIT NO. <i>B-18900</i>	LOCATION <i>3911 - Stockton Blvd</i>
DATE <i>5-10-50</i>	PURPOSE <i>Erect storage room</i>
ZONE	OWNER <i>N. Manning</i>
	ARCH'T.
	CONTR. <i>Clune</i>

VAL.	STORIES	ROOMS	APTS.	SIZE
<i>#200</i>				
LIGHT SHAFTS			ELEVATOR SHAFTS	
VENT SHAFTS			BOILER ROOMS	
OWNER'S INSPECTOR			SPRINKLER SYSTEM	
LATH			GAS VENTS	
FIRE ESCAPES			CHIMNEYS	
STAND PIPES			SKYLIGHTS	

DATE	CONDITION OF WORK-REMARKS
5/12/50	Forms M.A. Shumway
5/25/50	Weak rafters (double up) M.A.S
5/29/50	Frame M.A. Shumway
6-13-50	Final M.A.
	<p data-bbox="302 862 419 899">COMPLETE AND O. K.</p> <p data-bbox="1096 876 1220 894">INSPECTOR</p>