

CITY OF SACRAMENTO

1231 I Street, Sacramento, CA 95814

Permit No: 0403842

Insp Area: 1

Thos Bros: 297G6

Site Address: 1533 34TH ST SAC

Parcel No: 007-0295-007

ALHAMBRA CORRIDOR

Sub-Type: REM

Housing (Y/N): N

CONTRACTOR

OWNER

ARCHITECT

STORM JAMES
1533 34TH ST
SACRAMENTO CA 95816

Nature of Work: ENCLOSE EXIST. SCREENED PORCH TO CREATE BATHROOM AND LAUNDRY ROOM

CONSTRUCTION LENDING AGENCY : I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name _____ Lender's Address _____

LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class _____ License Number _____ Date _____ Contractor Signature _____

OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00);

JPS I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

PAID
CITY OF SACRAMENTO

I am exempt under Sec. _____ B & PC for this reason: _____
Date 3-16-04 Owner Signature James P. Storm MAR 16 2004

IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

NEIGHBORHOODS AND DEVELOPMENT SERVICES

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and hereby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

Date 3-16-04 Applicant/Agent Signature James P. Storm

WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations:

I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier _____ Policy Number _____ Exp Date _____

JPS (This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Date 3-16-04 Applicant Signature James P. Storm

WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.

THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.



CITY OF SACRAMENTO
PLANNING & BUILDING DEPARTMENT
BUILDING DIVISION

www.cityofsacramento.org

Help Line: 1-916-264-5656 OR 1-866-EZ-PERMIT
 Inspection: 1-916-808-4677



Downtown Permit Center 1-916-264-6807
 1231 I Street, Suite 200, Sacramento, CA 95814

North Permit Center 1-916-808-2354
 2101 Arena Blvd., Suite 200, Sacramento, CA 95834

PRELIMINARY RESIDENTIAL APPLICATION
 1-916-264-5656 OR 1-866-EZ-PERMIT

1533 34 th St.		
BUILDING SITE ADDRESS	SUITE	INSP. AREA
007-0295-007		0403842
ASSESSOR'S PARCEL NO.	COMMUNITY PLAN NO.	PLAN CHECK NO.

NAME OF APPLICANT	ADDRESS	ZIP CODE	PHONE NO.
LICENSED CONTRACTOR			
James P. Storm	1533 34 th St.	95816	284-9047
CONTRACTOR'S LICENSE NO.: (Painting Contractor: Cal. C33 648902)			
PROPERTY OWNER			
James P. Storm (owner builder)			
ARCHITECT/ENGINEER			

No. of Stories	No. of Rooms	Roof Covering	Area 1 st Floor	Total Area	Garage Area	Patio Area
1	2	New Comp.	1,250		200 sq. ft.	300 sq. ft.

THIS PERMIT IS FOR:

- BUILDING
 MECHANICAL
 PLUMBING
 ELECTRICAL
 SITE
 FIRE

NATURE OF WORK IN DETAIL

\$ _____
 VALUATION

60.34
 - 14.10

 46.24

OWNER-BUILDER VERIFICATION

ATTENTION PROPERTY OWNERS

An owner-builder building permit has been applied for in your name and bearing your signature.

Please complete and return this information in the envelope provided at your earliest opportunity to avoid unnecessary delay in processing and issuing your building permit. No building permit will be issued until this verification is received.

- 1. I personally plan to provide the major labor and materials for construction of the proposed Improvement (yes or no) _____
- 2. I (have/have not) _____ signed an application for A building permit for the proposed work.

3. I have contracted with the following person (firm) to provide the proposed construction:
Name _____ Address _____
City _____ Telephone _____
Contractors License No. _____

4. I plan to provide portions of the work, but I have hired the following person to coordinate, Supervise, and provide the major work.
Name _____ Address _____
City _____ Telephone _____
Contractors License No. _____

5. I will provide some of the work but I have contracted (hired) the following to provide the Work indicated:

Name	Address	Phone	Type of work
<u>I will hire licensed plumber and electrician;</u>			
<u>I have not yet chosen them. I will do framing and wall finishing, stucco and painting myself. (I am licensed painting Contr.)</u>			
<u>C33 State # 648902</u>			

Signed James P. Stone
Job Address 1533 34th St
Permit No: 0403842

City of Sacramento Planning Division
PLANNING REVIEW FOR BUILDING PERMIT SUBMITTAL

ADDRESS: 1533 34 th Street	APN: 007-0295-007
DRPB AREA / PUD / SPD: Alhambra Corridor	ZONING: R-1
EXISTING LAND USE: Single Family Home	
PROPOSED USE: Interior addition, enclosing rear utility porch.	
PLANNING STAFF WILL CHECK ONE OR MORE OF THE ITEMS BELOW:	
<input type="checkbox"/>	Planning review is NOT required.
<input type="checkbox"/>	Use is NOT allowed; applicant CANNOT submit for plan check.
<input type="checkbox"/>	Requires APPLICATION(s): PC ZA IR ER DR PB Required Planning application must be submitted <i>before</i> project can be submitted for plan check.
<input type="checkbox"/>	Application(s) IN PROGRESS: Applicant may submit for concurrent building permit plan check, at applicant's risk. Building Division must check with Planning staff and/or SITE before issuing building permit.
<input type="checkbox"/>	Application(s) COMPLETED: Building permit must conform to approved plans and comply with all conditions of approval. Do NOT issue building permit prior to end of 10 day appeal period.
<input checked="" type="checkbox"/>	Plans may be submitted for plan check. Plan checker(s) shall confirm compliance with Zoning Ordinance requirements and all applicable development standards <i>prior to issuance</i> of building permit.
<input checked="" type="checkbox"/>	Meets setback & lot coverage requirements as shown on site plan provided.
<input type="checkbox"/>	Plans to be submitted have been stamped/signed by Planning counter staff.
<input type="checkbox"/>	Route to SITE for plan check and inspection.
<input type="checkbox"/>	Preliminary review ONLY; the information on this form must be reviewed again and confirmed at the time of building permit submittal.
COMMENTS: Interior addition of bathroom does not impact existing setbacks or lot coverage. There are three new windows and a new stucco partition that will be reviewed by Design Review. No other planning issues.	
DATE: 03/16/04	BY: Ashley Feeney

↑ North

1533 34th St.
for Jim Storm
(916) 284-9047

1/4" = 6 inches

Existing Plumbing/Electrical

Driveway

ISSUED
MAR 15 2004
Sacramento Building Division

ISSUED
MAR 15 2004
Sacramento Building Division

Garage Interior

Cement Block

electricity
to garage.
From floor
to 5ft. up.
(conduit)

Exterior
Patio
← Stucco

Brick
steps →

Entrance →

Kitchen

Screened
Porch

-light switch
-electrical
plug

Screen Screen Screen Screen

Working hot + cold water
hose bibs.
-220 plug
electrical conduit for
light.
on outside of wall for

Drain
Capped off hot + cold water

EXTERIOR Stucco Wall

Closest


closet
Door

Bedroom

Stairs
Basement

This set of plans and specifications must be kept on the job at all times and it is unlawful to make any changes or alterations from the set without written permission from the architect or the Building Division.

The approval of this plan and specification shall not be taken to constitute approval of the work or any City Ordinance.



ISSUED

MAR 15 2004

Sacramento Building Division

Proposed additions to create
bathroom from half of screened
porch.
(ONLY BATHROOM TO BE CONDITIONED)
(47A)

Driveway

Garage Interior

Cement Block

Exterior
Patio
← STUCCO

New
Passage-
way

30" CLEAR
DIAM. CIRCLE
AT FLR OF
SHWR MIN

Claret

Claret
Door

Bedroom

North

1533 34th St.
for Jim Storm
(916) 284-9047

4" = 6 inches
30" x 30" window frame

windows:

32" wide (29")
41" High (39")

Porch:

80
Square feet

Brick
Steps

Entrance

Kitchen

15" CUR TO
CENTER LINE
24"

Toilet

15" CUR TO
CENTER LINE
24"

Sink

GFI
OUTLET

TEMP. GLASS
ENCLOSURE
w/ 22" WIDE
MIN. OUTWARD
SWINGING
DR.

Shower
(36" sq.)

FLOR. LIGHT
FIXTURE
REQUIRED

6'9"

CURB

220 outlet -
dryer vent

electrical
plugs

2x6 PLUMBING
WALL

Hot water


Cold water

Drain

UTILITY
SERVICE
PORCH

EXTERIOR STUCCO WALL

This set of plans and specifications must be kept on the job at all times and it is unlawful to make any changes or alterations from the same without written permission from the Building Inspection Division.
Approval of this plan and specification SHALL NOT be held to permit or approve the violation of any City or State Law.



Base ment



CITY OF SACRAMENTO, CALIFORNIA
BUILDING & SAFETY DIVISION 1231 I STREET, (916) 264-1965
SPECIAL PACKAGE D FOR RESIDENTIAL ADDITIONS IN CLIMATE ZONE 12

CERTIFICATE OF COMPLIANCE CF-1R ADDITION, 100 TO 999 SQUARE FEET WITH [99-SF EXEMPTIONS & REQUIREMENTS.]

Project Title SCREENED PORCH CONVERSION Date _____

Project Address 1533 34th St

Total Floor Area Addition: 470 Ft² Total Glazing Area Addition: _____ Ft² Floor Area x 16%= Total allowed. (_____ x 16%= _____)

REQUIREMENTS THAT APPLY TO NEW AREA FLOOR PLAN MAXIMUM GLASS ALLOWANCE FORMULA.

A. 9 Sq. Ft. B. 0 Sq. Ft. C. 9 Sq. Ft. D. 5.2 %

NOTE: Using package D, maximum glass allowed is 16%

Total Glass in addition: _____ Total of any removed glass (addition area): _____ Subtract B from A; enter amount in C: _____ Divide C by floor area of addition: _____

Module I (R-19 Ceiling.....R-13 Wall.....R-13 Floor)

99-SF or Less	50%MaxGlazing,No Credit for removed.	0.75 -U-Value	SHGC 0.40 Minimum.	No CF-4R, No HERS Testing No Radiant Barrier required.	See, *, **, exceptions.
---------------	--------------------------------------	---------------	--------------------	--	-------------------------

Module II Standard Package-D (R-38 Ceiling.....R-13 Wall.....R-19 Floor)

100-999 SF	16% Max Glazing See A,B,C,D above	0.65- U- Value 0.75 < 500 SF	SHGC 0.40 Minimum	Radiant Barrier In Addn Only.	Duct, TXV, & HERS Test, CF-R4, AFUE.78 **New 12 SEER, Duct test req. See***
------------	-----------------------------------	------------------------------	-------------------	-------------------------------	---

Module III Alternate Package-D (R-38 Ceiling.....R19-2x6"Wall.. or R-13 with R4.61 Rigid in a 2x4" Wall.....R-19 Floor)

100-999 SF	16% Max Glazing See A,B,C,D above	0.40-U-Value	SHGC 0.35 Minimum	Min 11 SEER when upgraded or added. Radiant Barrier addition only. See* & **.	AFUE 0.78 min. No CF-R4 required. No Duct, TXV, & HERS Test. **New 12 SEER
------------	-----------------------------------	--------------	-------------------	---	--

Module IV Standard Pkg-D or Computer Performance Compliance

Floor Plans in excess of 999-SF require Performance Compliance of both existing and Addition combined, achieved by an approved Computer Program or, both Existing & Addition Designed and constructed per Module II Package-D.

Both Module II & III may use existing HVAC systems when adequate and without testing the system. Should a 12 SEER be installed in either Module then No HERS/TXV tests required. See Exceptions below.

[All duct R-value 4.2 Min.] [Pre-1978 AFUE .68=OK] [* -New HVAC requires HERS Test 11 SEER Min.] [** -New 12 SEER A/C = No HERS/TXV or CF-R4] [*** No duct work, No HERS required] RB= Radiant barrier underside of roof & Gable walls, shiny side down. Duct Sealed= Ducts certified 6% leakage max. U= U-Value. TXV= Field verified by HERS rater. SEER= A/C Seasonal Energy Efficiency Ratio. SHGC= Window Solar Heat Gain Coefficient. AFUE= Annual Fuel Utilization Efficiency. [See **** & ***** for wall frame and vaulted ceiling requirements.]

QUESTIONARE: (By City of Sacramento Staff) FIELD VERIFY:

1. What year was home built? _____

2. What is SEER rating of current Air Conditioner? _____

3. What is current Furnace AFUE ? _____

4. Will Furnace or A/C be upgraded ? Yes/No? _____

5. New water heater (> 50 gal. Exempt) ? Yes/No? _____

6. Note: No duct assembly allowed in wall cavity chases, New Furnace or HVAC requires new Setback thermostats each Zone or unit. Split zones require 2. 2001 Title 24 Residential Energy manual sec 3.1-3.8; sec 7.1-7.6 Effective July 1st, 2001.

****Requires 2x6 assembly, or 2x4 R11 & Ext rigid R4.61. Cannot apply brace panels. *****Requires 2x12 @ Vaulted areas with 1" x 6" foam channel ventilation.

NEW HEATING, COOLING, OR DOMESTIC WATER HEATING

Systems installed in conjunction with the addition must comply with the appliance standards applicable to new installations in new residences. Complete the following standards if new equipment is being installed in conjunction with the room addition: Electric resistant heat not allowed.

HVAC SYSTEMS	Minimum Efficiency (SE, SEER, HSPF)	Duct Insulation	Output Manufacturer/Model # (Btu) (or approved equal)
<u>EXIST</u>	_____	R4.2	_____
_____	_____	R4.2	_____
_____	_____	R4.2	_____

HOT WATER SYSTEMS	Capacity (gallons)	Manufacturer/Model# (or Approved equal)	Special Features
<u>EXIST</u>	_____	_____	_____
_____	_____	_____	_____

COMPLIANCE STATEMENT

This certificate of compliance lists the building features and performance specifications needed to comply with Title 24, Chapter 2-53, and Title 20, Chapter 2, subchapter 4, Article 1, of the California Administrative Code. The individual has signed this certificate with overall design responsibility and the building owner, who shall retain a copy of it and transmit the certificate to any subsequent purchaser of the building. When this certificate of compliance is submitted for a single building plan to be built in multiple orientations, all building conservation features that vary are indicated in the Special Feature/Remarks section.

BUILDING OWNER OR DESIGNER Name: <u>James P. Storm</u> Title/Firm: <u>owner</u> Address: <u>1533 34th St.</u>	DOCUMENTATION AUTHOR Name: _____ Title/Firm: _____ Address: _____	ENFORCEMENT AGENCY Name: _____ City of Sacramento 1231 I Street Sacramento, Ca. 95814
---	---	--

James P. Storm 3/16/04
 Signature (date) Signature (date) Signature Approval (date)

NOTE: Low-rise residential buildings subject to the Standards must contain these measures regardless of the compliance approach used. Items marked with an asterisk (*) may be superseded by more stringent compliance requirements listed on the Certificate of Compliance. When this checklist is incorporated into the permit documents, the features noted shall be considered by all parties as binding minimum component performance specifications for the mandatory measures whether they are shown elsewhere in the documents or on this checklist only.

Instructions: Check or initial applicable boxes when completed or enter N/A if not applicable.

DESCRIPTION	DESIGNER	ENFORCEMENT
Building Envelope Measures.		
§150(a): *Minimum R-19 ceiling insulation.		
§150(b): Loose fill insulation manufacturer's labeled R-Value.		
§150(c): *Minimum R-13 wall insulation in wood framed walls or equivalent U-value in metal frame walls (does not apply to exterior mass walls).		
§150(d): *Minimum R-13 raised floor insulation in framed floors.		
§150(i): Slab edge insulation – water absorption rate no greater than 0.3%; water vapor transmission rate no greater than 2.0 perm/inch.		
§118: Insulation specified or installed meets insulation quality standards. Indicate type and form.		
§116-§117: Fenestration Products, Exterior Doors, and Infiltration/Exfiltration Controls 1. Doors and windows between conditioned and unconditioned spaces designed to limit air leakage. 2. Fenestration products (except field-fabricated), have label with certified U-value, certified Solar Heat Gain Coefficient (SHGC), and infiltration certification. 3. Exterior doors and windows weather-stripped; all joints and penetrations caulked and sealed.		
§150(g): Vapor barriers mandatory in Climate Zones 14 and 16 only.		
§150(f): Special infiltration barrier installed to comply with §151 meets Commission quality standards.		
§150(e): Installation of Fireplaces, Decorative Gas Appliances, and Gas Logs. 1. Masonry and factory-built fireplaces have: a. Closeable metal or glass door. b. Outside air intake with damper and control. c. Flue damper and control. 2. No continuous burning gas pilot lights allowed.		
Space Conditioning, Water Heating, and Plumbing System Measures.		
§110-§113: HVAC equipment, water heaters, showerheads, and faucets certified by the Commission.		
§150(h): Heating and/or cooling loads calculated in accordance with ASHRAE, SMACNA, or ACCA.		
§150(i): Setback thermostat on all applicable heating and/or cooling systems.		
§150(j): Pipe and Tank Insulation. 1. Storage gas water heaters rated with an Energy Factor less than 0.58 must be externally wrapped with insulation having an installed thermal resistance of R-12 or greater. 2. First 5 feet of pipes closest to water heater tank, non-recirculating systems, insulated (R-4 or greater). 3. Backup tanks for solar system, unfired storage tanks, or other indirect hot water tanks have R-12 external insulation or R-16 combined internal/external insulation. 4. All buried or exposed piping insulated in recirculating sections of hot water systems. 5. Cooling system piping below 55°F insulated. 6. Piping insulated between heating source and indirect hot water tank.		
§150(m): Ducts and Fans. 1. All ducts and plenums constructed, installed, insulated, fastened, and sealed to comply with the ICBO 1997 UMC Sections 601 and 603; ducts insulated to a minimum installed R-4.2 or ducts enclosed entirely within conditioned space. Openings shall be sealed with mastic, tape, aerosol sealant, or other duct closure system that meets the applicable requirements of UL181, UL181A, or UL181B and other applicable specified tests for longevity given in §150(m). 2. Exhaust fan systems have backdraft or automatic dampers. 3. Gravity ventilating systems serving conditioned space have either automatic or readily accessible, manually operated dampers.		
§114: Pool and Spa Heating Systems and Equipment. 1. System is certified with 68% thermal efficiency, on-off switch, weatherproof operating instructions, no electric resistance heating, and no pilot light. 2. System is installed with: a. At least 36" of pipe between filter and heater for future solar heating. b. Cover for outdoor pools or outdoor spas. 3. Pool system has directional inlets and a circulation pump time switch.		
§115: Gas-fired central furnace, pool heaters, spa heaters, or household cooking appliances have no continuously burning pilot light. (Exception: Non-electrical cooking appliances with Pilot <150 BTU/hr.)		
Lighting Measures.		
§150(k)1: Luminaries for general lighting in kitchens shall have lamps with an efficacy of 40 lumens/watt or greater for general lighting in kitchens. This general lighting shall be controlled by a switch on a readily accessible lighting control panel at an entrance to the kitchen.		
§150(k)2: Rooms with a shower or bathtub must either have at least one luminaire with lamps with an efficacy of 40 lumens/watt or greater switched at the entrance to the room or one of the alternatives to this requirement allowed in §150(k)2; and recessed ceiling fixtures are IC (insulation cover) approved.		

NOTE: *Minimum Measures above only apply to the Insulation R-Values of a Performance Computerized Design per State of California Title-24 minimums even though a Performance Design may show in some instances a lesser application and, do not apply to Prescriptive Packages D or Alternative Package D, Package D must comply strictly within its Module requirements. All others above apply to all packages.

PERMIT NO.

403842

WHEN CORRECTIONS HAVE BEEN MADE, CALL 264-7622 FOR REINSPECTION OF WORK.

JOB LOCATION 1533 34th ST

INSPECTION REQUESTED FRAME

THE UNDERSIGNED BUILDING PLUMBING MECHANICAL ELECTRICAL
INSPECTOR THIS DAY INSPECTED THIS STRUCTURE FOR THE REQUESTED INSPECTION AND FOUND THE FOLLOWING VIOLATIONS OF CITY AND/OR STATE LAWS GOVERNING SAME:

- ① SET TOILET FLANGE AND SECURE TO FLOOR
- ② PROVIDE 3" CLEAN OUT FOR DRAIN LINE
- ③ 5 FEET OF MAIN BUILDING DRAIN
- ④ NO WINDOWS INSTALLED
- ⑤ VERIFY THAT WATER IS BONDED
- ⑥ ^{O.K. A.C.} INSTALL DAM FOR SHOWER HOT WRP
- ⑦ COMPLETE EXHAUST DUCT
- ⑧ O.K. TO INSULATE A.C.

INSPECTOR CHAVEZ 808-8217 DATE 2/16/05

BUILDING INSPECTIONS 808-5716

INSPECTOR'S COPY

PERMIT NO.
0403842

CITY OF SACRAMENTO
2101 ARENA BLVD, #200
BUILDING INSPECTIONS DIVISION

AREA NO.
1

WHEN CORRECTIONS HAVE BEEN MADE, CALL 808-7622 FOR REINSPECTION OF WORK.

JOB LOCATION 1533 34th St

INSPECTION REQUESTED

THE UNDERSIGNED BUILDING PLUMBING MECHANICAL ELECTRICAL
INSPECTOR THIS DAY INSPECTED THIS STRUCTURE FOR THE REQUESTED INSPECTION AND FOUND THE
FOLLOWING VIOLATIONS OF CITY AND/OR STATE LAWS GOVERNING SAME:

No inspections have been signed off.

Expose for insp.

INSPECTOR R. Houtson 808 8019 DATE 10/26/05

BUILDING INSPECTIONS 808-5716

INSPECTOR'S COPY

0403842

1B-

WHEN CORRECTIONS HAVE BEEN MADE, CALL 264-7622 FOR REINSPECTION OF WORK.

JOB LOCATION 1553- 34th

INSPECTION REQUESTED FRAME

THE UNDERSIGNED BUILDING PLUMBING MECHANICAL ELECTRICAL
INSPECTOR THIS DAY INSPECTED THIS STRUCTURE FOR THE REQUESTED INSPECTION AND FOUND THE FOLLOWING VIOLATIONS OF CITY AND/OR STATE LAWS GOVERNING SAME:

- ① weather tight building prior to next inspection-
- ② DWV. to be on test
- ③ provide clamp for GWC.
- ④ complete shower pan at fa test
- ⑤ provide support at ABS. + copper under floor

INSPECTOR Tim M. DATE 11/15/04