

BUILDING DIVISION-BUILDING INSPECTOR'S REPORT CARD

TYPE BUILDINGS *B22-F465-470*

PERMIT NO.
B-40166

LOCATION **3222 Stockton Blvd**

DATE

PURPOSE **Erect storage room for store**

3-25-54

OWNER **Geo. Kwong Lee Sherk Toy**

ZONE

ARCH'T.

CONTR. **G.R. Dunphy 5330 - 10th Ave**

VAL. **8250**

STORIES

ROOMS

APTS.

SIZE

36x88

LIGHT SHAFTS		ELEVATOR SHAFTS	
VENT SHAFTS		BOILER ROOMS	
OWNER'S INSPECTOR		SPRINKLER SYSTEM	
LATH		GAS VENTS	
FIRE ESCAPES		CHIMNEYS	
STAND PIPES		SKYLIGHTS	

DATE	CONDITION OF WORK - REMARKS
4-21-54	center piers shallow he would dig them deeper M A Shrummy
4-22-54	change in front forms M A Shrummy
4-25-54	1st Bond M A Shrummy
5-3-54	Bond Top M A Shrummy
5-18-54	Final OK except for reeinforce on west end - not supported properly - They were to correct this M A Shrummy
	COMPLETE AND O. K. INSPECTOR

ISSUED
 JUN 20 1954
 SACRAMENTO
 PUBLIC WORKS