

CITY OF SACRAMENTO
1231 I Street, Sacramento, CA 95814

Permit No: 0100846
Insp Area: 3

Site Address: 5980 88TH ST SAC
Parcel No: 062-0060-078

Sub-Type: NOTHR
Housing (Y/N): N

CONTRACTOR
XCEL RACK CONTRACTOR
2401 GOLD RIVER RD
RANCHO CORDOVA 95670

OWNER
GRAFIL INC
5900 88TH ST
SACRAMENTO CA 95828

ARCHITECT

Nature of Work: INSTALLING RACKS IN WARE HOUSE.

CONSTRUCTION LENDING AGENCY: I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C.)

Lender's Name N/A Lender's Address _____

LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class C01/D21 License Number 693149 Date 03/07/01 Contractor Signature [Signature]

OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code: any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00).

I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code). The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.

I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code). The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law.

I am exempt under Sec. _____ B & PC for this reason: _____

Date _____ Owner Signature _____

IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and hereby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

Date 03/07/01 Applicant/Agent Signature [Signature]

WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations:

I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier STATE FUND Policy Number 432-2001 000446 Exp Date 01/01/2002

(This section need not be completed if the permit is for \$100,000 less). **WARNING:** that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Date 03/07/01 Applicant Signature [Signature]

WARNING - FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.

THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.

CITY OF SACRAMENTO
 BUILDING INSPECTION DIVISION
 APPLICATION FOR BUILDING PERMIT - HAZARDOUS MATERIAL SURVEY

0100846

As Required by Assembly Bill #3205 - A Building Permit Cannot be Approved Without This Completed Form

1 Business Name: Graf, Inc. Phone: _____

Site Address: 5900 88th Street Suite: _____
(Street) (Zip)

Business Owner/Representative: Bret Hogge Phone: 852 8960

Nature of Business: Storage of carbon wires

Property Owner: Graf, Inc. Phone: _____

Address: 5900 88th St. Suite: _____
Sacramento CA 95828
(City) (State) (Zip)

2 Are you developing an undetermined tenant space? Yes ___ No Is this permit for a shell building? Yes ___ No

Notify lessee of the responsibility to coordinate with the Fire Department regarding the use and handling of hazardous materials.

3 Does/Will your business generate hazardous waste? Yes ___ No

4 Does/Will your business handle, store or transport any solid, liquid, or gaseous chemicals? Yes ___ No

CONSULT THE EPA CHEMICAL LIST LOCATED AT THE BUILDING DIVISION COUNTER FOR HAZARDOUS OR ACUTELY HAZARDOUS MATERIALS TO COMPLETE THE FOLLOWING QUESTIONS.

If you answered "YES" to questions #3 and/or #4 above, continue on to questions 5 - 8.

5 Do you handle, store, or transport 55 gallons, 500 pounds, or 200 cubic feet (at Standard Temperature or Pressure) of a product or formulation containing hazardous materials at any one time? Yes ___ No ___

6 Do you handle, store or transport any amount of acutely hazardous materials? Yes ___ No ___

7 Is/Will your business be located within 1,000 feet of a school? Yes ___ No ___

If you answered "yes" to questions #6 and/or #7, complete the RMPP Informational sheet.

8 Is/Will your business be located within 1,000 feet of a hospital, and/or long-term healthcare facility? Yes ___ No ___

IF YOU ANSWERED "YES" TO QUESTION #3 AND/OR #4, PLEASE CONTACT THE CITY OF SACRAMENTO FIRE DEPARTMENT LOCATED AT 1231 I STREET, SUITE 401, SACRAMENTO, CA OR CALL 449-5416.

Prior to issuance of a certificate of occupancy, each business owner(s) shall contact the City of Sacramento Fire Department and comply with the Health and Safety Code regarding the use and handling of hazardous materials.

PENALTY: Any business that violates Section 25531-25541 of the Health and Safety Code shall be civilly liable to the administering agency in an amount of not more than two thousand dollars (\$2,000) for each day in which the violation occurs. If the violation results in, or significantly contributes to, an emergency, including a fire, the business shall also be assessed the full cost of the city emergency response, as well as the cost of cleaning up and disposing of the hazardous materials. Additional liability and punishment may be assessed for knowing a violation after reasonable notice of the violation.

Applicant's Name: Bret Hogge
(Print)

Bret Hogge 03/07/01
(Signature) (Date)

BID Use Only: Plan Ck# _____	Permit # <u>0100846</u>
OK to issue permit? <input checked="" type="checkbox"/> <u>03-31-01</u>	F.D. Appr Req'd? Yes No
init date	
Hold on Certificate of Occupancy? Yes <input checked="" type="checkbox"/> No	
Fire Dept. Use Only:	
OK to issue permit? init _____ date _____	
OK to issue Certificate of Occupancy? init _____ date _____	

CITY OF SACRAMENTO
BUILDING INSPECTION DIVISION
APPLICATION FOR BUILDING PERMIT - HAZARDOUS MATERIAL SURVEY

As Required by Assembly Bill #3205 - A Building Permit Cannot be Approved Without This Completed Form

1. Business Name: Graff Inc. Phone: _____
 Site Address: 5900-88th Street Suite: _____
(Street) (Zip)
 Business Owner/Representative: Stet Hagg Phone: 852 2760
 Nature of Business: Storage of carbon wires
 Property Owner: Graff Inc. Phone: _____
 Address: 5900 88th St. Suite: _____
Sacramento CA 95228
(City) (State) (Zip)

2. Are you developing an undetermined tenant space? Yes ___ No Is this permit for a shell building? Yes ___ No

Notify lessee of the responsibility to coordinate with the Fire Department regarding the use and handling of hazardous materials.

3. Does/Will your business generate hazardous waste? Yes ___ No

4. Does/Will your business handle, store or transport any solid, liquid, or gaseous chemicals? Yes ___ No

CONSULT THE EPA CHEMICAL LIST LOCATED AT THE BUILDING DIVISION COUNTER FOR HAZARDOUS OR ACUTELY HAZARDOUS MATERIALS TO COMPLETE THE FOLLOWING QUESTIONS.

If you answered "YES" to questions #3 and/or #4 above, continue on to questions 5 - 8.

5. Do you handle, store, or transport 55 gallons, 500 pounds, or 200 cubic feet (at Standard Temperature or Pressure) of a product or formulation containing hazardous materials at any one time? Yes ___ No ___

6. Do you handle, store or transport any amount of acutely hazardous materials? Yes ___ No ___

7. Is/Will your business be located within 1,000 feet of a school? Yes ___ No ___

If you answered "yes" to questions #6 and/or #7, complete the RMPP Informational sheet.

8. Is/Will your business be located within 1,000 feet of a hospital, and/or long-term healthcare facility? Yes ___ No ___

IF YOU ANSWERED "YES" TO QUESTION #3 AND/OR #4, PLEASE CONTACT THE CITY OF SACRAMENTO FIRE DEPARTMENT LOCATED AT 1231 I STREET, SUITE 401, SACRAMENTO, CA OR CALL 449-5416.

Prior to issuance of a certificate of occupancy, each business owner(s) shall contact the City of Sacramento Fire Department and comply with the Health and Safety Code regarding the use and handling of hazardous materials.

PENALTY: Any business that violates Section 25531-25541 of the Health and Safety Code shall be civilly liable to the administering agency in an amount of not more than two thousand dollars (\$2,000) for each day in which the violation occurs. If the violation results in, or significantly contributes to, an emergency, including a fire, the business shall also be assessed the full cost of the city emergency response, as well as the cost of cleaning up and disposing of the hazardous materials. Additional liability and punishment may be assessed for knowing a violation after reasonable notice of the violation.

Applicant's Name: Stet Hagg
(Print)
Stet Hagg 03/27/01
(Signature) (Date)

BID Use Only: Plan Ck# _____	Permit # <u>0100846</u>
OK to issue prmt? <input checked="" type="checkbox"/> <u>KE 37-01</u>	F.D. Appr Req'd? Yes ___ No ___
init date _____	
Hold on Certificate of Occupancy? Yes ___ No <input checked="" type="checkbox"/>	
Fire Dept. Use Only:	
OK to issue permit? ini' _____ date _____	
OK to issue Certificate of Occupancy? init _____ date _____	

APPLICATION FOR COMMERCIAL BUILDING PERMIT

CITY OF SACRAMENTO
 DEVELOPMENT SERVICES DIVISION
 PERMIT SERVICES SECTION
 1231 I Street, Rm. 200
 Sacramento, CA 95814 (916) 264-7619 FAX 264-7046

ACTIVITY # <u>0100846</u>	Insp. Area <u>3C</u>
------------------------------	-------------------------

Applicant **MUST** complete ALL Unshaded areas

ADDRESS 5980 88TH ST. SAC, 95828 Suite _____
 PARCEL # _____

CONTACT Name <u>JOE CIMORELLI</u> Street Address <u>11333 SUNCO DR. #101</u> City/State/Zip <u>RANCHO CORDOVA, CA, 95742</u> Phone <u>852-6930</u> FAX <u>852-2975</u> E-mail: _____		LICENSED CONTRACTOR Lic No. # <u>693149</u> Name <u>XCEL RACK CONTRACTORS</u> Address <u>2759 RIVER PLAZA DR. #235</u> City/State/Zip <u>SAC, CA 95833</u> Phone <u>649-8434</u> FAX <u>N/A</u> E-mail: _____	
ARCHITECT/ENGINEER Name <u>RACK DESIGN AND ENGINEERING CO.</u> Address <u>3786 LA CRASSENTA AVE. #204</u> City/State/Zip <u>GLENDALE, CA 91208</u> Phone <u>(818) 957-2980</u> FAX <u>(818) 957-8603</u> E-mail: _____		OWNER Name <u>GRAPIL INC.</u> Address <u>5980 88TH ST. SAC, CA</u> City/State/Zip <u>SAC, CA 95828</u> Phone <u>N/A</u> FAX <u>N/A</u> E-mail: _____	

→ Will permittee have any employees on the jobsite? No Yes → INSURANCE CO: _____
 → WORKER'S COMPENSATION POLICY # _____ EXPIRATION DATE: _____

NATURE OF WORK IN DETAIL: RACKS

OCCUPANT/TENANT: GRAPIL INC. VALUATION: \$ 12,000.00

FLOOD STATUS:				S.C.A.T.						
JOB DESCRIPTION		BLDG	SHELL	APT	TI()	REM()	SW	FIRE	ADD	OTH
INSPECTION DISCIPLINES			BLDG	MECH	PLUMB	ELEC	SITE	FIRE		
# Stories	1st flr Area.	Total Area	Use Zone	Occp Group	Const type	Fire Req. Y / N		Fed Code	Vio. File	
						SPR	ALARM		[H]	[Quad]
<u>B</u>	<u>L</u>	<u>P</u>	<u>M</u>	<u>E</u>	<u>F</u>	<u>S</u>		<u>D</u>	<u>PW</u>	<u>UTIL</u>

COMMENTS: _____

REGIONAL SANITATION FEES? Yes No HEALTH DEPARTMENT? Yes No
 WATER FLOW TEST FOR NEW BUILDINGS OR ADDITIONS? Provided Faxed

BY G. OHANIAN

RACK DESIGN & ENGINEERING CO.

DATE 1-3-01

3786 LA CRESCENTA AVE., SUITE 204

SHEET NO. 2

GLENDALE, CA. 91208


JOB NO. RD-5379

SUBJECT

TEL:(818)957-2980 FAX:(818)957-8603

GRAPIL, INC

5908 88th ST. SACRAMENTO, CA




FRONT VIEW

SIDE VIEW

LOAD BEAM

3000 # / LEVEL + 25% IMPACT LOAD
1800 # / BEAM




$I_x = 1.84$
 $S_x = .85$
 $F_y = 50 \text{ KSI.}$

$M = \frac{96 \times 1.8}{8} = 21.6 \text{ }^k$

$S_R = \frac{21.6}{30} = .72 < .85$

$\Delta = \frac{5 \times W \times l^3}{384 \times I_x \times E} = .32 \text{ } < \frac{96}{180} = .53 \text{ }^k$



1/2" x ANCHOR
PER BASE PLATE
AT INTERIOR COLUMNS
IS ACCEPTABLE

ISSUED

JUN 13 2001

Sacramento Building Division

O.K. JT
6/13/01

Permit No. 0100846
5908 88th St.