

BUILDING DIVISION-BUILDING INSPECTOR'S REPORT CARD

TYPE BUILDINGS

| | |
|---------------------------------------|--|
| PERMIT No. A-1413 | LOCATION 1820-3rd St. |
| DATE FEB. 21 1934 | PURPOSE Install Brick Foundation & make gen. Rep for old brick, masonry |
| ZONE General Commercial | OWNER KUNE ^{PHONES} 17 on lot Home of - 1st. Reemert Plumbing Co |
| | ARCH'T O. F. BROWN. |
| | CONT-R O. F. BROWN. |

| | | | | |
|---------------------------------|---------------------|-------|-------|------|
| VAL. 250⁰⁰ | STORIES 1 | ROOMS | APTS. | SIZE |
|---------------------------------|---------------------|-------|-------|------|

| | | |
|-------------------|----------------|------------------|
| Light Shafts | wrecked | Elevator Shafts |
| Vent Shafts | | Boiler Rooms |
| Owner's Inspector | | Sprinkler System |
| Lath | | Gas Vents |
| Fire Escapes | | Chimneys |
| Stand Pipes | | Skylights |

| DATE | CONDITION OF WORK-REMARKS |
|---------|---|
| 2/21/34 | 1 st W.S. Brick Foundation 2-brick wide for base. stepped up 2" offset to 8" walls ^{OK} - A.H. Campbell |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | COMPLETE AND O. K. INSPECTOR |