

Lot 28

BUILDING DIVISION—BUILDING INSPECTOR'S REPORT CARD \$41.00

Sherwood Heights

TYPE BUILDINGS

PERMIT NO.

E-132

LOCATION 1725 Sherwood Ave. A-3

DATE

11/21/61

PURPOSE Const dwelling and garage

ZONE

R-1

ARCH'T

WA 2-6673

CONTR Perkins Const Co 430 Grand Ave. No. Sacto

VAL.	STORIES	ROOMS	APTS.	SIZE
\$14,000.	1	6		1520 S. F.

INSP.

DATE

INSPECTOR

FORM

11-24-61 Barbach

JOIST

12-7-61 Jones

FRAME

1-22-62 Crush

LATH

1-29-62 Crush

FINAL

5-8-62 R. Hunt

DATE	SPECIAL CONDITIONS OF WORK—REMARKS
------	------------------------------------

12-6-62	Plumbing: No plan on job. No address sign
	No seals on girders joints. 2x6 perimeter
	joints on East side. Mid side not drilled. No
	stair in fireplace. Plumbing
	troughs not back-filled. Filler
1-11-62	Pl. Frame: Nailing braces for
1-16-62	No attic access door into gar. ^{Crack}
1-16-62	Pl. Frame: SR blocking improperly installed. ^{Crack}
1-18-62	Pl. Frame: Not properly blocked at pounce
3-29-62	Pl. Frame: Olds locked. ^{Filler}
4-3-62	Pl. Frame: Fixture not secured to slab
4-5-62	Pl. Frame: This corner ^{Crack}
	Pl. Frame: Connectors not made ^{Crack}

COMPLETE AND OK

INSPECTOR

