

**CITY OF SACRAMENTO**  
1231 I Street, Sacramento, CA 95814

**Permit No: 0113907**  
**Insp Area: 4**  
Thos Bros:  
Sub-Type: NSFR  
Housing (Y/N): N

**Site Address: 4 BLUE FERN CT SAC**

Parcel No: 274-0570-011

NATOMAS W 2 LOT 31

CONTRACTOR

KAUFMAN AND BROAD  
611 ORANGE DR  
VACAVILLE CA. 95687

OWNER

ARCHITECT

**Nature of Work:** NSFR MP1706 8 RMS 1 STORY

**CONSTRUCTION LENDING AGENCY :** I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name \_\_\_\_\_ Lender's Address \_\_\_\_\_

**LICENSED CONTRACTORS DECLARATION:** I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class B License Number 761970 Date 11-01-01 Contractor Signature [Signature]

**OWNER-BUILDER DECLARATION:** I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00);

\_\_\_\_ I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

\_\_\_\_ I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

\_\_\_\_ I am exempt under Sec. \_\_\_\_\_ B & PC for this reason: \_\_\_\_\_

Date \_\_\_\_\_ Owner Signature \_\_\_\_\_

**IN ISSUING THIS BUILDING PERMIT,** the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and hereby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

Date 11-01-01 Applicant/Agent Signature [Signature]

**WORKER'S COMPENSATION DECLARATION:** I hereby affirm under penalty of perjury one of the following declarations:

\_\_\_\_ I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

Q I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier AMERICAN CASUALTY Policy Number WC247837616 Exp Date 05/01/2002

\_\_\_\_ (This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Date 11-01-01 Applicant Signature [Signature]

**WARNING: FAILURE TO SECURE WORKERS COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEYS FEE.**

**THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.**

**RESIDENTIAL SUBDIVISION BUILDING PERMIT APPLICATION**

Project Address: 4 Blue Fern Court  
 Lot Number: 31

Assessor Parcel # 274-0570-011  
 Subdivision Natomas Village 2

**OWNER INFORMATION:**

Legal Property Owner: KB Home Phone# (707)469-2464  
 Owner Address: 611 Orange Drive City Vacaville State CA Zip 95687

**CONTRACTOR INFORMATION:**

Contractor: KB Home Lic. # 761970 Phone # (707)469-2464 Fax (707)469-2405

**PROJECT INFORMATION:**

Land Use Zone RIA Occupancy Group R3 Construction Type VN Fed Code 1A  
 No. of Stories: 1 No. of Rooms: \_\_\_\_\_ Street Width: \_\_\_\_\_  
 1<sup>st</sup> Floor Area 1700 2<sup>nd</sup> Floor Area \_\_\_\_\_ Basement \_\_\_\_\_ Roof Material \_\_\_\_\_

AREA IN SQUARE FOOT OF:

Dwelling/Living	<u>1700</u>
Garage/Storage	<u>436</u>
Decks/Balconies	<u>25</u>
Carports	_____

SCOPE OF WORK: New single Family Dwelling

**9-27**

FOR OFFICE USE ONLY

- |   |   |   |
|---|---|---|
| <input type="checkbox"/> Information Above Complete | <input type="checkbox"/> AR Flood Waiver Required             | <input type="checkbox"/> Planning Approval            |
| <input type="checkbox"/> Violation Files Checked    | <input type="checkbox"/> Flood Elevation Certificate Required | <input type="checkbox"/> Design Review Approval       |
| <input type="checkbox"/> Standard Setbacks          | <input type="checkbox"/> Water Development Infill Area        | <input type="checkbox"/> Special Fee Districts Apply: |
| <input type="checkbox"/> County Sewer               |   |   |

**~THE FOLLOWING MUST BE PROVIDED IN ORDER TO SUBMIT FOR PERMIT~**

- 2 COMPLETE PLOT PLANS, LEGIBLE & DRAWN TO SCALE
- 11 X 17 COPY OF FLOOR PLAN WITH FOLLOWING INFORMATION
 

a) Assessor's Parcel Number	c) Owners Name
b) New Floor Area	d) Project Address

# CERTIFICATION OF INSULATION

PART I GENERAL  
PART II AREAS INSULATED  
PART III CERTIFICATION

ADDRESS ON FILE <div style="font-size: 24pt; font-weight: bold; margin-left: 20px;">K&amp;B</div> LOT # <span style="font-size: 24pt; font-weight: bold;">31</span>  <div style="font-size: 24pt; font-weight: bold; margin-left: 20px;">4 BLUE FERN Ct.</div>  <div style="font-size: 24pt; font-weight: bold; margin-left: 20px;">California GARDENS</div>	SACRAMENTO BUILDING PRODUCTS <input checked="" type="checkbox"/> P.O. BOX 854, WEST SACRAMENTO, CA 95691 LIC. #202026 <input type="checkbox"/> 1309 MELODY ROAD, MARYSVILLE, CA 95901 LIC. #202026 <input type="checkbox"/> P.O. BOX 9651, FRESNO, CA 93793-9651 LIC. #202026 <input type="checkbox"/> P.O. BOX 1631, RENO, NV 89505 LIC. #10675 <input type="checkbox"/> 3326 A PONDEROSA WAY, LAS VEGAS, NV 89118 LIC. #10675  DATE INSULATION COMPLETED <div style="font-size: 24pt; font-weight: bold; margin-left: 20px;">6-24-02</div>
---	--

WALLS			CEILING			FLOORS		
( SQUARE FEET)			( SQUARE FEET)			( SQUARE FEET)		
TYPE OF INSULATION			TYPE OF INSULATION			TYPE OF INSULATION		
MATERIAL <b>FIBERGLASS</b>			MATERIAL <b>FIBERGLASS</b>			MATERIAL <b>FIBERGLASS</b>		
FORM <b>BATTS</b>			FORM <b>BATTS &amp; BLOW</b>			FORM <b>BATTS</b>		
MANUFACTURER'S PRODUCT I.D.			MANUFACTURER'S PRODUCT I.D.			MANUFACTURER'S PRODUCT I.D.		
MANUFACTURER			MANUFACTURER			MANUFACTURER		
CT	OC	JM	CT	OC	JM	CT	OC	JM
BAGS			BAGS			BAGS		
APPLIED THICKNESS	R-VALUE	MIN. INSTALLED	APPLIED THICKNESS	R-VALUE	MIN. INSTALLED	APPLIED THICKNESS	R-VALUE	MIN. INSTALLED
13	3 7/8	38	12	12				
		38	14 3/4					

KNEE WALLS IF R-VALUE IS OTHER THAN WALLS ABOVE

MATERIAL <b>FIBERGLASS</b>	FORM <b>BATTS</b>	R VALUE	MANUFACTURER
			CT OC JM

AIR INFILTRATION SEALANT

MATERIAL <b>FOAM</b>	MANUFACTURER
	HILTI HANDY FOAM

THIS IS TO CERTIFY THAT INSULATION AND/OR SEALANT HAS BEEN INSTALLED IN CONFORMANCE WITH APPLICABLE CODES, MATERIAL STANDARDS AND REGULATIONS.

SIGNATURE — INSULATION CONTRACTOR <i>Jeff Cable</i>	TITLE <b>MANAGER</b>	DATE <b>7-1-02</b>
SIGNATURE — GENERAL CONTRACTOR	TITLE	DATE

REMARKS



**WALLACE • KUHL & ASSOCIATES INC.**  
 GEOTECHNICAL ENGINEERING • CONSTRUCTION TESTING

3050 Industrial Blvd.  
 PO Box 1137  
 West Sacramento  
 California 95691  
 916-372-1434

DATE 5.30.02		JOB NO. 3750.04		WEATHER		TEMP. ° at		AM	
PROJECT K + B Cal Gardens		Technician I		<input type="checkbox"/>		Staff E/G		<input type="checkbox"/>	
LOCATION BLUE FERN CT LOTS 31, 33, 35 36, 42, 43 + 44		Technician II		<input type="checkbox"/>		Project E/G		<input type="checkbox"/>	
TYPE OF WORK ANCHOR LOAD PULL TESTING		Technician III		<input type="checkbox"/>		Senior E/G		<input type="checkbox"/>	
Inside 50 mi. radius <input checked="" type="checkbox"/>		Outside 50 mi. radius <input type="checkbox"/>		Nuclear Densities		<input type="checkbox"/>		Principal E/G <input type="checkbox"/>	
PERSONNEL	REG. HRS	OT HRS	TOTAL HRS	TRAVEL	ON JOB	VEHICLE	MILES		
K. KUNDRAK						#31			

OBSERVATIONS:  
 PERFORMED ANCHOR LOAD PULL TESTS AS FOLLOWS


(LOT #)	(ANCHOR)	(BOLT SIZE)	(TEST VALUE)	(RESULT)
LOT 31	(2) HTT22'S	5/8" BOLTS	6398*/3000 PSI =	PASSED
33	}	(10) SILL ANCHORS	3/8" BOLTS	4000*/2000 PSI =
36				
35	(2) HTT22'S	5/8" BOLTS	6398*/3000 PSI =	PASSED
42	(1) HD8A	7/8" BOLT	10,444*/6200 PSI =	HELD PASSED

ALL TESTED BOLTS MARKED WITH PINK MARKING PAINT.  
 USED RAM JACK F/GAUGE SF

NOTE: LOTS 35, 36, 43 + 44 NEEDED 7/8" ANCHOR TESTS  
 AT STRONG WALLS, HOWEVER HARDWARE WAS  
 IN PLACE OBSTRUCTING ACCESS. DAN W/KB IS  
 HAVING CEDAR VALLEY PREP THEM FOR ACCESS +  
 TESTING TOMORROW (5/31/02) AM.

**FIELD REPORT**

Signed Karen M. Kundrak



SWEET MAPLE WAY

BLUE FERN COURT

SCALE 1" = 20'

DATE: 7-27-01  
 A.P.N.: 274-0570-011  
 ADDRESS: 4 BLUE FERN COURT

LOT AREA: 5,468 SF  
 LOT COVERAGE: 40%

**Stantec**

Stantec Consulting Inc.  
 2590 Venture Oaks Way  
 Sacramento, CA 95833-3288  
 Tel. 916.925.5550  
 Fax. 916.921.9274  
 www.stantec.com

**NATOMAS WEST  
 VILLAGE 2**

**LOT 31  
 PLAN 3A**

**CALIFORNIA GARDENS**

CITY OF SACRAMENTO, CA  
 CLIENT: KAUFMAN & BROAD