

CITY OF SACRAMENTO  
1231 I Street, Sacramento, CA 95814

Permit No: 0102092  
Insp Area: 4

Site Address: 4612 WINDSONG ST SAC  
Parcel No: 225-1210-005 GATEWAY N 1 LOT 5

Sub-Type: NSFR  
Housing (Y/N): N

CONTRACTOR  
MARCHBROOK BUILDING CO  
PO BOX 7576  
STOCKTON CA 95267

OWNER

ARCHITECT

Nature of Work: NSFR MP2010 1 STORY 7 RMS

**CONSTRUCTION LENDING AGENCY:** I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C.)

Lender's Name \_\_\_\_\_ Lender's Address \_\_\_\_\_

**LICENSED CONTRACTORS DECLARATION:** I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class 5 License Number 740353 Date 3/28/01 Contractor Signature Paul B...

**OWNER-BUILDER DECLARATION:** I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00).

I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code. The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code. The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

I am exempt under Sec. \_\_\_\_\_ B & PC for this reason: \_\_\_\_\_

Date \_\_\_\_\_ Owner Signature \_\_\_\_\_

**IN ISSUING THIS BUILDING PERMIT,** the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and hereby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

Date 3/28/01 Applicant/Agent Signature Paul B...

**WORKER'S COMPENSATION DECLARATION:** I hereby affirm under penalty of perjury one of the following declarations:

I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

P/B I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier SAFECO INSURANCE CO OF AMERICA Policy Number WC2342690D Exp Date 07/01/2001

(This section need not be completed if the permit is for a CONSTRUCTION PLANNING project that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Date 3/28/01 Applicant Signature Paul B...

WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.

**THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.**

**RESIDENTIAL BUILDING PERMIT APPLICATION**

New Construction     Addition     Remodels     Other

Project Address: 4622 Wincomg Street    Assessor Parcel # 225-1210-005

OWNER INFORMATION: Lot 5 - MP-2010

Legal Property Owner: Sundance Lake LLC, A Delaware Limited Liability Co. Phone # (209)473-6000  
 Owner Address: P.O. Box 7576 City Stockton State CA Zip 95267

**CONTRACTOR INFORMATION:**

Contractor: Marchbrook Building Co Lic. # 740353 Phone # (209)473-6000 Fax # (209)473-6044

**PROJECT INFORMATION:**

Land Use Zone \_\_\_\_\_ Occupancy Group \_\_\_\_\_ Construction Type \_\_\_\_\_ Fed Code \_\_\_\_\_

No. of stories: 1 No. of rooms: 7 Street width: \_\_\_\_\_

1<sup>st</sup> Floor Area 2010 2<sup>nd</sup> Floor Area \_\_\_\_\_ Basement \_\_\_\_\_ Roof Material \_\_\_\_\_

| AREA IN SQUARE FOOT OF: | EXISTING    | NEW   |
|-------------------------|-------------|-------|
| Dwelling/Living         | <u>2010</u> | _____ |
| Garage/Storage          | <u>556</u>  | _____ |
| Decks/Balconies         | <u>60</u>   | _____ |
| Carports                | <u>10/A</u> | _____ |

SCOPE OF WORK: SFD

**FOR OFFICE USE ONLY**

|   |   |  |
|---|---|--|
| <input type="checkbox"/> Information above complete | <input type="checkbox"/> AR Flood Waiver required             | <input type="checkbox"/> Planning Approval                   |
| <input type="checkbox"/> Violation files checked    | <input type="checkbox"/> Flood Elevation Certificate Required | <input type="checkbox"/> Design Review Approval              |
| <input type="checkbox"/> Standard setbacks          | <input type="checkbox"/> Water Development Infill Area        | <input type="checkbox"/> Special Fee Districts Apply : _____ |
| <input type="checkbox"/> County Sewer               | _____   |  |

**NEW STRUCTURES & ADDITIONS**

❖ THE FOLLOWING MUST BE PROVIDED IN ORDER TO SUBMIT FOR PLAN REVIEW

2 COMPLETE PLANS, LEGIBLE & DRAWN TO SCALE    ❖ *Plans to include: site plan, floor plan, elevations, roof/ceiling plan, foundation and structural framing details, and structural calculations for non-conforming structures.*


3 SETS IF PROJECT IS IN A DESIGN REVIEW AREA

Title 24 Energy Compliance documentation     11" x 17" copy of floor plan for County Assessor

Grading and Erosion Control Questionnaire     Plan Review Fees

Date: \_\_\_\_\_ Received by: (staff) \_\_\_\_\_

ACTIVITY/PERMIT #



# WesPac

## Insulation

8 MASCO COMPANY



809 North Market Blvd., Ste. 11 • Sacramento, CA 95834  
(916) 927-7149 • Fax (916) 927-4257  
Lic. #487478

### Installed Insulation Certificate

We certify that the building insulation listed herein is installed in conformance with current energy conservation regulations, California Administrative Code, Title 24, State of California

| REACTION | AREA           | TYPE             | INCHES/BACS (ELOWN) |
|----------|----------------|------------------|---------------------|
| R38      | ATTIC          | FIBERGLASS BLOWN | 14.75" / 36         |
| R38      | CEILING        | FIBERGLASS BATT  | 13"                 |
| R13      | EXTERIOR WALLS | FIBERGLASS BATT  | 3.5"                |

JOHN LAING

Certified by *Jimmy Shivers*  
Secretary

SUNDANCE LAKE  
MARC SUNDANCE LAKE/5  
Address or Lot Number

Date Installed 07/26/01  
Phase 1



**ALLACE • KUHL & ASSOCIATES INC.**  
 GEOTECHNICAL ENGINEERING • CONSTRUCTION TESTING

3050 Industrial Blvd.  
 PO Box 1137  
 West Sacramento  
 California 95691  
 916-372-1434

|  |  |  |  |          |        |         |       |
|--|--|--|--|----------|--------|---------|-------|
| DATE<br>6-4-01   | JOB NO.<br>3895.14                             | WEATHER                                    | TEMP.<br>° at<br>° at                  | AM<br>PM |        |         |       |
| PROJECT<br>GATEWAY WEST 2                                |  | Technician I <input type="checkbox"/>      | Staff E/G <input type="checkbox"/>     |          |        |         |       |
| LOCATION<br>Lots # 4, 5                                  |  | Technician II <input type="checkbox"/>     | Project E/G <input type="checkbox"/>   |          |        |         |       |
| TYPE OF WORK<br>PULL TEST                                |  | Technician III <input type="checkbox"/>    | Senior E/G <input type="checkbox"/>    |          |        |         |       |
| Inside 50 mi. radius <input checked="" type="checkbox"/> | Outside 50 mi. radius <input type="checkbox"/> | Nuclear Densities <input type="checkbox"/> | Principal E/G <input type="checkbox"/> |          |        |         |       |
| PERSONNEL  | REG. HRS                                       | OT HRS                                     | TOTAL HRS                              | TRAVEL   | ON JOB | VEHICLE | MILES |
| DS   | 1.0  | 0  | 1.5                                    | .5       | 7 AM   | # 14    | 16    |

OBSERVATIONS:  
 ON SITE AS REQUESTED @ 7 AM TO PERFORM PULL TEST ON 5/8" ALL-THREAD FOR HITZ'S HOLD DOWNS @ A PULL VALUE OF 7500# PER ENGINEER AND A GAGE PSI. OF 3300# USING JACK A WITH GAGE # SA @ THE FOLLOWING LOCATIONS.

LOT # 4 - 1EA. W/WALL LIVING RM. 2EA. W/WALL MASTER BEDROOM SHOWER. 1EA. S/WALL GARAGE. PASSED.

LOT # 5 - 1EA. W/WALL DINING ROOM. 2EA. W/WALL GARAGE. PASSED.