

R222 F598-604

BUILDING DIVISION — BUILDING INSPECTOR'S REPORT CARD

\$119.50

Municipal Airport

TYPE BUILDINGS

*show plan 10.4.67**4234**417 file*

PERMIT NO. F-8275	LOCATION 6201 Freeport Blvd.		A-4	
DATE Aug. 21/67	PURPOSE Const. office building at airport			
ZONE	OWNER Yttrup & Oates 6700-Folsom Blvd.			
	ARCH'T			
	CONT'R A & A Builders	Same		452-1471
VAL. \$40,000.	STORIES 1	ROOMS	APTS.	SIZE 4,130 sq. ft.
INSP.	DATE	BLDG. TYPE V no hr.	OCCUPANCY GROUP F-2	PHONE (O) (C)
FORM	<i>3/1/67</i>	<i>Correct</i>		
JOIST				
FRAME	<i>10.16.67</i>	<i>Correct</i>		
SHEET ROCK	<i>10.16.67</i>	<i>Correct</i>		
FINAL	<i>11.9.67</i>	<i>Correct</i>		<i>Est</i>

DATE	SPECIAL CONDITIONS OF WORK — REMARKS <i>Fuller</i>
8-30-67	<i>OK perimeter & pier footing</i>
10-2-67	<i>OK roof nail - no glue lam. ^{Coast} report</i>
10-16-67	<i>OK wall & roof nail ^{Coast}</i>
11-6-67	<i>OK Bond - Permanent address not</i>
	<i>installed. Fire Hydrant not installed ^{Fuller}</i>
	<p>COMPLETE AND OK</p> <p style="text-align: right;">INSPECTOR</p>