

INSTALLATION CERTIFICATE

CF-6R

Beck Properties - Pelican Pointe

Site Address

Permit Number

An installation certificate is required to be posted at the building site or made available for all appropriate inspections. (The information provided on this form is required; however, use of this form to provide the information is optional.) After completion of final inspection a copy must be provided to the building department (upon request) and the building owner at occupancy, per Section 10-103(b).

HVAC SYSTEMS:

Heating Equipment

Equip. Type (pkg. Heat pump)	CEC Certified Mfr name and Model #	# of Identical Systems	(1) Efficiency (AFUE, etc.) > CF-1R value	Duct Location (attic, etc.)	Duct or Piping R-value	Heating Load (Btu/hr)	Heating Capacity (Btu/hr)	
Furnace	York #P4HUC20L8001	1	0.80	Attic	R-4.2	42,926	100,000	Plan 1
Furnace	York #P4HUC20L8001	1	0.80	Attic	R-4.2	47,748	100,000	Plan 2
Furnace	York #P4HUC20L8001	1	0.80	Attic	R-4.2	52,101	100,000	Plan 3
Furnace	York #P4HUC20L8001	1	0.80	Attic	R-4.2	55,213	100,000	Plan 4

Cooling Equipment

Equip. Type (pkg. Heat pump)	CEC Certified Compressor Unit Mfr Name and Model #	# of Identical Systems	(1) Efficiency (SEER, etc.) > CF-1R value	Duct Location (attic, etc.)	Duct R-value	Cooling Load (Btu/hr)	Cooling Capacity (Btu/hr)	
Condenser	York #H*RC042	1	12.0	Attic	R-4.2	34,006	39,000	Plan 1
Condenser	York #H*RC048	1	12.0	Attic	R-4.2	37,718	47,000	Plan 2
Condenser	York #H*RC048	1	12.0	Attic	R-4.2	42,783	47,000	Plan 3
Condenser	York #H*RC048	1	12.0	Attic	R-4.2	44,810	47,000	Plan 4

***TXV - Indicates Thermal Expansion Valve On Coil**

(1) > reads greater than or equal to.

I, the undersigned, verify that equipment listed above is: 1) is the actual equipment installed, 2) equivalent to or more efficient than that specified in the certificate of compliance (Form CF-1R) submitted for compliance with the Energy Efficiency Standards for residential buildings, and 3) equipment that meets or exceeds the appropriate requirements for manufactured devices (from the Appliance Efficiency Regulations or Part 6), where applicable.

Michael Radelsky 9-8-03
Signature, Date

Beutler Corporation

OR General Contractor (Co. Name) OR Owner

WATER HEATING SYSTEMS:

Heater Type	CEC Certified Mfr Name & Model #	Distribution Type (Std. point of use)	If Recirculation Control Type	# of Identical Systems	(2) Rated Input (kW or Btu/hr)	Tank Volume (gallons)	(2) Efficiency (EF,RE)	(2) Standby Loss (%)	External Insulation R-value

(2) For small gas storage (rated input of less than or equal to 75,000 Btu/hr), electric resistance and heat pump water heaters, list Energy Factor. For large gas storage water heaters (rated input of greater than 75,000 Btu/hr), list Recovery Efficiency, Standby Loss and Rated Input. For instantaneous gas water heaters, list Recovery efficiency and Rated Input.

(3) R-12 external insulation is mandatory for storage water heaters with an energy factor of less than 0.58.

Facets & Shower Heads:

All facets and showerheads installed are certified to the Commission, pursuant to Title 24, Part 6, Section 111.

I, the undersigned, verify that equipment listed above my signature is: 1) the actual equipment installed; 2) equivalent to or more efficient than that specified in the certificate of compliance (Form CF-1R) submitted for compliance with the Energy Efficiency Standards for residential buildings; and 3) equipment that meets or exceeds the appropriate requirements for manufactured devices (from the Appliance Efficiency Regulations or Part 6), where applicable.

Signature, Date

Installing Subcontractor (Co. Name)

OR General Contractor (Co. Name) OR Owner

COPY TO: Building Department
HERS Provider (if applicable)
Building Owner at Occupancy

CERTIFICATION OF INSULATION

PART I
GENERAL

Beck Pelican P. LOT # 42-2

- P.O. BOX 854, WEST SACRAMENTO, CA 95691 LIC. #202026
- 1309 MELODY ROAD, MARYSVILLE, CA 95901 LIC. #202026
- P.O. BOX 9651, FRESNO, CA 93793-9651 LIC. #202026
- P.O. BOX 1631, RENO, NV 89505 LIC. #10675
- 3326 A PONDEROSA WAY, LAS VEGAS, NV 89118 LIC. #10675

DATE INSULATION COMPLETED 11-19-04

PART II
AREAS INSULATED

WALLS			CEILINGS			FLOORS			
(SQUARE FEET)			(SQUARE FEET)			(SQUARE FEET)			
MATERIAL			MATERIAL			MATERIAL			
FIBERGLASS			FIBERGLASS			FIBERGLASS			
FORM			FORM			FORM			
BATTS			BATTS & BLOW			BATTS			
MANUFACTURER'S PRODUCT I.D.			MANUFACTURER'S PRODUCT I.D.			MANUFACTURER'S PRODUCT I.D.			
MANUFACTURER			MANUFACTURER			MANUFACTURER			
CT	OC	JM	CT	OC	JM	CT	OC	JM	
BAGS			BAGS			BAGS			
R-VALUE	APPLIED	R-VALUE	APPLIED	R-VALUE	APPLIED	R-VALUE	APPLIED	R-VALUE	
13 19	3 1/2 5 1/2	38	14						
KNEE WALLS IF R-VALUE IS OTHER THAN WALLS ABOVE									
MATERIAL		FORM		R VALUE			MANUFACTURER		
FIBERGLASS		BATTS					CT	OC	JM
MATERIAL				MANUFACTURER					
				HILTI		HANDY FOAM			

PART III
CERTIFICATION

THIS IS TO CERTIFY THAT INSULATION AND/OR SEALANT HAS BEEN INSTALLED IN COMPLIANCE WITH APPLICABLE CODES, MATERIAL STANDARDS AND REGULATIONS.

SIGNATURE — INSULATION CONTRACTOR	J.C.	TITLE	MANAGER	DATE	11-19-04
SIGNATURE — GENERAL CONTRACTOR		TITLE		DATE	

REMARKS

BUILDER COPY