


0415917

8951 OSAGE AV

2005 ACCEPTANCE REQUIREMENTS FOR CODE COMPLIANCE**Lighting Control Acceptance Document**

LTG-2-A

Form of

PROJECT NAME <i>Remy Handal - Handal Stone</i>	DATE <i>11-15-06</i>
PROJECT ADDRESS <i>8951 - 8957 Osage Ave, Spoto, CA</i>	
TESTING AUTHORITY	
LIGHTING CONTROL SYSTEM NAME / DESIGNATION	

Intent: Lights are turned off when not needed per 119(d) & 131(d).**Construction Inspection**

- 1 Instrumentation to perform test includes, but not limited to:
 - a. Light meter
 - b. Hand-held amperage and voltage meter
 - c. Power meter
- 2 Occupancy Sensor Construction Inspection
 - Occupancy sensor has been located to minimize false signals
 - Occupancy sensors do not encounter any obstructions that could adversely effect desired performance
 - Ultrasonic occupancy sensors do not emit audible sound (119a) 5 feet from source
- 3 Manual Daylighting Controls Construction Inspection
 - If dimming ballasts are specified for light fixtures within the daylit area, make sure they meet all the Standards requirements, including "reduced flicker operation" for manual dimming control systems
- 4 Automatic Time Switch Controls Construction Inspection
 - a. Automatic time switch control is programmed for (check all):
 - Weekdays
 - Weekend
 - Holidays
 - b. Document for the owner automatic time switch programming (check all):
 - Weekdays settings
 - Weekend settings
 - Holidays settings
 - Set-up settings
 - Preference program setting
 - Verify the correct time and date is properly set in the time switch
 - Verify the battery is installed and energized
 - Override time limit is no more than 2 hours

MICROFILM AT FINAL

Certification Statement: I certify that all statements are true on this LTG-2-A form including the PASS/FAIL Evaluation.

I affirm I am eligible to sign this form under the provisions described in the Statement of Acceptance on form LTG-1-A

Name: CHRIS HARAKASCompany: SAC City ElectricSignature: Date: 10-19-06

0415917

8951 OSAGE AV

2005 ACCEPTANCE REQUIREMENTS FOR CODE COMPLIANCE

Automatic Daylighting Controls Acceptance Document LTG-3-A
Form of

<small>PROJECT NAME</small> Remy Handal - Handalstone	<small>DATE</small> 11-15-06
<small>PROJECT ADDRESS</small> 8951-8959- Osage Ave, Sacto, CA	
<small>TESTING AUTHORITY</small>	
<small>TELEPHONE</small>	
<small>AUTOMATIC DAYLIGHTING CONTROL NAME / DESIGNATION</small>	
<small>Checked by/Date Enforcement Agency Use</small>	

Intent: Verify operation of daylighting systems meet 119(e)2.

Construction Inspection

- 1 Instrumentation to perform test includes, but not limited to:
 - a. Light meter
 - b. Hand-held amperage and voltage meter
 - c. Power meter
- 2 Documentation of all control devices (photocells) have been properly located including:
 - a. Factory-calibrated (proof required)
 - Factory-calibration certificate attached
 - b. Field-calibrated
 - Setpoint properly set
 - Lighting threshold
- 3 Documentation has been provided by the installer for:
 - Setpoints for each device
 - Settings for each device
 - Programming for each device
- 4 Luminaires controlled by automatic daylighting controls are only in daylit areas; and
 - Separately circuited for daylit areas by windows and daylit areas under skylights

MICROFILM AT FINAL

Certification Statement: I certify that all statements are true on this LTG-3-A form including the PASS/FAIL Evaluation.

I affirm I am eligible to sign this form under the provisions described in the Statement of Acceptance on form LTG-1-A

Name: CHRIS HARAKAS

Company: OAC CITY ELECTRIC

Signature: [Signature]

Date: 10-19-06