

**CITY OF SACRAMENTO**  
1231 I Street, Sacramento, CA 95814

**Permit No: 0009202**

**Insp Area: 1**

**Site Address: 5641 J ST SAC**

Parcel No: 008-0122-021

Sub-Type: REM

Housing (Y/N): N

**CONTRACTOR**

CAI RAM  
1891 ENTERPRISE  
W. SACRAMENTO CA 95691

**OWNER**

JERRY THOMPSON  
1207 FRONT ST  
SACRAMENTO CA 95814

**ARCHITECT**

**Nature of Work:** RESTAURANT & APT. REMODEL/FIRE REPAIR; PARKING LOT;NEW COOLER&TRASH ENCLOSURE,DRIVEWAY.HC.& CURB.

**CONSTRUCTION LENDING AGENCY :** I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name WESTERN SUGAR BANK Lender's Address \_\_\_\_\_

**LICENSED CONTRACTORS DECLARATION:** I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class \_\_\_\_\_ License Number \_\_\_\_\_ Date \_\_\_\_\_ Contractor Signature \_\_\_\_\_

**OWNER-BUILDER DECLARATION:** I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00).

\_\_\_\_ I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

\_\_\_\_ I am exempt under Sec. \_\_\_\_\_ B & PC for this reason: \_\_\_\_\_

Date 12-28-00 Owner Signature [Signature] **PAID**  
**CITY OF SACRAMENTO**  
**NEIGHBORHOODS PLANNING AND DEVELOPMENT SERVICES**  
DEC 28 2000

**IN ISSUING THIS BUILDING PERMIT,** the applicant represents, and the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvement. This permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and hereby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

Date 12-28-00 Applicant/Agent Signature [Signature]

**WORKER'S COMPENSATION DECLARATION:** I hereby affirm under penalty of perjury one of the following declarations:

\_\_\_\_ I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued

\_\_\_\_ I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier FREMONT COMP Policy Number WN00-795293-02 Exp Date 04/01/2001

(This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Date 12-28-00 Applicant Signature [Signature]

**WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.**

**THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.**

CITY OF SACRAMENTO

30 DAY TEMPORARY  
Certificate of Occupancy

For Information Contact (916) 264-5716

Building Address: 5641 J ST Permit No. 0009202

Building Use: RESTAURANT & APARTMENT Occupancy: A-3, R-1

Building Owner: JERRY THOMPSON Construction Type: V-N

Owner Address: 1207 FRONT ST SACRAMENTO Sprinkled? [ ] Yes [x] No

Portion of Building Occupied: ENTIRE Area: 3438 Sq. Ft.

Specific purpose for temporary occupancy and/or conditions/limitations of temporary occupancy:

5/23/01

Date

Walter Harris

By: Print

Sign

DENNIS RICHARDSON


CITY BUILDING OFFICIAL

[TCO approvals: DP, MJS, JZB, SB, MG]

**BC 109.4 TEMPORARY CERTIFICATE**

*If the Chief Building Official finds that no substantial hazard will result from occupancy of any building or portion thereof before the same is completed, a temporary Certificate of Occupancy may be issued for the use of a portion or portions of a building or structure prior to the completion for the entire building or structure.*

**POST IN A CONSPICUOUS PLACE**



Insp. Area 1C

The set of plans and specifications must be kept on the job at all times and it is unlawful to make any changes or alterations from the original without written permission from the Building Inspection Division.

# AUTHORIZATION TO START WORK ISSUED

CITY OF SACRAMENTO, BUILDING INSPECTIONS DIVISION, 2000  
1511 ST. ROOM 200, SACRAMENTO, CA 95814

The approval of this plan and specification SHALL NOT be held to permit or approve the violation of any City Ordinance or State Law.

Company: Sacramento Building Division  
CONSTRUCTION CO. INC. PC # 00-09202  
Address: 1891 ENTERPRISE W. SACTO BID App. \_\_\_\_\_  
Job Phone: \_\_\_\_\_ Office Ph. 372-1610 Fee 350.00  
SUBJECT: Project Address: 5641 J ST Suite # \_\_\_\_\_

I request permission to start the following work INTERIOR, NONSTRUCTURAL ROUGH FRAMING, PLUMBING, ELECTRICAL, MECHANICAL, NO SHEETROCK & DO NOT COVER ANYTHING UP. FOR INTERIOR DEMOLITION ONLY

I realize that all work will be at the owner's and contractor's risk without assurance that the permit for the project will be granted. Any code conflicts will be corrected. I agree not to cover or conceal any work or portion thereof. I realize that inspections will not be made on this project until a building permit is issued. All changes required to conform to the approved plans will be completed without dispute. Work affecting the structural integrity of the existing building is not permitted.

I will expedite necessary revisions, corrections and clarifications as required to obtain the building permit.

If it should be determined subsequently by the City that changes in the design of the building are necessary after commencement of the work authorized, I assume full responsibility and all risk of loss which may result by reason of such changes. I agree that the building shall conform to the approved final plans as amended, without regard to the stage of completion.

This authorization is valid for 30 days while the plans are being processed for permit. These state required declarations must be properly executed before this authorization is valid. This authorization is valid when initialed by authorized Building Department personnel and stamped approved. Keep posted on job site at all times.

## CONSTRUCTION LENDING AGENCY

I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ.C.)

Lender's Name WESTERN SIERRA NATIONAL BANK  
Lender's Address 1900 POINT WEST WY. SACTO 95815

## LICENSED CONTRACTORS DECLARATION

I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with Section 7000) of the Business and Professions Code and my license is in full force and effect.

Lic. Class: BB Lic. Number: 466622 CON CONST.  
SIGNATURE \_\_\_\_\_ DATE 11-29-00

OWNER-BUILDER DECLARATION

I hereby affirm under penalty of perjury that I am exempt from the Contractors License Law for the following reason (Section 703.1, Business and Professions Code: Any city or county which requires a permit to construct, alter, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00):

I, as owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his or her own employees, provided that such improvement are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he or she did not build or improve for the purpose of sale).

I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

I am exempt under Sec. \_\_\_\_\_ B & P Code for this reason \_\_\_\_\_

\_\_\_\_\_  
SIGNATURE DATE

WORKER'S COMPENSATION DECLARATION

I hereby affirm under penalty of perjury one of the following declarations:

I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued.

I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier: GOLDEN EAGLE Insurance Co. exp. 4-20-01

Policy No.: CLP 64858900

I certify under penalty of perjury that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

\_\_\_\_\_  
SIGNATURE DATE

WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEES.

In issuing this permit, the applicant represents, and the City relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or the accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read, understand and agree to the above conditions. I certify under penalty of perjury that the above information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and hereby authorize representatives of this city to enter upon the above mentioned property for inspection purposes.

[Signature] 11-29-00  
SIGNATURE OF APPLICANT OR AGENT DATE

**APPLICATION FOR COMMERCIAL BUILDING PERMIT**

**CITY OF SACRAMENTO**  
**DEVELOPMENT SERVICES DIVISION**  
**PERMIT SERVICES SECTION**

2311 Street, Rm. 200  
 Sacramento, CA 95814 (916) 264-7619 FAX 264-7046

ACTIVITY # <u>00-09202</u>	Insp. Area <u>1C</u>
-------------------------------	-------------------------

Applicant **MUST** complete ALL Unshaded areas

ADDRESS 5645 S St Suite \_\_\_\_\_  
 PARCEL # 008-0121-021 + [REDACTED]

<p align="center"><b>CONTACT</b></p> Name <u>Jerry Thompson</u> Street Address <u>1207 Front St</u> City/State/Zip <u>Sacto</u> Phone <u>442-0983</u> FAX <u>442-2126</u> E-mail: <u>955-2734</u> <u>cell 955-2734</u>	<p align="center"><b>LICENSED CONTRACTOR</b> Lic No. # _____</p> Name <u>Kleann FUEBLEIN</u> Address _____ City/State/Zip <u>[Signature]</u> Phone _____ FAX _____ E-mail: _____
<p align="center"><b>ARCHITECT/ENGINEER</b> C11751</p> Name <u>ERABEL KUSMOSSEN</u> Address <u>1725 J St</u> City/State/Zip <u>Sacto CA</u> Phone <u>444-6966</u> FAX <u>444-7490</u> E-mail: _____	<p align="center"><b>OWNER</b></p> Name <u>J St Food + BEV INC</u> Address <u>1207 Front St #23</u> City/State/Zip <u>Sacto</u> Phone <u>442-0983</u> FAX <u>442-2126</u> E-mail: _____

→ Will permittee have any employees on the jobsite?  No  Yes → INSURANCE CO: \_\_\_\_\_  
 → WORKER'S COMPENSATION POLICY # \_\_\_\_\_ EXPIRATION DATE: \_\_\_\_\_

NATURE OF WORK IN DETAIL: Restaurant Remodel + APT Remodel  
NEW Coolers, Tough enclosures, restriping parking  
FIRE REPAIR  
 VALUATION: \$ 305,000

OCCUPANT/TENANT: EAST END PUBLIC HOUSE VALUATION: \$ 305,000

FLOOD STATUS: <u>NA</u>		S.C.A.T. XI; XII; X12; <u>301</u> ; 207; <u>X95</u> ; 701								
JOB DESCRIPTION		BLDG	SHELL	APT	TI( )	REM( )	SW	FIRE	ADD	OTH
INSPECTION DISCIPLINES		<u>BLDG</u>	<u>MECH</u>	<u>PLUMB</u>	<u>ELEC</u>	<u>SITE</u>	<u>FIRE</u>			
# Stories	1st flr Area	Total Area	Use Zone	Occp Group	Const type	Fire Req. Y/N	Fed Code	Vio. File		
<u>2</u>	<u>3438</u>	<u>5070</u>	<u>APT</u>	<u>A-3</u> <u>R-1</u>	<u>V-U</u>	<u>Y</u>	<u>18</u>	[H]	[Quad]	
<u>B</u>	<u>C</u>	<u>P</u>	<u>M</u>	<u>E</u>	<u>F</u>	<u>S</u>	<u>D</u>	<u>PW</u>	<u>UTIL</u>	

COMMENTS: \_\_\_\_\_  
 \_\_\_\_\_  
1302

REGIONAL SANITATION FEES  Yes  No HEALTH DEPARTMENT  Yes  No  
 WATER FLOW TEST FOR NEW BUILDINGS OR ADDITIONS?  Provided  Faxed

Date of Request: \_\_\_\_\_

By: \_\_\_\_\_

**CITY OF SACRAMENTO DEVELOPMENT SERVICES DIVISION  
PLANNING AND ZONING INFORMATION REQUEST**

Project Address: 5641

Assessor's Parcel Number 008-0121-021 ✓

Previous Use Restaurant

Description of Request/Proposed Use Fire Damage Repair

92-118

Is This a Change of Use? NO

Zoning Designation: C-2

Prior Applications for Project Site(P#, Z#, DRPB#): \_\_\_\_\_

Comments \_\_\_\_\_

No more than 72 seats

Are There Any Planning Issues?: (circle one) YES (NO)

- \* Staff Site Plan Check Required? (Circle one) YES (NO)
- \* Field Inspection Required? (Circle one) YES (NO)
- \* Design Review/Preservation Required?: (Circle one) YES (NO)

Planning Review by/Date: Sandra Lopez 9 Aug 00

A list of items that must be reviewed by Planning is provided on the reverse side of this form.

MICROFILM AFTER FINAL

OWNER-BUILDER VERIFICATION

ATTENTION PROPERTY OWNERS

An owner-builder building permit has been applied for in your name and bearing your signature.

Please complete and return this information in the envelope provided at your earliest opportunity to avoid unnecessary delay in processing and issuing your building permit. No building permit will be issued until this verification is received.

1. I personally plan to provide the major labor and materials for construction of the proposed Improvement (yes or no) \_\_\_\_\_

2. I (have/have not) Jerry Thompson signed an application for A building permit for the proposed work.

3. I have contracted with the following person (firm) to provide the proposed construction:

Name CAL P&W Address 1891 Enterprise

City WEST SACK Telephone 372-1610

Contractors License No. 466622

4. I plan to provide portions of the work, but I have hired the following person to coordinate, Supervise, and provide the major work.

Name \_\_\_\_\_ Address \_\_\_\_\_

City \_\_\_\_\_ Telephone \_\_\_\_\_

Contractors License No. \_\_\_\_\_

5. I will provide some of the work but I have contracted (hired) the following to provide the Work indicated:

Name	Address	Phone	Type of work
------	---------	-------	--------------


X Signed [Signature]

Job Address 5641 5th

Permit No: \_\_\_\_\_

**CITY OF SACRAMENTO**  
 BUILDING INSPECTION DIVISION  
 APPLICATION FOR BUILDING PERMIT - HAZARDOUS MATERIAL SURVEY

*As Required by Assembly Bill #3205 - A Building Permit Cannot be Approved Without This Completed Form*

1. Business Name: EAST END BAKE & GRILL Phone: 452-7511  
 Site Address: 5641 J St Suite: \_\_\_\_\_  
(Street) (Zip)  
 Business Owner/Representative: Jerry Thompson Phone: 955-2734  
 Nature of Business: BAKE + RESTAURANT  
 Property Owner: Jerry Thompson Phone: 442-0983  
 Address: 1217 Front St # 23 Suite: 23  
SACRAMENTO CA. 95814  
(City) (State) (Zip)

2. Are you developing an undetermined tenant space? Yes \_\_\_ No  Is this permit for a shell building? Yes \_\_\_ No

Notify lessee of the responsibility to coordinate with the Fire Department regarding the use and handling of hazardous materials.

3. Does/Will your business generate hazardous waste? Yes \_\_\_ No

4. Does/Will your business handle, store or transport any solid, liquid, or gaseous chemicals? Yes \_\_\_ No

**CONSULT THE EPA CHEMICAL LIST LOCATED AT THE BUILDING DIVISION COUNTER FOR HAZARDOUS OR ACUTELY HAZARDOUS MATERIALS TO COMPLETE THE FOLLOWING QUESTIONS.**

If you answered "YES" to questions #3 and/or #4 above, continue on to questions 5 - 8.

5. Do you handle, store, or transport 55 gallons, 500 pounds, or 200 cubic feet (at Standard Temperature or Pressure) of a product or formulation containing hazardous materials at any one time? Yes \_\_\_ No \_\_\_

6. Do you handle, store or transport any amount of acutely hazardous materials? Yes \_\_\_ No \_\_\_

7. Is/Will your business be located within 1,000 feet of a school? Yes \_\_\_ No \_\_\_

If you answered "yes" to questions #6 and/or #7, complete the RMPP informational sheet.

8. Is/Will your business be located within 1,000 feet of a hospital, and/or long-term healthcare facility? Yes \_\_\_ No \_\_\_

IF YOU ANSWERED "YES" TO QUESTION #3 AND/OR #4, PLEASE CONTACT THE CITY OF SACRAMENTO FIRE DEPARTMENT LOCATED AT 1231 I STREET, SUITE 401, SACRAMENTO, CA OR CALL 449-5416.

**Prior to issuance of a certificate of occupancy, each business owner(s) shall contact the City of Sacramento Fire Department and comply with the Health and Safety Code regarding the use and handling of hazardous materials:**

**PENALTY:** Any business that violates Section 25531-25541 of the Health and Safety Code shall be civilly liable to the administering agency in an amount of not more than two thousand dollars (\$2,000) for each day in which the violation occurs. If the violation results in, or significantly contributes to, an emergency, including a fire, the business shall also be assessed the full cost of the city emergency response, as well as the cost of cleaning up and disposing of the hazardous materials. Additional liability and punishment may be assessed for knowing a violation after reasonable notice of the violation.

Applicant's Name: Jerry Thompson  
(Print)  
[Signature] 12-28-00  
(Signature) (Date)

BID Use Only: Plan Ck# _____	Permit # <u>0009202</u>
OK to issue prmt? <input checked="" type="checkbox"/> <u>BT/12/28/00</u> of F.D. Appr Req'd? Yes <input checked="" type="checkbox"/>	init date
Hold on Certificate of Occupancy? Yes <input checked="" type="checkbox"/> No	
Fire Dept. Use Only:	
OK to issue permit? init _____ date _____	
OK to issue Certificate of Occupancy? init _____ date _____	



# WATER SUPPLY TEST - DEPARTMENT OF UTILITIES

1395 35TH AVENUE SACRAMENTO, CA. 95822 PHONE: 916 / 264-1430 FAX: 916 / 264-1497	TEST NO:	FILE NO:
	COMPLETE DATE:	PC#
	ANALYSIS FEE: \$90.00	DATE PAID:
	FIELD TEST FEE: \$360.00	DATE PAID:
CONTACT PERSON: <b>JERRY THOMPSON</b>	PHONE NO: <b>(916) 442-0353</b>	FAX NO: <b>v</b>
COMPANY: <b>Jet Food &amp; Beverage Inc</b>	CELL PHONE NO: <b>v 955-2734</b>	
COMPANY ADDRESS: <b>v 1207 Front St</b>	STREET ADDRESS OF TEST: <b>v 5641 J St</b>	
PURPOSE OF TEST: <b>v ADDING COOLER BOX</b>	ASSESSOR'S PARCEL NUMBER: <b>v 008-0121-021</b>	

The undersigned agrees to the following items and conditions:

- (1) The street address shown above is correct.
- (2) Water supply data is developed from several sources of information which may include water supply test data, pipe network computer models, and continuous pressure recording stations. The design water supply data given below is to be used for design purposes.
- (3) Although the water supply data reported herein is believed to be accurate, the City makes no warranty, guaranty, certification or other representation of any kind that such data is accurate or correct, or that the pressures and/or flow rates reported herein can or will be maintained. The undersigned agrees that the City, its officers and employees shall not be liable for any damages of any kind resulting from the use of or reliance upon the water supply data reported herein by the undersigned or by any third party.
- (4) If the undersigned desires to witness the water supply test performed by the City, please check the box below:
  - I want to witness this water supply test, which will be scheduled at the convenience of the Department of Utilities.
- (5) If the undersigned elects to hire a licensed engineer, at the undersigned's sole expense, to witness and certify the water supply test performed by the City, please check the box below:
  - At my expense, I will arrange for a licensed engineer to witness and certify this water supply test, which will be scheduled at the convenience of the Department of Utilities.

REQUESTED BY B.J. FOSTER (B.J.)

Print Name: **v Jerry Thompson** Signature: **v**

Date: **v 12/29/00**

ASAP

ENGINEERING REQUEST DATE:	DATE OF TEST:	TIME OF TEST:								
WATER MAIN SIZE: _____ TEST CONDUCTED BY: _____										
RESIDUAL	HYDRANT NO	MAP PAGE	STATIC PRES. (PSI)	RESIDUAL PRES. (PSI)	PITOT PRES. (PSI)	OUTLET DIA. (IN.)	COEFFICIENT		CALC. FLOW @ PRES. (G.P.M.)	FLOW @ 20 PSI (G.P.M.)
							C <sub>1</sub>	C <sub>2</sub>		
RESIDUAL										
FLOWED										
FLOWED										
FLOWED										
FLOWED										

- THE WATER SUPPLY TEST DATA IS NOT TO BE USED FOR THE DESIGN OF DOMESTIC WATER SYSTEMS.
- (STATIC PRES. - RESIDUAL PRES.) / (STATIC PRES. - 20 PSI) IS LESS THAN 25%. THEREFORE, THESE RESULTS ARE ONLY VALID FOR FLOWS NOT EXCEEDING \_\_\_\_\_ G.P.M.

WATER SUPPLY DATA SUMMARY		
	ACTUAL	DESIGN (1)
STATIC PRESSURE	PSI	PSI
RESIDUAL PRESSURE	PSI	PSI
TOTAL FLOW @ RESIDUAL	G.P.M.	G.P.M.
TOTAL FLOW @ 20PSI	G.P.M.	G.P.M.

(1) The Design Water Supply Data reflects fluctuations and future demands on the water distribution system. It is to be used for design purposes.

FAXED 12/27/00 BJL

City of Sacramento  
**Water and Sewer Service Quotation**  
 FY 99/00

*FEES FOR PUBLIC WORK  
 1.5 HR ADDITIONAL*

Date: 12/26/00	Time:	Planning No:	Plan Check No.: 0009202
Address: 5641 J Street		Parcel No.: 008-0122-021	
Description: <b>Shakey's Pizza</b> Restuarant remodel			
Subdivision Map:		Water Page No.:	
Estimate By: RT			
Engineering Firm:		Project Engineer:	
		Phone No.:	
		Fax No.:	
Sewer Jurisdiction: <input type="checkbox"/> County <input type="checkbox"/> City			
Comment No. 1: Abandon an existing 1" service			
Comment No. 2: 1-1.5" service and meter (easement tap)			
Comment No. 3: Pro-rated development fee			
Comment No. 4:			
Comment No. 5:			
Comment No. 6:			
TOTAL WATER DEV FEES: <b>\$1,786</b>		14 hrs x \$75 per hour = \$1,050	
TOTAL SEWER DEV FEES: <b>\$0</b>		or \$300.00 (whichever is greater)	
		Total on-site grading and drainage review fee: <b>\$1,050</b>	

*+ 1.5 HR x 75 = 337.50*

*entire*

*entire*

*by*

**Water Service Quotations**

Main Size	Serv. Size			St. Tap	Esmt. Tap	Description	No of Tap	No. of Meter	Tap Fee/ea.	Meter Fee/ea.	Total Tap cost	Development Fees
	D	I	F									
6"	1.5"				x	service & meter	1	1	\$765	\$500	\$1,265	\$3,692
											\$0	
											\$0	
											\$0	
											\$0	
											\$0	
											\$0	
<b>4" TAP AND 3" METER</b>												
											n/a	
<b>ABANDONMENT</b>												
6"	Abandon			1	in		1				\$510	
	Abandon				in							
<b>CREDIT</b>												
6"	Credit for			1	in			1				(\$1,906)
	Credit for				in							
							0		Fire Hydrant			
<b>Total for Water</b>											<b>\$1,775</b>	<b>\$1,786</b>

**Sewer Service Quotations**

Main Size	Service Size	Description	QTY	Full St W (FT)	No. OF MH	Total Tap cost	Development Fees
		Development Fee Only				\$0	
		Easement Tap + MH + Dev. Fee				\$0	
		Street Tap + MH + Dev. Fee				\$0	
		Credit					\$0
<b>Total for Sewer</b>						<b>\$0</b>	<b>\$0</b>

Note: Total cost = Qty. x Street/2 x Tap Fee + MH Fee, MH Fee is \$1200.00

Sewer Tap Construction Charge: \$0  
 Water Main Construction Charge: \$1,775  
**Total For Address: \$1,775**

**MEMORANDUM**

**SACRAMENTO FIRE DEPARTMENT**

**TO:** BUILDING DEPARTMENT

**DATE:** 5-23-01

**FROM:** Troy Malaspino  
Fire Marshal

**SUBJECT: FIRE SYSTEM INSPECTION**

A final inspection of the newly installed fire system at:

5641 J ST

Has been conducted by Inspector

S Bidelle

On

5-23-01

00 09202911  
Permit Number

\_\_\_\_\_  
Square Footage

KIT Hood  
Type of Inspection

They system is acceptable by this department.

R. Woodman  
By: Ross L. Woodman,  
Fire Prevention Officer II

00-487  
F.D. Reference Number

# CIRCO SYSTEM BALANCE, INC.

SB JOB NO. \_\_\_\_\_  
 SECTION \_\_\_\_\_ PAGE \_\_\_\_\_  
 DATE \_\_\_\_\_

## FAN TEST SHEET

AREA SERVED Kitchen Hood #1 UNIT KeF-1

### MOTOR NAMEPLATE DATA

MFG CENTRAL FR M56H  
 HP 1.5 V 208 FLA 7.8  
 PH 1 SF 120 RPM 1725

### SHEAVE DATA

DIA 1 1/4 SHAFT 5/8  
 ADJ  %MIDFIXED

### FAN NAMEPLATE DATA

MFG CENTRI-MASTER  
 MODEL PNU-18586-1  
 TYPE UP BLAST  
 SIZE \_\_\_\_\_

### SHEAVE DATA

DIA AKS 1 SHAFT 1"  
 BELTS (1) A-27

DATA ITEM	TEST 1	TEST 2	TEST 3
VOLTS	210	210	
AMPS	6.4	6.0	
BHP	1.23	1.15	
RPM	1558	1360	
SP	.59	.51	
SP +	-	-	
TSP	.59	.51	
FILTER SP	-	-	
CFM TOTAL	3570	3316	
CFM RA	-	-	
CFM OA	-	-	

### FAN DESIGN DATA

CFM 3300 SP \_\_\_\_\_ RPM \_\_\_\_\_ BHP \_\_\_\_\_

REMARKS: FILTERS = (5) 14x10 = 8.75 SQ FT X 377 FPM = 3300 CFM (DESIGN)  
= 8.75 SQ FT X 400 FPM = 3570 (TEST 1)  
= 8.75 SQ FT X 379 FPM = 3316 (TEST 2)

Hood size 108x44 = 33 SQ FT

*John Mitchell*



CHARTER MEMBER OF ASSOCIATED AIR BALANCE COUNCIL

# CIRCO SYSTEM BALANCE, INC.

SB JOB NO. \_\_\_\_\_  
 SECTION \_\_\_\_\_ PAGE \_\_\_\_\_  
 DATE \_\_\_\_\_

## FAN TEST SHEET

AREA SERVED Kitchen Hood #2 UNIT K.E.-2

### MOTOR NAMEPLATE DATA

MFG Centrax FR M554H  
 HP 1.5 V 208 FLA 7.8  
 PH 1 SF 1.2 RPM 1725

### SHEAVE DATA

DIA 1.649 SHAFT 5/8  
 ADJ 6mm FIXED

### FAN NAMEPLATE DATA

MFG Centrax  
 MODEL PNV-10526-1  
 TYPE UPBLAST  
 SIZE \_\_\_\_\_

### SHEAVE DATA

DIA AKS1 SHAFT 1"  
 BELTS 11/A-27

DATA ITEM	TEST 1	TEST 2	TEST 3
VOLTS	210	210	
AMPS	6.9	6.4	
BHP	1.33	1.19	
RPM	1550	1382	
SP -	.88	.52	
SP +	-	-	
TSP	.88	.52	
FILTER SP	-	-	
CFM TOTAL	3605	3342	
CFM RA	-	-	
CFM OA	-	-	

### FAN DESIGN DATA

CFM \_\_\_\_\_ SP \_\_\_\_\_ RPM \_\_\_\_\_ BHP \_\_\_\_\_

REMARKS FILTERS - (5) 14X18 = 13.75 SQ FT X 377 FPM = 3300 CFM (DESIGN)  
 13.75 SQ FT X 412 FPM = 3605 CFM (TSP)  
 13.75 SQ FT X 382 FPM = 3342 CFM (TSP)

HOOD SIZE = 108X44 = 33 SQ FT

*Jean M. [Signature]*



CHARTER MEMBER OF ASSOCIATED AIR BALANCE COUNCIL