

4187 HOVNANIAN DR
PERMIT# 0616463

OMEGA PRODUCTS INTERNATIONAL, INC.
DIAMOND WALL INSULATING STUCCO SYSTEM
ICBO Report # 4004

Builder : **K. HOVNANIAN**
Project Name : **BUNGALOWS**

Lot Number: 3044 Date of Job Completion: February 16, 2007

PLASTERING CONTRACTOR:

Name: STUCCO WORKS, INC.

Address: 5900 WAREHOUSE WAY- SACRAMENTO, CALIFORNIA 95826

Telephone No: (916) 383-6667

Contractor Number of Diamond Wall System: 2175

This is to certify that the exterior coating system on the building exterior at the above address has been installed in accordance with the evaluation report specified above and the manufacturer's Inspections.

February 21, 2007
Date


Signature of authorized representative of Plastering Contractor

This installation card must be presented to the building inspector after completion of work and before final inspection.

INSULATION CERTIFICATE

4187 HOVNANIAN DR

THIS IS TO CERTIFY THAT INSULATION HAS BEEN INSTALLED IN CONFORMANCE WITH THE CURRENT ENERGY REGULATIONS, CALIFORNIA ADMINISTRATION CODE TITLE 24, STATE OF CALIFORNIA, IN THE BUILDING LOCATED AT:

PERMIT # 0616463

SITE ADDRESS 4187 HOVNANIAN LOT 44 BUNGALOWS NATOMAS CA
NUMBER CITY STATE

CEILINGS:

BLOW: MANUFACTURER GREENFIBER THICKNESS 10.3" RVALUE 38
MANUFACTURER GREENFIBER THICKNESS _____ RVALUE _____

BATTS: MANUFACTURER KNAUF THICKNESS 13" RVALUE 38
KNAUF _____ _____

EXTERIOR WALLS:

MANUFACTURER KNAUF THICKNESS 3.5" RVALUE 13
KNAUF _____ 6.25" _____ 19

FLOOR INSULATION:

MANUFACTURER KNAUF THICKNESS N/A RVALUE N/A
KNAUF _____ _____

AIR INFILTRATION:

(TITLE 24)
YES XXX NO _____

OTHER:

GENERAL CONTRACTOR K HOVNANIAN LICENSE # _____

BY: [Signature] TITLE CORPST. MANAGER DATE 4-4-07

INSULATION CONTRACTOR: WESTERN INSULATION LP LICENSE # 794484

BY: Becky Guthrie TITLE AUTH. AGENT DATE 2/26/2007
BECKY GUTHERZ

INSULATION CERTIFICATE

THIS IS TO CERTIFY THAT INSULATION HAS BEEN INSTALLED IN CONFORMANCE WITH THE CURRENT ENERGY REGULATIONS, CALIFORNIA ADMINISTRATION CODE, TITLE 24, STATE OF CALIFORNIA, IN THE BUILDING LOCATED AT:

4167 HOVNANIAN DR
 4167 HOVNANIAN DR
 SITE ADDRESS _____
 NUMBER _____ CITY NATOMAS CA STATE
 PERMIT# 0616462

CEILINGS:

BLOW:	MANUFACTURER	GREENFIBER	THICKNESS	10.3"	RVALUE	38
	MANUFACTURER	GREENFIBER	THICKNESS		RVALUE	
BATTS:	MANUFACTURER	KNAUF	THICKNESS	13"		38
		KNAUF				

EXTERIOR WALLS:

MANUFACTURER	KNAUF	THICKNESS	3.5"	RVALUE	13
	KNAUF		6.25"		19

FLOOR INSULATION:

MANUFACTURER	KNAUF	THICKNESS	N/A	RVALUE	N/A
	KNAUF				

AIR INFILTRATION: (TITLE 24)

YES XXX NO _____

OTHER: _____

GENERAL CONTRACTOR: K HOVNANIAN LICENSE # _____

BY: [Signature] TITLE CONS-MANAGER DATE 4-4-07

INSULATION CONTRACTOR: WESTERN INSULATION LP LICENSE # 794484

BY: [Signature] TITLE AUTH. AGENT DATE 2/26/2007
BECKY GUTHERZ