

CITY OF SACRAMENTO
1231 I Street, Sacramento, CA 95814

Permit No: 0510270
Insp Area: 2
Thos Bros: 317D6

Site Address: 2169 47TH AV SAC
Parcel No: 035-0141-029

Sub-Type: NOTHR
Housing (Y/N): N

CONTRACTOR

OWNER
AVILA EDILIA
2169 47TH AV
SACRAMENTO, CA 95822

ARCHITECT

Nature of Work: NEW TOOL SHED 10'X16' WITH 2 SKY LIGHTS.

CONSTRUCTION LENDING AGENCY: I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name _____ Lender's Address _____


LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class _____ License Number _____ Date _____ Contractor Signature _____

OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00);


I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

____ I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

____ I am exempt under Sec. _____ B & PC for this reason: _____
Date 07-14-05 Owner Signature 

IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and hereby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.


Date 07-14-05 Applicant/Agent Signature 

WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations:
 I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

____ I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

| Carrier | Policy Number | Exp Date |
|-------------------------------------|---------------|----------|
| <input checked="" type="checkbox"/> | | |


This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Date 07-14-05 Applicant Signature 

WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.

THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.

City of Sacramento
Development Services Department
PLANNING REVIEW FOR BUILDING PERMIT SUBMITTAL

| | |
|--|--|
| ADDRESS: 2169 47 th Avenue | APN: 035-0141-029 |
| DRPB AREA / PUD / SPD: Not Applicable | ZONING: R-1-EA-4 |
| EXISTING LAND USE: 1-story, Single Family Residence, attached garage. | |
| PROPOSED USE: Convert garage into living space and small rear addition AND 10 X 16 SHED | |
| PLANNING STAFF WILL CHECK ONE OR MORE OF THE ITEMS BELOW: | |
| <input type="checkbox"/> | Planning review is NOT required. |
| <input type="checkbox"/> | Use is NOT allowed; applicant CANNOT submit for plan check. |
| <input type="checkbox"/> | Requires APPLICATION(s): PC ZA IR ER DR PB Required Planning application must be approved <i>before</i> project can be submitted for plan check |
| <input type="checkbox"/> | Application(s) IN PROGRESS: File Number: Application must be approved before project can be submitted for plan check. |
| <input type="checkbox"/> | Application(s) COMPLETED: File Number & approval date: Building permit must conform to approved plans and comply with all conditions of approval. Do NOT accept applications for a building permit prior to the end of the 10-day appeal period. |
| <input checked="" type="checkbox"/> | Plans may be submitted for plan check. Plan checker(s) shall confirm compliance with Zoning Ordinance requirements and all applicable development standards <i>prior to issuance</i> of building permit. |
| <input checked="" type="checkbox"/> | Meets setback & lot coverage requirements as shown on site plan provided. |
| <input checked="" type="checkbox"/> | Site Plans to be submitted have been stamped/signed by Planning counter staff. |
| <input type="checkbox"/> | Route to SITE for plan check and inspection. |
| <input type="checkbox"/> | Route to SITE for inspection only, plan check not required. |
| <input type="checkbox"/> | Preliminary review ONLY; the information on this form must be reviewed again and confirmed at the time of building permit submittal. |
| CONDITIONS AND COMMENTS: Meets all applicable setbacks and lot coverage on the stamped site plan. Lot at least 6490 sq ft. Footprint of all covered structures after rear addition will be less than 1780 sq ft. Lot coverage less than 27% (of the maximum 40% R-1 zone). Setbacks okay, addition must be at least 5' from the sides and 15' from rear. Garage conversion okay without Variance. Garage is recessed and applicant has fully paved driveway to use as parking pad. The driveway is over 45' long from the street and 16' wide. Applicant has the required 10' x 20' parking pad outside the front setback. SHED MUST BE A MIN. 4' FROM SFR AND SITE PLAN SHOWS 5'. DOES NOT EXCEED 33% LOT COVERAGE OF REAR SETBACK WALL HEIGHT DOES NOT EXCEED 10' AND OVERALL HEIGHT DOES NOT EXCEED 18'. <i>No other planning issues apparent.</i> | |
| DATE: 21 June 2005 / 07-13-2005 | BY: Robert W. Williams/PCALDWELL  |