

BUILDING DIVISION—BUILDING INSPECTOR'S REPORT CARD

TYPE VII BUILDINGS

PERMIT NO. <i>1204</i>	LOCATION <i>4101 1/2</i>
DATE	PURPOSE <i>Private Garage</i>
ISSUED SEP 10 1927 SACRAMENTO BUILDING DIVISION	ROOMS
	APTS.
OWNER <i>J. E. Foster</i>	PHONE
ARCHT	
CONTR	
VAL. <i>70 -</i>	STORIES
	SIZE

FOUNDATION	STORY	BSMT	1	2	3	ROOF		
Ex Wall	Joists						Chimneys	Cement Tests
	Beams and Girders						Fire Place	
Int Wall	Studs and Columns						Gas Water Heater	
	Bridging Fire Stops						Heater Closet	
Piers	Fire Escape Stand Pipes						Furnace	Window Courts
	Metal Lath						Boiler Room	
	Stairs						Elevator Shaft	

DATE	CONDITION OF WORK—REMARKS
9/19/27.	Put up Notice for Owner to Take out Permit. A.W. Campbell
9/20/27	Nobody on job. Garage does not comply with Bldg Code. West Wall built with Cor Iron 18" from line and East Wall rustic less than 6 ft from house. A.W. Campbell
11/24/27	5 th Floor - Owner put brick Wall on both on base side and side wall. Work done by M.L. Brown
10/20/27	4 th Floor - Garage completed except painting. Work done by M.L. Brown. A.W. Campbell
10/20/27	COMPLETED AND O. K. A.W. Campbell
	Inspector