

CITY OF SACRAMENTO
1231 I Street, Sacramento, CA 95814

Permit No: 0010976
Insp Area: 2

Site Address: 7773 LARAMORE WY SAC
Parcel No: 053-0016-002 MEADOWVIEW VIL.-7 LOT 2

Sub-Type: NSFR
Housing (Y/N): N

CONTRACTOR
NEW FAZE DEVELOPMENT
2377 GOLD MEADOW WY STE.270
GOLD RIVER CA. 95670

OWNER

ARCHITECT

Nature of Work: NSFR MP1624 8 RMS 2 STORY

CONSTRUCTION LENDING AGENCY : I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name FARMERS MERCH Lender's Address ELK GROVE, CA

LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class B License Number 714601 Date _____ Contractor Signature [Signature]

OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00):

____ I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

____ I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

____ I am exempt under Sec. _____ B & PC for this reason: _____

Date _____ Owner Signature _____

IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and hereby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

Date 10/18/00 Applicant/Agent Signature [Signature]

WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations:

____ I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier STATE OCT FIDELITY Policy Number 153696-99 Exp Date 11-01-00

____ (This section need not be completed if \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person who is not subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Date 10/18/00 Applicant Signature [Signature]

WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.

THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.




WesPac

insulation

a MASCO Company

809 North Market Blvd., Ste. 11 • Sacramento, CA 95834
(916) 927-7149 • Fax (916) 927-4257
Lic. #487478



Installed Insulation Certificate

We certify that the building insulation listed herein is installed in conformance with current energy conservation regulations, California Administrative Code, Title 24, State of California

REFLECTOR	AREA	TYPE	INCHES/BAGS (BLOWN)
R38	Attic	Blown	12
R38	Basement	Blown	12
R13	Walls	Blown	12

Insulation installed on 01/24/01

Devin K. Tubbs

Certified by

8414-001 SPRINGS
1111 KATHRON SPRINGS

Address or Lot Number

Title Secretary

01/24/01

Phase #

Date Installed



BASALITE®

PACIFIC STUCCO SYSTEMS

4290 Roseville Road
North Highlands, CA 95660-5710
(916) 486-4094
Fax (916) 486-4187

**Installation Card
Fiber Reinforced Stucco**

Job Name and Address: New Phase Development

ICBO# 5269

Rainbow Spring Lot - 2

Date of job completion

Sacramento, CA

Plastering Contractor

Name: G. Glenn Plastering

Address 6330 Main Ave. Suite 4, Orangevale, CA 95662

Telephone No (916) 989-8727

Approved contractor as issued by Basalite/Pacific Stucco

This is to certify the exterior coating system at the above address, has been installed in accordance with the evaluation report specified above and the manufacturers instructions.

Glenn Glenn

Signature of authorized representative of plastering contractor

Date

This installation card must be presented to the building inspector after completion of work and before final inspection.

CONSOLIDATED ENGINEERING LABORATORIES
CONCRETE, REINFORCING, POST-TENSIONING

Project Name: RAINBOW SPRINGS
Project Address: _____
Type of Work: P/T

Date: 1/6/01 Project No.: 51737
Inspector: DAVID ROBBINS
 Sampling Inspection

- 1 Checked materials and operations at batch plant.
- 2 Visually checked loads for proper slump.
- 3 Obtained grab sample of cement.
- 4 Inspected precast operations at: _____
- 5 Reported to: Chris at jobsite.
- 6 Inspected rebar placement for: _____
- 7 Inspected placement of: a. Anchor Bolts, b. Holddowns, c. Tiedowns for: _____
- 8 Monitored loads arriving at jobsite for correct mix and proper slump.
- 9 Inspected jobsite placing and vibrating of _____ cubic yards of concrete.
- 10 Performed air entrainment test: a. tests
- 11 Performed unit wt test: a. tests
- 12 Performed slump test: a. tests
- 13 Cast one set: a. _____ sets of cylinders b. _____ and one set of shrinkage beams, and c. _____ sets of shrinkage beams representing Concrete Mix No. _____ placed at: _____

- NOTE:** Take specimens from any loads suspected as being out of specification due to high slump, overtime mixing, etc.
- 14 Returned to plant for duration of pour.
 - 15 Checked ram and gauge calibration. (PT)
 - 16 Inspected stressing operations; elongation for LOTS 1 THROUGH 8
 - 17 Elongations were within specified limits. a. with the following exceptions: _____
 - 18 Job cancelled due to _____
 - 19 Work inspected was in compliance with approved plans and specifications: a. except as noted
 - 20 per approved drawings no. PT-1
 - 21 Non-Compliance Report left at jobsite. (Lab copy attached.)
 - 22 _____ hours spent performing reinspection.
- Unusual circumstances or problems? No Yes
*Describe below. Notified Chris
at jobsite and _____ at CEL

Handwritten: FILE IN FILE

NOTES/COMMENTS: Continued on back of page
ALL LOTS HAVE #4 HAIRPINS INSTALLED AT APPROX. 1/4 IN STRIPS.

