

CITY OF SACRAMENTO
1231 I Street, Sacramento, CA 95814

Permit No: 9909703
Insp Area: 4

Site Address: 1097 SONOMA AV SAC
Parcel No 265-0021-019

Sub-Type: RES
Housing (Y/N): Y

CONTRACTOR

OWNER
EUBANKS JERRY
1731 POPE AV
SIMI VALLEY CA 93065

ARCHITECT

Nature of Work: Repair per housing check list.

CONSTRUCTION LENDING AGENCY : I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name _____ Lender's Address _____

LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class _____ License Number _____ Date _____ Contractor Signature _____

OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code: any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00).

I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

I am exempt under Sec. _____ B & PC for this reason: _____

Date _____ Owner Signature _____

IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and hereby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

Date 8-30-99 Applicant/Agent Signature Susan Vary

WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations:

I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier _____ Policy Number _____ Exp Date _____

(This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Date 8-30-99 Applicant Signature Susan Vary

WARNING: FAILURE TO SECURE WORKERS' COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.

THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.

Housing/Dangerous Bldgs Division
Case Field Check List

Case # **HSG9900044**

99-09703H

Address: **1097 SONOMA AV**

Location: THE SOUTH 115 OF THE EAST 40 FEET O

<u>Date</u>	<u>Description</u>
01/26/99	49.04.402(A) Attractive Nuisance. Vacant structure & Sub Standard Structure.
01/25/99	49.10.1008(30) Defective or lack of weather protection for exterior walls including lack of paint or weathering due to lack of paint or other approved protective covering. WEATHERED AND MISSING SHINGLES, WATERPROOF MEMBRANE DAMAGED, DRYROT, LACK OF PAINT
01/26/99	Design Review requirements required.
01/26/99	49.07.702 Unsafe electrical service equipment.
01/25/99	49.10.1005 Faulty equipment or wiring presenting a hazard to person or property. FAILED ELECTRICAL RACEWAYS AT REAR OF BUILDING
01/26/99	49.07.702 Improper or inadequate grounding or bonding of equipment or items requiring same.
01/26/99	49.07.701 Provide approved type and installation of room heater which will maintain a temperature of 70 degrees three(3) feet above the floor.
01/26/99	49.05.521 Provide replacement of deteriorated plumbing fixtures with approved type.

Housing/Dangerous Bldgs Division
Case Field Check List

Case # **HSG9900044**

Address: **1097 SONOMA AV**

Location: THE SOUTH 115 OF THE EAST 40 FEET O

<u>Date</u>	<u>Description</u>
01/26/99	49.05.521 Provide approved P-traps for all plumbing fixtures.
01/26/99	49.10.1007 All gas appliances shall be approved type and installed in an approved manner.