

**CITY OF SACRAMENTO**  
1231 I Street, Sacramento, CA 95814

**Permit No: 0317298**

**Insp Area: 4**

**Thos Bros:**

**Sub-Type: NCOM**

**N**

**Site Address: 4110 TRUXEL RD SAC**

**Parcel No:**

**Housing (Y/N):**

**CONTRACTOR**

PANATTONI CONSTRUCTION INC  
8745 FOLSOM BL  
SAC CA 95826

**OWNER**

PANATTONI DEVELOPMENT COMPANY  
8401 JACKSON RD.  
SACTO, CA 95826

**ARCHITECT**

**Nature of Work: SHELL BLDG. F, 12,496 SF**

**CONSTRUCTION LENDING AGENCY :** I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name \_\_\_\_\_ Lender's Address \_\_\_\_\_

**LICENSED CONTRACTORS DECLARATION:** I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class B License Number 759899 Date 3/11/04 Contractor Signature Red Golden

**OWNER-BUILDER DECLARATION:** I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00);

\_\_\_\_\_, I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

\_\_\_\_\_, I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

\_\_\_\_\_, I am exempt under Sec. \_\_\_\_\_ B & PC for this reason: \_\_\_\_\_

Date \_\_\_\_\_ Owner Signature \_\_\_\_\_

**PAID**  
**CITY OF SACRAMENTO**  
**MAR 11 2004**  
**NORTH PERMIT**

**IN ISSUING THIS BUILDING PERMIT,** the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and herby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

Date 3/11/04 Applicant/Agent Signature Red Golden

**WORKER'S COMPENSATION DECLARATION:** I hereby affirm under penalty of perjury one of the following declarations:

\_\_\_\_\_, I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier STATE COMPENSATION INS FUND Policy Number 713-6577-002 Exp Date 10/01/2003

\_\_\_\_\_, (This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Date 3/11/04 Applicant Signature Red Golden

**WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.**

**THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.**

# ATM Engineering

LETTER

2941 Sunrise Boulevard, Suite 105  
Rancho Cordova, CA 95742  
Phone: 916-859-7300  
Fax: 916-859-7304  
E-mail: atm@atmengineering.com

Timothy W. McPartland, SE3826  
Amy Dale McPartland, CE46742

September 16, 2004

David Estrada  
Panattoni Construction  
8745 Folsom Blvd, Ste 150  
Sacramento, CA 95826

Re: Natomas Crossing Buildings Addresses 4110, 4150, 4180, 4130, 4170, 4190 Truxel Road

Dear David:

I am writing to confirm that there is no high strength bolting on the referenced buildings and therefore no required special inspection of such.


If you have any questions or comments regarding this, please call.


Sincerely,



Tim McPartland, SE

Microfilm





September 7, 2004

Panattoni Construction, Inc.  
Attention: Rod Gover  
8745 Folsom Boulevard, Suite 150  
Sacramento, CA 95826

Microfilm

**FINAL REPORT**  
**CONSTRUCTION OBSERVATION AND TESTING SERVICES**  
**NATOMAS CROSSING - BUILDINGS A THROUGH F**  
4110 4130, 4150, 4170, 4180 and 4190 Truxel Road  
Sacramento, California  
Reference No. 192-197.01  
Permit Nos. 0312955, 0317296, 0311317, 0317297, 0311314, 0317298

In accordance with your request, our firm has completed construction observation and testing services during building pad, foundation, floor slab, wall panel, welding and epoxy construction for the subject buildings. During construction, our firm performed *Special Inspection and Testing* in accordance with Sections 106 and 1701 of the Uniform Building Code. Our subject construction observations and testing were performed between October 15, 2003 and August 2, 2004. Our firm prepared a Geotechnical Investigation Report for the project dated January 16, 2003.<sup>1</sup> A summary letter addressing building pad construction was prepared on February 3, 2004 and a letter summarizing buildings J, K and L was prepared on March 22, 2004.<sup>23</sup> This letter summarizes the results of our subsequent construction observation and testing.

Our observation and test results indicate that the following items for the referenced buildings were constructed, to the best of our knowledge, in accordance with the project plans, specifications, and our referenced report.

Earthwork: Observed and tested:  
1) Building pads, including chemical treatment  
2) Foundation excavations

Reinforcing Steel: Verified placement of reinforcing steel for:  
1) Foundations

<sup>1</sup> Raney Geotechnical Inc.; "Geotechnical Investigation, Natomas Crossing -- Allegheny Area 2, Truxel Road and Arena Boulevard, Sacramento, California"; Job No. 192-197; January 16, 2003.

<sup>2</sup> Raney Geotechnical Inc.; "Final Report, Construction Observation and Testing Services, Building Pads, Foundations and Floor Slabs, Natomas Crossing -- Buildings J, K and L. 4010, 4030 and 4050 Truxel Road, Sacramento, California"; Reference No. 192-197.01; February 3, 2004.

<sup>3</sup> Raney Geotechnical Inc.; "Final Report, Construction Observation and Testing Services, , Natomas Crossing -- Buildings J, K and L. 4010, 4030 and 4050 Truxel Road, Sacramento, California"; Reference No. 192-197.01; March 22, 2004.