

BUILDING DIVISION-BUILDING INSPECTOR'S REPORT CARD

TYPE BUILDINGS

PERMIT NO. 8996	LOCATION S-Q R 20-21	2031 R St.
DATE 12/1/31	PURPOSE 1-5TY BRICK	Storage Bld Adm PHONES
ZONE In Com	OWNER Valley 2nd Groceries	
	ARCH'T J Schlenker	
	CONT-R <input checked="" type="checkbox"/>	

VAL. 9500-	STORIES 1	ROOMS	APTS.	SIZE 80x160-25
-------------------	------------------	-------	-------	-----------------------

Light Shafts		Elevator Shafts	
Vent Shafts		Boiler Rooms	
Owner's Inspector		Sprinkler System	
Lath		Gas Vents	
Fire Escapes		Chimneys	
Stand Pipes		Skylights	

DATE	CONDITION OF WORK—REMARKS
2/2/32	1 ST /N.S.P. FOOTINGS FOR EXT BRICK WALLS ^{OK} A.W. Campbell
2/2/32	6th Sample of Concrete Mix. A.W. Campbell
2/15/32	2 ND /N.S.P. (PARTIAL) Bricklayers now getting ready to lay exterior brick 8" walls with plaster's center posts up. ^{OK} A.W. Campbell
2/3/32	6th Sample of Concrete Mix. Result 2770 lbs per Sq. Inch.
2/6/32	Tested " " (35 days)
3/9/32	2 ND /N.S.P. Bal. of Frame. Roof in Place. ^{OK} A.W. Campbell.
3/22/32	4 TH /N.S.P. BRICK WAREHOUSE COMPLETED ^{OK} A.W. Campbell
	ISSUED CERTIFICATE OF OCCUPANCY # 8996
3/22/32	COMPLETE AND O. K. <i>Arthur W. Campbell</i> INSPECTOR