



CITY OF SACRAMENTO

CITY MANAGER'S OFFICE  
**RECEIVED**  
NOV 5 1980

DEPARTMENT OF ENGINEERING  
915 I STREET SACRAMENTO, CALIFORNIA 95814  
CITY HALL ROOM 207 TELEPHONE (916) 449-5281

R. H. PARKER  
CITY ENGINEER  
J. F. VAROZZA  
ASSISTANT CITY ENGINEER

November 4, 1980

City Council  
Sacramento, California

Honorable Members in Session:

SUBJECT: Replacement of Drainage Line From Ellen Street to  
Manhole in Glenrose Avenue

SUMMARY:

Attached is a report recommending that approval be given for financing the replacement of a drainage line from Ellen Street to a manhole in Glenrose Avenue. The Budget and Finance Committee approved the staff recommendation on November 3, 1980.

RECOMMENDATION:

It is recommended that the City Council approve the financing for the subject project.

Respectfully submitted,

R. H. PARKER  
City Engineer

Recommendation Approved:

Walter J. Slupe, City Manager

APPROVED  
BY THE CITY COUNCIL

NOV 12 1980

OFFICE OF THE  
CITY CLERK

November 12, 1980  
District No. 2

6



# CITY OF SACRAMENTO

DEPARTMENT OF ENGINEERING  
915 I STREET SACRAMENTO, CALIFORNIA 95814  
CITY HALL ROOM 207 TELEPHONE (916) 449-5281

F/Ref.  
C.C.8738

R. H. PARKER  
CITY ENGINEER  
J. F. VAROZZA  
ASSISTANT CITY ENGINEER

October 23, 1980

Budget and Finance Committee  
Sacramento, California

Honorable Members in Session:

SUBJECT: Replacement of Drainage Line from Ellen Street  
to Manhole in Glenrose Avenue

SUMMARY:

This report recommends that approval be given for financing the replacement of a Drainage Line from Ellen Street to a Manhole in Glenrose Avenue. (See attached map.)

BACKGROUND:

The existing 10" concrete drain line in Ellen Street, according to Maintenance Personnel, has deteriorated to the extent that flooding is caused on Ellen Street. Water flows out of the outlet of the existing pipe into an unimproved roadside area causing further flooding. High maintenance costs are encountered in attempting to keep this deteriorating system functioning.

It is recommended that the deteriorated 10" drain line be replaced with a new 12" Reinforced Concrete Pipe, and that this new drain pipe be connected to an existing manhole in Glenrose Avenue to resolve this flooding problem.

FINANCIAL DATA:

It is estimated the project will cost approximately \$40,000.00. It is proposed that funding be provided from the Sewer Fund Balance. An appropriation of funds will be requested upon receipt of bids.

RECOMMENDATION:

Staff recommends that the Budget and Finance Committee recommend to the full City Council that financing be approved for the subject project from the Sewer Fund Balance.

Respectfully submitted,

R. H. PARKER  
City Engineer

Recommendation Approved:

Jack Crist, Finance Director

# PROPOSED DRAIN LINE - ELLEN ST.

LOCATION MAP

