

BUILDING DIVISION-BUILDING INSPECTOR'S REPORT CARD

TYPE BUILDINGS

PERMIT NO. <i>B-27710</i>	LOCATION <i>5421. Dur street.</i>
DATE <i>1-27-50.</i>	PURPOSE <i>Erect duplex & garage</i>
ZONE	OWNER <i>C. E. De Cuba</i>
	ARCH'T.
	CON'T R. <i>Owner</i>

VAL. <i>\$ 8000</i>	STORIES	ROOMS	APTS.	SIZE
---------------------	---------	-------	-------	------

LIGHT SHAFTS		ELEVATOR SHAFTS	
VENT SHAFTS		BOILER ROOMS	
OWNER'S INSPECTOR		SPRINKLER SYSTEM	
LATH		GAS VENTS	
FIRE ESCAPES		CHIMNEYS	
STAND PIPES		SKYLIGHTS	

DATE	CONDITION OF WORK-REMARKS
2/8/50	Forms Insp. H.E. Jones
3/20/50	Frame " " " "
6-21-50	Final " (5420 Q st) M.A.S.
	vents in garage too small and attic
	door not 1 br
	<p data-bbox="338 1060 491 1106">COMPLETE AND O. K.</p> <p data-bbox="1328 1081 1491 1106">INSPECTOR</p>