

BUILDING DIVISION-BUILDING INSPECTOR'S REPORT CARD

TYPE BUILDINGS

PERMIT No. 2429-A	LOCATION 4632 - Q Street -
DATE 10/11/34	PURPOSE To make repairs to roof damage
ZONE	OWNER Smith!
	ARCH'T
	CONT'R J. F. Saunders -
VAL. 212⁰⁰	STORIES
	ROOMS
	APTS.
	SIZE

Light Shafts		Elevator Shafts	
Vent Shafts		Boiler Rooms	
Owner's Inspector		Sprinkler System	
Lath		Gas Vents	
Fire Escapes		Chimneys	
Stand Pipes		Skylights	

DATE	CONDITION OF WORK-REMARKS
10/12/34	Made inspection of Repairs to Dry, on acct
10/21/34	<p>of Damage by Termites. It was necessary to replace sills, plates, ends of floor joists and corner studs & attic plates. All defective materials replaced with new and crossed and also treated with Sodium of Arsenite. Floor and Hardwood Floors relayed: Also repairs made to ramped floor</p>
10/30/34	<p>COMPLETE AND O. K. <i>Allen H. Campbell</i> INSPECTOR</p>