

CITY OF SACRAMENTO
1231 I Street, Sacramento, CA 95814

Permit No: 0405289
Insp Area: 4
Thos Bros: 256J3

Site Address: 2642 SAN MARIN LN SAC
Parcel No: 201-0910-018
N

Sub-Type: NSFR
HERITAGE @ NATOMAS PARK VIL. 6 LOT #76 Housing (Y/N):

CONTRACTOR
LENNAR RENAISSANCE INC
1075 CREEKSIDE RIDGE DR
ROSEVILLE, CA 95678

OWNER

ARCHITECT

Nature of Work: MP1143 1 STORY 6 ROOM SFR

CONSTRUCTION LENDING AGENCY : I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name _____ Lender's Address _____

LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class _____ License Number 732348 Date 5/20/04 Contractor Signature Kir Mas

OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00);

_____, I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

_____, I, as owner of the property, am exclusively contracting with licensed contractors to construct the project. (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

_____, I am exempt under Sec. _____ B & PC for this reason: _____
Date _____ Owner Signature _____

PAID
CITY OF SACRAMENTO
MAY 20 2004
NORTH PERMIT
CENTER

IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and hereby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

Date 5/20/04 Applicant/Agent Signature Kir Mas

WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations:

_____, I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

_____, I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier OLD REPUBLIC INS. CO. Policy Number MWC10845400 Exp Date 11/01/2004

_____, (This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.


Date 5/20/04 Applicant Signature Kir Mas

WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.

THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.

75
PAD=24.0

77
PAD=24.9



This set of plans and specifications must be kept on the lot at all times and it is unlawful to remove any portion of these plans from the lot without the approval of the City of Roseville.

DIMENSIONS SHOWN ARE APPROXIMATE EXCEPT FOR MINIMUMS REQUIRED BY ORDINANCE. THIS PLOT DOES NOT REFLECT AS BUILT CONDITIONS AND MAY VARY FROM THIS PLAN.

RENAISSANCE HOMES

1075 CREEKSIDE RIDGE DR. SUITE 100. ROSEVILLE, CA. 95678
PHONE (916) 773-4083 FAX (916) 773-4086

MENDOCINO
HERITAGE PARK
VILLAGE 6
SACTO. COUNTY, CALIFORNIA

PLOT PLAN
NOTES:

ADDRESS: 2642 SAN MARIN LANE

LOT COV: 43.7 %

PLAN NO.: 1143-A LOT SQ. FT.: 4,941.8

ROOF PITCH: A & B ELEVS.= 4/12 PITCH
C ELEV.= 7/12 PITCH

DRAWN BY: R.P. APPROVED BY: MB

DATE: 2/10/04

SCALE: 1"=20'

LOT 76



**INSULATION CONTRACTORS
ASSOCIATION
OF AMERICA**

INSULATION
CERTIFICATE

47652

1321 DUKE STREET, SUITE 303 • ALEXANDRIA, VA 22314 • (703) 739-0356

THIS IS TO CERTIFY THAT INSULATION HAS BEEN INSTALLED IN CONFORMANCE WITH CURRENT ENERGY REGULATIONS, CALIFORNIA ADMINISTRATIVE CODE, TITLE 24, STATE OF CALIFORNIA, IN THE BUILDING LOCATED AT:

Remittance LOT # 76 TRACT # Meridian

STREET 21650 Pinnacle CITY Sacramento

EXTERIOR WALLS:

MANUFACTURER KS THICKNESS/TYPE 2 1/2" R-VALUE 13

CEILINGS:

BATTS: MANUFACTURER KS THICKNESS/TYPE 1 1/2" R-VALUE 38

BLOWN IN: MANUFACTURER 21650 Pinnacle MINIMUM THICKNESS 14 3/4" R-VALUE 38

SQUARE FOOTAGE COVERED 632 NUMBER OF BAGS USED 37

FLOORS:

MANUFACTURER _____ THICKNESS/TYPE _____ R-VALUE _____

SLAB ON GRADE: MANUFACTURER _____ THICKNESS/TYPE _____ R-VALUE _____

MANUFACTURER _____ THICKNESS/TYPE _____ R-VALUE _____

WIDTH OF INSULATION _____ INCHES

FOUNDATION WALLS: MANUFACTURER _____ THICKNESS/TYPE _____ R-VALUE _____

GENERAL CONTRACTOR _____ DATE _____
CALIFORNIA CONTRACTORS LICENSE # _____

INSULATION CONTRACTOR **ARCADE INSULATION** TITLE _____
CALIFORNIA CONTRACTORS LICENSE #815286
NEVADA CONTRACTORS LICENSE #55201

Carolee J. Taylor DATE 10/6/04
SIGNATURE TITLE

KwikKote

No. 200-920972

Stucco System Installation Card

Job Name: MENDOCINO COLLECTION
Address: 2636 SAN MARIN LANE
SACRAMENTO, CA
Lot #: 00075-6

Stucco System Trade Name: KWIK KOTE
Stucco System Manufacturer: KWIK KOTE CORP.

ICBO Evaluation Service, Inc.
Report No. 3607
Date of Job Completion:

Home Builder: LENNAR RENAISSANCE
Address: 1075 Creekside Ridge Dr. #100
ROSEVILLE, CA


Stucco Contractor: KENYON PLASTERING, INC.
Address: PO BOX 2077
North Highlands, CA

Telephone Number: 916/349-8191

Approved Contractor Number as
issued by the Stucco Manufacturer: 1001

Card Print Date: 05/14/2004

This is to certify that the stucco system on the building exterior at the above address had been installed in accordance with the evaluation report specified above and the manufacturer's instructions.


Signature of authorized representative of stucco contractor

10-8-04
Date

RENAISSANCE HOMES: HERITAGE PARK (MENDOCINO)

Site Address

2636 San Martin Lane

Permit Number

0405307

An installation certificate is required to be posted at the building site or made available for all appropriate inspections. (The information provided on this form is required; however, use of this form to provide the information is optional.) After completion of final inspection a copy must be provided to the building department (upon request) and the building owner at occupancy, per Section 10-103(b).

HVAC SYSTEMS:

Heating Equipment

Equip. Type (pkg. Heat pump)	CEC Certified Mfr name and Model #	# of Identical Systems	(1) Efficiency (AFUE, etc.) > CF-1R value	Duct Location (attic, etc.)	Duct or Piping R-value	Heating Load (Btu/hr)	Heating Capacity (Btu/hr)	
Furnace	CARRIER #58MVP040-14	1	94%	Attic	R-6	22,532	40,000	PLAN 1141
Furnace	CARRIER #58MVP040-14	1	94%	Attic	R-6	25,020	40,000	PLAN 1142
Furnace	CARRIER #58MVP040-14	1	94%	Attic	R-6	25,595	40,000	PLAN 1143
Furnace	CARRIER #58MVP040-14	1	94%	Attic	R-6	30,198	40,000	PLAN 1144

Cooling Equipment

Equip. Type (pkg. Heat pump)	CEC Certified Compressor Unit Mfr Name and Model #	# of Identical Systems	(1) Efficiency (SEER, etc.) > CF-1R value	Duct Location (attic, etc.)	Duct R-value	Cooling Load (Btu/hr)	Cooling Capacity (Btu/hr)	
A/C	CARRIER #38TDB036 *	1	16	Attic	R-6	22,053	36,000	PLAN 1141
A/C	CARRIER #38TDB036 *	1	16	Attic	R-6	23,238	36,000	PLAN 1142
A/C	CARRIER #38TDB036 *	1	16	Attic	R-6	23,151	36,000	PLAN 1143
A/C	CARRIER #38TDB036 *	1	16	Attic	R-6	26,728	36,000	PLAN 1144

(1) > reads greater than or equal to. * = TXV installed with coil

I, the undersigned, verify that equipment listed above is: 1) is the actual equipment installed, 2) equivalent to or more efficient than that specified in the certificate of compliance (Form CF-1R) submitted for compliance with the Energy Efficiency Standards for residential buildings, and 3) equipment that meets or exceeds the appropriate requirements for manufactured devices (from the Appliance Efficiency Regulations or Part 6), where applicable.

[Signature]
Signature, Date

Beutler Corporation

Installing Subcontractor (Co. Name)
OR General Contractor (Co. Name) OR Owner

WATER HEATING SYSTEMS:

Heater Type	CEC Certified Mfr Name & Model #	Distribution Type (Std. point of use)	If Recirculation Control Type	# of Identical Systems	(2) Rated Input (kW or Btu/hr)	Tank Volume (gallons)	(2) Efficiency (EF,RE)	(2) Standby Loss (%)	External Insulation R-value
GAS	RHEEM 41V60-40TF	STD	N/A	N/A	40,000	50			19.2

- (2) For small gas storage (rated input of less than or equal to 75,000 Btu/hr), electric resistance and heat pump water heaters, list Energy Factor. For large gas storage water heaters (rated input of greater than 75,000 Btu/hr), list Recovery Efficiency, Standby Loss and Rated Input. For instantaneous gas water heaters, list Recovery efficiency and Rated Input.
- (3) R-12 external insulation is mandatory for storage water heaters with an energy factor of less than 0.58.

Facets & Shower Heads:


All facets and showerheads installed are certified to the Commission, pursuant to Title 24, Part 6, Section 111.

I, the undersigned, verify that equipment listed above by signature is: 1) the actual equipment installed; 2) equivalent to or more efficient than that specified in the certificate of compliance (Form CF-1R) submitted for compliance with the Energy Efficiency Standards for residential buildings; and 3) equipment that meets or exceeds the appropriate requirements for manufactured devices (from the Appliance Efficiency Regulations or Part 6), where applicable.

[Signature]
Signature, Date

BEUTLER CORP. RENAISSANCE HOMES
Installing Subcontractor (Co. Name)
OR General Contractor (Co. Name) OR Owner

COPY TO: Building Department
HERS Provider (if applicable)
Building Owner at Occupancy



**INSULATION CONTRACTORS
ASSOCIATION
OF AMERICA**

INSULATION
CERTIFICATE

47651

1321 DUKE STREET, SUITE 303 • ALEXANDRIA, VA 22314 • (703) 739-0356

THIS IS TO CERTIFY THAT INSULATION HAS BEEN INSTALLED IN CONFORMANCE WITH CURRENT ENERGY REGULATIONS. CALIFORNIA ADMINIS TRATIVE CODE TITLE 26, CHAPTER 10, CALIFORNIA, IN THE BUILDING LOCATED AT:

Remediation LOT # 76 TRACT # Mendocino
2642 San Pablo City Sausalito

EXTERIOR WALLS: R- VALUE 13
MANUFACTURER AC THICKNESS/TYPE 3/2

CEILINGS: R- VALUE 38
BATT: 12 THICKNESS/TYPE
MANUFACTURER R- VALUE 38
BLOWN IN: 4 3/4 MINIMUM THICKNESS
MANUFACTURER 364

SQUARE FOOTAGE COVERED 1476 NUMBER OF BAGS USED
FLOORS: R- VALUE
MANUFACTURER THICKNESS/TYPE
SLAB ON GRADE: R- VALUE
MANUFACTURER THICKNESS/TYPE

WIDTH OF INSULATION _____ INCHES R- VALUE
FOUNDATION WALLS: R- VALUE
MANUFACTURER THICKNESS/TYPE

GENERAL CONTRACTOR _____ DATE
CALIFORNIA CONTRACTORS LICENSE # _____

SIGNATURE _____ TITLE

INSULATION CONTRACTOR **ARCADE INSULATION**
CALIFORNIA CONTRACTORS LICENSE #815286
NEVADA CONTRACTORS LICENSE #55201

Signature: *[Handwritten Signature]* TITLE

KwikKote

No. 200-920971

Stucco System Installation Card

Job Name: MENDOCINO COLLECTION
Address: 2642 SAN MARIN LANE
SACRAMENTO, CA
Lot #: 00076-6

Stucco System Trade Name: KWIK KOTE
Stucco System Manufacturer: KWIK KOTE CORP.

ICBO Evaluation Service, Inc.
Report No. 3607
Date of Job Completion:

Home Builder: LENNAR RENAISSANCE
Address: 1075 Creekside Ridge Dr. #100
ROSEVILLE, CA


Stucco Contractor: KENYON PLASTERING, INC.
Address: PO BOX 2077
North Highlands, CA

Telephone Number: 916/349-8191

Approved Contractor Number as
issued by the Stucco Manufacturer: 1001

Card Print Date: 05/14/2004

This is to certify that the stucco system on the building exterior at the above address had been installed in accordance with the evaluation report specified above and the manufacturer's instructions.


Signature of authorized representative of stucco contractor

10-8-04
Date

INSTALLATION CERTIFICATE

RENAISSANCE HOMES: HERITAGE PARK (MENDOCINO)

Permit Number

0405289

Site Address

2642 San Martin Lane

An installation certificate is required to be posted at the building site or made available for all appropriate inspections. (The information provided on this form is required; however, use of this form to provide the information is optional.) After completion of final inspection a copy must be provided to the building department (upon request) and the building owner at occupancy, per Section 10-103(b).

HVAC SYSTEMS:

Heating Equipment

Equip. Type (pkg. Heat pump)	CEC Certified Mfr name and Model #	# of Identical Systems	(1) Efficiency (AFUE, etc.) > CF-1R value	Duct Location (attic, etc.)	Duct or Piping R-value	Heating Load (Btu/hr)	Heating Capacity (Btu/hr)	
Furnace	CARRIER #58MVP040-14	1	94%	Attic	R-6	22,532	40,000	PLAN 1141
Furnace	CARRIER #58MVP040-14	1	94%	Attic	R-6	25,020	40,000	PLAN 1142
Furnace	CARRIER #58MVP040-14	1	94%	Attic	R-6	25,595	40,000	PLAN 1143
Furnace	CARRIER #58MVP040-14	1	94%	Attic	R-6	30,198	40,000	PLAN 1144

Cooling Equipment

Equip. Type (pkg. Heat pump)	CEC Certified Compressor Unit Mfr Name and Model #	# of Identical Systems	(1) Efficiency (SEER, etc.) > CF-1R value	Duct Location (attic, etc.)	Duct R-value	Cooling Load (Btu/hr)	Cooling Capacity (Btu/hr)	
A/C	CARRIER #38TDB036 *	1	16	Attic	R-6	22,053	36,000	PLAN 1141
A/C	CARRIER #38TDB036 *	1	16	Attic	R-6	23,238	36,000	PLAN 1142
A/C	CARRIER #38TDB036 *	1	16	Attic	R-6	23,151	36,000	PLAN 1143
A/C	CARRIER #38TDB036 *	1	16	Attic	R-6	26,728	36,000	PLAN 1144

(1) > reads greater than or equal to. * = TXV installed with coil
 I, the undersigned, verify that equipment listed above is: 1) the actual equipment installed, 2) equivalent to or more efficient than that specified in the certificate of compliance (Form CF-1R) submitted for compliance with the Energy Efficiency Standards for residential buildings, and 3) equipment that meets or exceeds the appropriate requirements for manufactured devices (from the Appliance Efficiency Regulations or Part 6), where applicable.

[Signature]
 Signature, Date

Beutler Corporation

Installing Subcontractor (Co. Name)
 OR General Contractor (Co. Name) OR Owner

WATER HEATING SYSTEMS:

Heater Type	CEC Certified Mfr Name & Model #	Distribution Type (Std. point of use)	If Recirculation Control Type	# of Identical Systems	(2) Rated Input (kW or Btu/hr)	Tank Volume (gallons)	(2) Efficiency (EF,RE)	(2) Standby Loss (%)	External Insulation R-value
GAS	RHEEM 41VRC2-40TE	SIR	N/A	N/A	40,000	50			19.2

(2) For small gas storage (rated input of less than or equal to 75,000 Btu/hr), electric resistance and heat pump water heaters, list Energy Factor. For large gas storage water heaters (rated input of greater than 75,000 Btu/hr), list Recovery Efficiency, Standby Loss and Rated Input. For instantaneous gas water heaters, list Recovery efficiency and Rated Input.
 (3) R-12 external insulation is mandatory for storage water heaters with an energy factor of less than 0.58.

Facets & Shower Heads:

All facets and showerheads installed are certified to the Commission, pursuant to Title 24, Part 6, Section 111.

I, the undersigned, verify that equipment listed above my signature is: 1) the actual equipment installed; 2) equivalent to or more efficient than that specified in the certificate of compliance (Form CF-1R) submitted for compliance with the Energy Efficiency Standards for residential buildings; and 3) equipment that meets or exceeds the appropriate requirements for manufactured devices (from the Appliance Efficiency Regulations or Part 6), where applicable.

[Signature]
 Signature, Date

BEUTLER CORP. (RENAISSANCE HOMES)

Installing Subcontractor (Co. Name)
 OR General Contractor (Co. Name) OR Owner

COPY TO: Building Department
 HERS Provider (if applicable)
 Building Owner at Occupancy